

ANNEXURE-12: PRE-BID QUERIES FORMAT
[For Technical Specification, PY-51282, Rev00]

Sl. No.	Section / Part/Subsection	Page No.	Clause No.	Bid Specification	Bidder's Query	Purchaser's Reply Dtd: 05.12.17
1.	Annexure-2A/2C of Technical Specification for Fire Water Pumps, Doc. No. PY-51282	25 & 32	S.No. 19 & 97	S.No. 19: Rated speed of Engine: 1500 rpm S.No. 97: Speed of Engine: Not more than 2300 rpm.	WHETHER ENGINE TO BE OFFERED WITH 2300RPM OR UPTO 1500 RPM . AS PER DATA SHEET BOTH ARE MENTIONED	Bidder to Select engine speed as 1500 rpm suitable for pump speed.
2.	Annexure-2A/2B/2C of Technical Specification for Fire Water Pumps, Doc. No. PY-51282	27, 31 & 34	S.No. 82, 81 & 82	S.No. 81/ 82: Cable, Cable glands & Lugs: Cable details shall be furnished during During Detail Engg. Accordingly suitable double compression Nickel plated brass cable glands and Tinned copper lugs to be provided by the bidder.	CABLE GLANDS AND LUGS FOR HT MOTORS ARE GIVEN IN OUR SCOPE WHERE AS HT MOTORS ARE NOT IN OUR SCOPE. WE REQUEST YOU TO INCLUDE THE SAME IN YOUR SCOPE	Cable, Cable Glands, & Lugs of HT Motors are excluded from bidder scope of supply.
3.	Annexure-4A/2B/2C of Technical Specification for Fire Water Pumps, Doc. No. PY-51282	46, 49 & 51	S.No. D.1.4	Bearing Rings : Sets of Each Type	MANDATORY SPARES FOR PUMPS MENTIONS BEARING RINGS : KINDLY NOTE BEARING RINGS ARE NOT APPLICABLE FOR PUMPS. PLEASE CLARIFY WHETHER SAME IS WEARING RING?	As per contract specification, it is bearing rings. Hence, Bidder to consider bearing rings (If Applicable).

Additional Clarifications

Mandatory spares:

A) If any of the items indicated by the specified name are not applicable, bidder to offer alternative item serving the same function as per equipment's design and indicate the item being replaced.

B) If bidder is not able to meet the above note-A, then bidder may mention "Not Applicable" in the price bid format. However, if found applicable during detailed engg. stage or alternative item as per equipment design can serve the same function, bidder to supply the specified quantity without any delivery and commercial implications to BHEL.

Note: During Preparation of Pre-Bid Queries, Complete Tender Specification Doc. No. PY-51282 (along with all Annexures) shall also be referred.