

**3 x 800 MW PVUNL PATRATU TPP PHASE-I - FQA LAB MECHANICAL****BOQ CUM UNPRICE SCHEDULE****TECHNICAL SPECIFICATION: PE-TS-434-571-A001A**

S. No.	ITEM CODE For INDENT	ITEM DESCRIPTION	QTY	UOM	HSN Code	To be filled by bidder (Quoted/Not Quoted)
1	Total lump sum firm price of equipment / item inclusive of all prevailing taxes, duties and other levies for SUPPLY PART comprising of design (i.e. preparation and submission of drawing /documents including "As Built" drawings and O&M manuals), engineering,manufacture, fabrication, assembly, inspection / testing at vendor's & sub-vendor's works, painting, cutting tools and cutting tool mounting accessories (as applicable), maintenancetools & tackles (as applicable), fill of lubricants & consumables, alongwith spares forerection, startup and commissioning as required, foundation bolts, nuts, lock nuts, washers, levelling pads, forwarding, proper packing, shipment and delivery at site for project and package specified above complete with all accessories for the total scope defined as per BHEL NIT & tender technical specification, amendment & agreements till placement of order.					
1	571-01002-A	ALCO Meter-Ultrasonic digital (Coating Thickness Meter)	1	NOS.	90318000	
2	571-01003-A	D-Meter-Digital (ultrasonic Thickness gauge)	1	NOS.	90318000	
3	571-01004-A	Ultrasonic testing machine	1	NOS.	90318000	
4	571-01009-A	Helium Leak Detector	1	NOS.	90271000	
5	571-01010-A	Hardness Tester (Portable type)	1	NOS.	90248091	
6	571-01011-A	Rubber Hardness tester	1	NOS.	90248091	
7	571-01012-A	XRF metal Analyser (Handheld)	1	NOS.	90221900	
<b>Note :- Bids shall be evaluated on item wise basis.</b>						

## **Risk & Cost Purchase clause- Annexure-II**

BHEL reserves the right to terminate the contract or withdraw portion of work and get it done through other agency, at the risk and cost of the contractor after due notice of a period of 14 days' by BHEL in any of the following cases:

- i) If the Seller/Contractor fails to deliver the goods or materials or any instalment thereof within the period(s) fixed for such delivery or the Seller's poor progress of the supply/ services vis-à-vis delivery/execution timeline as stipulated in the Contract, backlog attributable to seller including unexecuted portion of supply does not appear to be executable within balance available period;
- ii) Delivers goods or materials not of the contracted quality and failing to adhere to the contract specifications;
- iii) Withdrawal from or repudiation/ abandonment of the supply/ services by Seller before completion as per contract or if the Seller refuses or is unable to supply goods or materials covered by the Order/Contract either in whole or in part or otherwise fails to perform the Order/Contract;
- iv) Non-supply by the Seller within scheduled completion/delivery period as per Contract or as extended from time to time, for the reasons attributable to the Seller;
- v) Termination of Contract on account of any other reason (s) attributable to Seller.
- vi) Assignment, transfer, subletting of Contract without BHEL's written permission resulting in termination of Contract or part thereof by BHEL.
- vii) If the Seller be an individual or a sole proprietorship Firm, in the event of the death or insanity of the Seller;
- viii) If the Seller/Contractor being an individual or if a firm on a partnership thereof, shall at any time, be adjudged insolvent or shall have a receiving order for administration of his estate made against him or shall take any proceeding for composition under any Insolvency Act for the time being in force or make any assignment of the Order/Contract or enter into any arrangement or composition with his creditors or suspend payment or if the firm dissolved under the Partnership Act;
- ix) If the Seller/Contractor being a company is wound up voluntarily or by order of a Court or a Receiver, Liquidator or Manager on behalf of the debenture holders and creditors is appointed or circumstances shall have arisen which entitles the Court of debenture holder and creditors to appoint a receiver, liquidator or manager;
- x) Non-compliance to any contractual condition or any other default attributable to Seller.

Such defaulting vendor/Seller shall not be eligible to participate in re-tendering conducted on account of risk purchase made due to fault of such vendor/Seller.

### **3.1 Risk & Cost Amount against Balance Work:**

Risk & Cost amount against balance work shall be calculated as follows:

$$\text{Risk \& Cost Amount} = [(A-B) + (A \times H/100)]$$

Where,

A= Value of Balance scope of Work (\*) as per rates of new contract

## **Risk & Cost Purchase clause- Annexure-II**

B= Value of Balance scope of Work (\*) as per rates of old contract being paid to the contractor at the time

of termination of contract i.e. inclusive of PVC & ORC, if any.

H = Overhead Factor to be taken as 5

In case (A-B) is less than 0 (zero), value of (A-B) shall be taken as 0 (zero).

### **3.2 \* Balance scope of work (in case of termination of contract):**

Difference of Contract Quantities and Executed Quantities as on the date of issue of Letter for 'Termination of Contract', shall be taken as balance scope of Work for calculating risk & cost amount.

Contract quantities are the quantities as per original contract. If, Contract has been amended, quantities as per amended Contract shall be considered as Contract Quantities.

Items for which total quantities to be executed have exceeded the Contract Quantities based on drawings issued to contractor from time to time till issue of Termination letter, then for these items total Quantities as per issued drawings would be deemed to be contract quantities.

Substitute/ extra items whose rates have already been approved would form part of contract quantities for this purpose.

Substitute/ extra items which have been executed but rates have not been approved, would also form part of contract quantities for this purpose and rates of such items shall be determined in line with contractual provisions.

However, increase in quantities on account of additional scope in new tender shall not be considered for this purpose.

NOTE: In case portion of work is being withdrawn at risk & cost of contractor instead of termination of contract, contract

quantities pertaining to portion of work withdrawn shall be considered as 'Balance scope of work' for calculating Risk &

Cost amount.

### **3.3 LD against delay in executed work in case of Termination of Contract:**

LD against delay in executed work shall be calculated in line with LD clause no. 16 of GCC, for the delay attributable to

contractor. For limiting the maximum value of LD, contract value shall be taken as Executed Value of work till termination

of contract.

Method for calculation of LD against delay in executed work in case of termination of contract" is given below.

i. Let the time period from scheduled date of start of work till termination of contract excluding the period of

Hold (if any) not attributable to contractor = T1

ii. Let the value of executed work till the time of termination of contract = X

### **Risk & Cost Purchase clause- Annexure-II**

iii. Let the Total Executable Value of work for which inputs/fronts were made available to contractor and were

planned for execution till termination of contract = Y

iv. Delay in executed work attributable to contractor i.e.  $T2 = [1 - (X/Y)] \times T1$

v. LD shall be calculated in line with LD clause (clause 16) of the Contract for the delay attributable to contractor taking "X" as Contract Value and "T2" as period of delay attributable to contractor.


#### **3.4. Recoveries arising out of Risk & Cost and LD or any other recoveries due from Contractor**

Without prejudice to the other means of recovery of such dues from the Seller recoveries from the Seller on whom risk & cost has been invoked shall be made from the following:

- a) Dues available in the form of Bills payable to seller, SD, BGs against the same contract.
- b) Dues payable to seller against other contracts in the same Region/Unit/ Division of BHEL.
- c) Dues payable to seller against other contracts in the different Region/Unit/ division of BHEL.

In-case recoveries are not possible with any of the above available options, Legal action shall be initiated for recovery against contractor.

**BHEL-PEM-MAUX**  
**PRE-QUALIFICATION CRITERIA**

	<b>PACKAGE: FQA LAB MECHANICAL</b> <b>PROJECT: 3X800 MW PATRATU TPP PHASE-I</b> <b>PRE-QUALIFICATION REQUIREMENT- FQA LAB MECHANICAL</b>		PE-PQ-999-571-A001	
			DATE	19.10.2021
			REV NO	00

1.0	Supplier should have capability of manufacturing and facility for testing of at least one of the following Machines: - <table><tr><th>S. N.</th><th>Machine Name</th><th>Machine Specification</th></tr><tr><td>1</td><td>D-Meter-Digital (Ultrasonic Thickness gauge)</td><td>Ultrasonic thickness gauge machine having range 1 mm to 150 mm thickness range.</td></tr><tr><td>2</td><td>Ultrasonic testing machine</td><td>High Performance Ultrasonic flaw detector.</td></tr><tr><td>3</td><td>Helium Leak Detector</td><td>Leak rate 1.0 X10-2 to 1.0 X10-5 mbar lit / Sec</td></tr><tr><td>4</td><td>Hardness Tester (Portable type)</td><td>Hardness range for steel and cast steel-80-400 BHN (Brinell) , SS - 85-400 BHN</td></tr><tr><td>5</td><td>XRF metal Analyser (Handheld)</td><td>Hand Held metal analyser. Miniature X ray tube.</td></tr></table>	S. N.	Machine Name	Machine Specification	1	D-Meter-Digital (Ultrasonic Thickness gauge)	Ultrasonic thickness gauge machine having range 1 mm to 150 mm thickness range.	2	Ultrasonic testing machine	High Performance Ultrasonic flaw detector.	3	Helium Leak Detector	Leak rate 1.0 X10-2 to 1.0 X10-5 mbar lit / Sec	4	Hardness Tester (Portable type)	Hardness range for steel and cast steel-80-400 BHN (Brinell) , SS - 85-400 BHN	5	XRF metal Analyser (Handheld)	Hand Held metal analyser. Miniature X ray tube.
S. N.	Machine Name	Machine Specification																	
1	D-Meter-Digital (Ultrasonic Thickness gauge)	Ultrasonic thickness gauge machine having range 1 mm to 150 mm thickness range.																	
2	Ultrasonic testing machine	High Performance Ultrasonic flaw detector.																	
3	Helium Leak Detector	Leak rate 1.0 X10-2 to 1.0 X10-5 mbar lit / Sec																	
4	Hardness Tester (Portable type)	Hardness range for steel and cast steel-80-400 BHN (Brinell) , SS - 85-400 BHN																	
5	XRF metal Analyser (Handheld)	Hand Held metal analyser. Miniature X ray tube.																	
2.0	<p>The supplier has to submit either of following supporting documents meeting above mentioned pre-qualifying requirement</p> <p>a. Copy of minimum one (1) performance certificate in English from end user along with copy of related Purchase Order (PO) or letter of intent (LOI) or letter of award (LOA) or work order (WO) specifying that the product/ equipment is running successfully for one (1) year from date of commissioning meeting the minimum pre-qualifying requirement. OR</p> <p>b. Minimum two PO/ LOI /LOA/ WO placed with a minimum gap of six (6) months from same purchaser meeting the minimum pre-qualifying requirement. OR</p> <p>c. Minimum one PO/ LOI /LOA/ WO after commissioning of first order from same purchaser meeting the minimum pre-qualifying requirement. OR</p> <p>d. Minimum three customer's/ third party's inspection reports/ test certificates/commissioning certificates meeting the minimum pre-qualifying requirement.</p>																		
3.0	Indian stockist/ trader/ distributor/ dealer/ authorized agent/ channel partner/ Indian sales office or subsidiary of principal - with aftersales service agreement with OEM/principal are also acceptable provided OEM/principal meets the minimum pre-qualification criteria stipulated above at S.no 1.																		
4.0	Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.																		
5.0	Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.																		
6.0	Consideration of offer shall be subject to customer's approval of bidders, if applicable.																		
7.0	After satisfactory fulfilment of all the above criteria / requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.																		

Prepared by

Reviewed by

Approved by

**NTPC LIMITED**

(A Govt. of India Enterprise)



**PATRATU SUPER THERMAL POWER PROJECT  
EXPANSION PHASE-I (3X800 MW).**

**TECHNICAL SPECIFICATION  
FOR  
FQA LAB MECHANICAL**

**SPECIFICATION NO: PE-TS-434-571-A001A**



**BHARAT HEAVY ELECTRICALS LIMITED**

(A Govt. of India Undertaking)

**POWER SECTOR**

**PROJECT ENGINEERING MANAGEMENT**

**NOIDA, U.P**

**INDIA**



TITLE

**TECHNICAL SPECIFICATION  
FOR  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS – 434 - 571 – A001A

VOLUME II

SECTION

REV 0

SHEET OF

**CONTENTS**

<b><u>S. N.</u></b>	<b><u>SECTION</u></b>	<b><u>TITLE</u></b>
1.0	VOLUME II - B	
	SECTION - A	Scope of enquiry
	SECTION - C	Specific technical requirements
		Drawing / Document distribution schedule Annexure II and MDL Annexure-III
		Painting Specification Annexure-IV
		MQP and FQP Annexure V
		Electrical equipment specification
2.0	VOLUME - III	
		Documents Furnished Along with Offer
		Compliance Cum Confirmation Certificate
		Electrical Load Data

513079/2021/PS-PEM-MAX

PEM-6666-0

TITLE



**TECHNICAL SPECIFICATION  
FOR  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS - 434 - 571 – A001A

VOLUME II B

SECTION A

REV 0

SHEET OF

# SECTION - A

## SCOPE OF ENQUIRY





TITLE

# TECHNICAL SPECIFICATION FOR FQA LAB MECHANICAL

SPECIFICATION NO. PE-TS-434-571-A001A

VOLUME II B

SECTION A

REV 00

Page 1 of 2

## 1.0 SCOPE OF ENQUIRY/ INTENT OF SPECIFICATION

- 1.1 The specification is intended to cover design, engineering, manufacture, inspection and testing at vendor's/ sub-vendor's works, painting, proper packing and supply and dispatch to power station site, Performance and guarantee testing and handing over of **FQA LAB MECHANICAL** as per details in different sections / volumes of this specification for **3 X 800 MW PATRATU STPP**.
- 1.2 The contractor shall be responsible for providing all material, equipment & services, which are required to fulfil the intent of ensuring operability, maintainability, reliability and complete safety of the complete work covered under this specification, irrespective of whether it has been specifically listed herein or not. Omission of specific reference to any component / accessory necessary for proper performance of the equipment shall not relieve the vendor from the responsibility of providing such facilities to complete the supply of **FQA LAB MECHANICAL**.
- 1.3 It is not the intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respects to high standards of design, engineering and workmanship and shall be capable of performing the required duties in a manner acceptable to purchaser who will interpret the meaning of drawings and specifications and shall be entitled to reject any work or material which in his judgement is not in full accordance herewith.
- 1.4 The extent of supply under the contract includes all items shown in the drawings, notwithstanding the fact that such items may have been omitted from the specification or schedules. Similarly, the extent of supply also includes all items mentioned in the specification and /or schedules, notwithstanding the fact that such items may have been omitted in the drawing.
- 1.5 The general term and conditions, instructions to tenderer and other attachment referred to elsewhere are made part of the tender specification. The equipment materials and works covered by this specification is subject to compliance to all attachments referred to in the specification. The bidder shall be responsible for and governed by all requirements stipulated herein.
- 1.6 While all efforts have been made to make the specification requirement complete & unambiguous, it shall be bidders' responsibility to ask for missing information, ensure completeness of specification, to bring out any contradictory / conflicting requirement in different sections of the specification and within a section itself to the notice of BHEL and to seek any clarification on specification requirement in the format enclosed under Vol-III of the specification. In absence of any such clarifications, in case of any contradictory requirement, the more stringent requirement as per interpretation of Purchaser/Customer shall prevail and shall be complied by the bidder without any commercial implication on account of the same. Further in case of any missing information in the specification not brought out by the prospective bidders as part of pre-bid clarification, the same shall be furnished by Purchaser/ Customer as and when brought to their notice either by the bidder or by purchaser/ customer themselves. However, such requirements shall be binding on the successful bidder without any commercial & delivery implication.



TITLE

TECHNICAL SPECIFICATION FOR  
FQA LAB MECHANICAL

SPECIFICATION NO. PE-TS-434-571-A001A

VOLUME II B

SECTION A

REV 00

Page 2 of 2

- 1.7 The bidder's offer shall not carry any sections like clarification, interpretations and /or assumptions.
- 1.8 Deviations, if any, should be very clearly brought out clause by clause in the enclosed schedule; otherwise, it will be presumed that the vendor's offer is strictly in line with NIT specification.
- 1.9 In case all above requirements are not complied with, the offer may be considered as incomplete and would become liable for rejection.
- 1.10 Unless specified otherwise, all through the specification, the word contractor shall have same meaning as successful bidder /vendor and Customer/ Purchaser/Employer will mean BHEL and /or NTPC including their consultant as interpreted by BHEL in the relevant context.

513079/2021/PS-PEM-MAX

PEM-6666-0

TITLE



**TECHNICAL SPECIFICATION  
FOR  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS - 434 - 571 – A001A

VOLUME II B

SECTION C

REV 0

SHEET OF

## SECTION - C

## SPECIFIC TECHNICAL REQUIREMENTS



TITLE

**SPECIFIC TECHNICAL  
REQUIREMENTS  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS – 434 - 571 – A001A

VOLUME II B

SECTION C

REV 0

SHEET 1 OF 11

### 1.0 **SYSTEM DESCRIPTION AND SCOPE OF WORK**

Various types of equipment / machines which are included in bidder's scope of work and required for the maintenance and repair of the power station equipment are given under :-

S. N.	EQUIPMENT NAME	TECHNICAL SPECIFICATION	QTY.
1.	ALCO Meter-Ultrasonic digital (Coating Thickness Meter)	Coating Thickness meter (for measuring the thickness of paint, Proceldain enamel, aluminium) , Thickness range 0-500 micron, resolution 0.1 Micron, Accuracy $\pm 5\%$	1
2.	D-Meter-Digital (ultrasonic Thickness gauge)	Ultrasonic thickness gauge machine having range 1 mm to 199.9 mm thickness range depends on material, transducer type, surface condition and component temperature, testing method Pulse echo, Material metal and non metals.	1
3.	Ultrasonic testing machine	High Performance Ultrasonic flaw detector with: High definition LCD display, built in single board computer, Tunable square wave pulser, receiver band width 0.5 to 20 MHz by wide band.	1
4.	Helium Leak Detector	Leakage rate varies from $1.0 \times 10^{-2}$ to $1.0 \times 10^{-5}$ mbar lit/sec , Temperature of dry air at out let of Vacuum pump around 49.0 deg C, bidder to provide cooling and dehumidifying unit suitable for helium leak detector selected for helium leak detector selected for leakage rate specified above, sampling probe, spray gun for helium spraying, valve and other required accessories for completeness of system / equipment.	1
5.	Hardness Tester (Portable type)	Hardness range for steel and cast steel-80-647 BHN (Brinell) , SS - 85-655 BHN average measuring deviation $\pm 1\%$ .	1
6.	Rubber Hardness tester	Plunger type rubber hardness tester, Minor force $30.6 \pm 2$ gm, major force $550.5 \pm 1$ gm, Radio us of indenter 1.25mm, dial gauge 0-10X0.01mm, Related standard ASTM D 1415-81 Rubber property- International hardness	1
7.	XRF metal Analyser (Handheld)	Hand Held metal analyser, Miniature X ray tube, Alloy measuring range Titanium, Vanadium, magnesium, Chromium. USB cable With PC Software	1

### **NOTES:-**

- 1) Maintenance tools and tackles as required for the various machines / equipments, commissioning spares for various machines as applicable, first fill lubricant /coolant for each equipment is included in Bidder's scope of work.
- 2) Machines shall be supplied with the manufacturer's standard accessories & other accessories as indicated above.

### 2.0 **The followings shall also be included in bidder's scope of work:-**

- 2.1 Required numbers of machines in new / unused condition along with standard accessories and special accessories as listed above in the specification.
- 2.2 First fill of lubricants, oil, coolants etc. for all machines.



TITLE

**SPECIFIC TECHNICAL  
REQUIREMENTS  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS – 434 - 571 – A001A

VOLUME II B

SECTION C

REV 0

SHEET 2 OF 11

- 2.3 Painting of equipment shall be done by the bidder before despatch as per the attached painting schedule. Bidder shall also supply adequate quantity of loose touch up paint along with the equipment so that damage in transition, if any, can be taken care.
- 2.4 Base plates, Support plates, anchor bolts, foundation bolts and nuts, lifting lugs, eye bolts etc. if any. All commissioning spares shall be included in the scope of work of each equipment / item.
- 2.5 Terminal points for electrical shall be the power supply terminals in respective machines and power cable glands and lugs shall be in bidder's scope.
- 2.6 The electrical equipment supplied as a part of machine shall include isolating switch for power supply isolation incorporating mechanical safety as required.
- 2.7 VOID.
- 2.8 Commissioning spares shall be included in the scope of work of the bidder.
- 2.9 A complete unused new set of special purpose service / maintenance tools & tackles shall be supplied with each machine. The tools shall be supplied in steel tool box & shall be of the best quality & specially protected against rusting in tropical climate.
- 2.10 VOID.
- 2.11 Five (5) metres of power cable (spare) shall be supplied alongwith each machine / item.
- 2.12 Any other works not covered above but required for the safe operation of the machines.
- 3.0 **CODES & STANDARD**
- The machines covered under the scope of work shall be new, of streamlined construction, rugged and vibration free in line with the Indian / international standard and practices.
- 4.0 **SERVICES BY CUSTOMER**
- 4.1 Draining arrangement of liquid coolant from source to the nearest drain.
- 4.2 Construction of FQA Lab Building.
- 4.3 Pipe trench & cable trenches, doors / windows, rolling shutter, ramp and glass partition wall, if any.
- 4.4 Cable termination.
- 4.5 Erection and commissioning of FQA Lab.
- 5.0 **DOCUMENTS AND DATA REQUIRED TO BE SUBMITTED AFTER PLACEMENT OF LOI**
- Following drawings and documents shall be submitted to BHEL for approval after the placement of LOI:-
- a) General arrangement drawing indicating overall dimensions, total weights, foundation details and bill of material for all types of machines including requirement of withdrawal space.



TITLE

**SPECIFIC TECHNICAL  
REQUIREMENTS  
FAQ LAB MECHANICAL**

SPECIFICATION NO. PE – TS – 434 - 571 – A001A

VOLUME II B

SECTION C

REV 0

SHEET 3 OF 11

- b) Final details of motors (machine wise) indicating guaranteed power consumption as per BHEL's format.
- c) Manual calculation for selection of machines including authentic supporting literature (e.g. handbook / standards).
- d) Manual calculation for requirement of air / water quantity and pressure including authentic supporting literature (e.g. handbook / standards).
- e) Final filled up Data sheet "B" / Data sheet "C"
- f) Quality assurance plan being followed for all items of each type of machine starting from raw material to final product including routine and type test being conducted at works.
- g) Write - up on working principle and special safety features envisaged for each type of machines.
- h) Final requirement of air and water indicating quantity, pressure and terminal points, if any.
- i) Painting schedule.
- j) O & M manual.
- k) List of spares (commissioning).
- l) List of Tools and Tackles.
- m) Schedule of lubricants indicating quantity, make and trade name of at-least three manufacturers.
- n) Data sheet of machines / equipment.

**NOTE:-**

- 1) The list of drawings and documents to be submitted after placement of order shall be forwarded to the successful bidder after award of contract.
- 2) Only manual calculation with authentic supporting literature shall be furnished (e.g. Hand book / standards / codes).
- 3) Drawings and documents not covered above but required to check safety of machines / system shall be submitted during detailed engineering stage without any commercial implication.

**6.0 General requirement**

- 01. All the drawings shall be prepared in Auto Cad - 2007 version and required number of hardcopies and soft copies of all the drawings, documents, O & M and spare parts manuals shall be furnished to BHEL during detailed engineering stage as per Annexure – II enclosed with the NIT specification.
- 02. Inspection checklist / quality plan and recommended field quality plan for each machine and submitted to BHEL for approval after placement of order and any changes required by BHEL / CUSTOMER for the same shall be incorporated and adhered by the bidder without any commercial implications.



TITLE

**SPECIFIC TECHNICAL  
REQUIREMENTS  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS – 434 - 571 – A001A

VOLUME II B

SECTION C

REV 0

SHEET 4 OF 11

03. BHEL will require 21 days time to offer their comments on the drawings and documents being submitted by the bidder from the date of receipt.
04. All drawings including general arrangement, civil foundation drawing shall be furnished to BHEL during detailed engineering stage and shall include BOQ / BOM in tabular form indicating all major components including bought out items, standard as well as optional accessories which are covered under the bidder's scope of supply and their quantity, material of construction indicating its applicable code / standard, weight, make.
05. All drawings of each machine including general arrangement and foundation drawings if required shall be furnished to BHEL during detailed engineering stage and shall include / indicate the following details for clarity w.r.t. inspection, construction, erection and maintenance etc. :-
- All drawings and documents shall bear BHEL's title block and drawing / document number. However, BHEL's drawing / document numbering scheme shall be furnished to the successful bidder after the placement of L.O.I.
  - All drawings shall indicate the list of all reference drawings including general arrangement and foundation drawings.
  - All drawings shall include / show plan, elevation, side view, cross - section, skin section, blow - up view and all major self-manufactured, bought out items, standard as well as optional accessories which are covered under the bidder's scope of supply shall be labelled and included in BOQ / BOM in tabular form.
  - Specification / schedule of coolant / oil for oil cooler / lubricant / paint indicating at least 3 trade name shall be made as a part of general arrangement drawing of each machine.
  - Extreme location of various items / assembly due to movement shall be shown in dotted lines indicating the dimensions of the same from the extreme point of idle location.
  - Location of motor (s), control panel along with dimensions shall be shown in the drawing.
  - Space required for the door opening of panel shall be shown in dotted lines with dimensions in all the general arrangement drawing.
  - Details of job feeding and withdrawal direction with arrow and its required space shall be shown in dotted lines with dimensions from some reference point like edge / center of the machine.
  - Location of operator and required space for his movement shall be shown in the general arrangement drawing in dotted lines with dimensions from some reference point like edge / center of the machine.
  - Requirement of withdrawal space for maintenance, if any, shall be shown in the general arrangement drawing in dotted lines with dimensions from the reference point like edge / center of the machine.
  - Recommended clearance / maintenance space around the machine shall be shown in the general arrangement drawing in dotted lines with dimensions from the reference point like edge / center of the machine.



TITLE

**SPECIFIC TECHNICAL  
REQUIREMENTS  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS – 434 - 571 – A001A

VOLUME II B

SECTION C

REV 0

SHEET 5 OF 11

- l) Mounting details of each machine indicating size and required number of holes and the distances between them shall be indicated in the general arrangement drawing.
- m) Distance between the mounting holes and distances of the same from some reference point like center line of machine / edge of the machine to ensure correct construction of foundation and to know maximum space required for civil foundation and mechanical equipment.
- n) Technical parameters of the machine shall be furnished (gearbox details, job rpm, vibration limit, noise level at a distance of 1.0 meter at a level of 1.5 meters above ground, V - belt details, details of pulley, details of all motors and hydraulics, whether the machine will be dispatched / delivered in the assembled condition or dismantled condition indicating the weight as the case may be, recommended capacity of E.O.T Crane, weight of heaviest (single) part / component of the machine, weight of machine along with accessories, job and total weight shall be furnished separately etc.) in all the general arrangement drawing and those shall be indicated in the drawing with dimensions to the extent possible.
- o) Details of cable entry for each machine shall be shown in all the 3 views (plan, elevation and side view).
- p) Hardness and type / method of hardening of various parts of each machine shall be indicated in the general arrangement drawing.
06. Manual Calculation for motor (s) sizing shall be furnished to BHEL during detailed engineering stage for approval along with the copy of authentic supporting literature e.g. Hand book, National / international Standards etc in line with the technical specification.
07. O & M manual shall be furnished to BHEL for approval during detailed engineering stage along with the general arrangement drawing.
08. Drawing / data sheet of all accessories shall be furnished to BHEL for approval during detailed engineering stage indicating brief specification.
09. Operational write-up along with safety features and interlock / control details of each machine shall be furnished to BHEL separately for approval during detailed engineering stage.
10. Separate drawing for lifting arrangement of machine during erection shall be furnished to BHEL for approval indicating dimensions and details of lifting lugs, rope etc.
11. Civil foundation drawing of each machine if applicable shall be furnished to BHEL for approval during detailed engineering stage showing / including the followings: -
  - a) Scope of work by BHEL and vendor which shall be indicated with different legend or in the form of note.
  - b) Weight of moving parts, its frequency and its height from floor shall be furnished.
  - c) Recommended location of cable trench for feeding cable to machine shall be furnished along with the details of cable entry.
  - d) Civil loads per bolt (static and dynamic) shall be furnished in tabular form considering weight of maximum size of job and worst cutting force.





TITLE

**SPECIFIC TECHNICAL  
REQUIREMENTS  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS – 434 - 571 – A001A

VOLUME II B

SECTION C

REV 0

SHEET 6 OF 11

12. Separate general arrangement drawing of drive arrangement shall be furnished to BHEL for approval during detailed engineering stage.
13. Characteristic curve of motor shall be furnished to BHEL for approval during detailed engineering stage showing torque, speed, current & voltage.
14. Design of machines shall be such that no cooling water / air from external source shall be required for cooling of any part of machine. Necessary cooling arrangement, as required, shall be provided by the bidder in their machines.
15. First fill of all oil, lubricants, coolants etc. shall be included in scope of work of the bidder for each machine and shall be supplied along with the machine and **price for the same shall be taken care in the price bid, if any.**
16. Filled up sketch indicating various dimensions for the space requirements of each equipment, center line of job feeding and its dimension from some reference point like the center line of machine or edge of the machine, location of operator, direction of job feeding & withdrawal and details of cable entry.
17. Bidder has to depute competent designer (s) of each machine at BHEL's office during detailed engineering stage to discuss drawings and other technical documents as and when required by BHEL. However, minimum 7 days notice shall be served for the same.
18. **Unit price for each special accessories of each machine shall be furnished in the price bid.**
19. Make of various bought items shall be as indicated in the NIT specification. Bidder will seek approval from BHEL during detailed engineering stage for those items which are not appearing in the list but required for the machine. However, Bidder shall not approach BHEL for approval of additional make of any item which is already appearing in the list.
20. Painting specification and schedule shall be provided by the bidder for each machine as indicated in the NIT specification. However, painting specification of those items / equipments which are not covered in the specification, bidder to prepare the painting specification (suitable for sea atmosphere) for each item / machine / equipment and will be submitted to BHEL / CUSTOMER for approval after placement of order and any changes required by BHEL / CUSTOMER for the same shall be incorporated and adhered by the bidder without any commercial implications. Bidder to include adequate quantity of loose touch up paint for each item / equipment / machine which is required to be supplied along with the item / equipment / machine to take care damage during transit and price for the same, if any, shall be taken care in the price bid.
21. Noise level for each machine at a horizontal distance of 1.0 meter from the edge of the machine and at a height of 1.5 meters from the ground shall be limited to 85 dba and the same shall be shown during the "PG" test.
22. Inspection checklist / PG TEST procedure etc. shall be prepared by the bidder and will be submitted to BHEL / CUSTOMER for approval after placement of order and any changes required by BHEL / CUSTOMER for the same shall be incorporated and adhered by the bidder without any commercial implications. Necessary instruments / job material (steel plate / bar etc.) as required for the testing / inspection of machines shall be arranged by the bidder and shall also be included in bidder's scope of work.



TITLE

**SPECIFIC TECHNICAL  
REQUIREMENTS  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS – 434 - 571 – A001A

VOLUME II B

SECTION C

REV 0

SHEET 7 OF 11

23. All foundation nuts, bolts, lock nuts, washers etc. as required for fixing the machine with foundation shall be included in bidder's scope of work for each machine and the same shall be supplied along with the machine and **price for the same shall be taken care in the price bid, if any.**
24. All necessary guards, devices, tools & other means that will effectively protect all personnel from any accidental or injury that may occur while machine is in running condition shall be in bidder's scope of work and shall be provided and shown in the drawings to be submitted during detail engineering stage.
25. Offered machines shall be suitable for the electrical conditions like voltages, frequencies, variations etc. as indicated in project information of NIT specification.
26. BHEL, will provide one (1) no. feeder per machine. Bidder to note & confirm that they will distribute the power requirement of various motors at their end only for this feeder.
27. VOID.
28. List of maintenance tools / hand tools & tackles in terms of numbers only indicating sizes / ratings etc. in annexure form for each machine shall be submitted during detail engineering stage and the same shall be included in bidder's scope of work. Maintenance tools and tackles shall be supplied along with the tool box(es) and **price for the same shall be taken care in the final price bid, if any.**
29. VOID.
30. List of commissioning spares in terms of numbers only indicating sizes / ratings etc. in annexure form for each machine shall be indicated in the offer and shall be supplied along with the machine. **Price for the same shall be taken care in the final price bid, if any.**
31. VOID.
32. Necessary earthing studs / facilities for the machine and cables within the machine shall be provided by the bidder.
33. All machines shall be provided with DOL starter.
34. Bidder to furnish the Signed & stamped copy of quality plan for motors attached with the NIT specification during detail engineering stage.
35. Cable Glands shall be double compression tinned brass type and the cable glands shall be supplied as a part of each machine and **price for the same shall be taken care in the price bid, if any.**
36. All cable lugs shall be heavy-duty tin-plated crimping type the cable lugs shall be supplied as a part of each machine and **price for the same shall be taken care in the price bid, if any.**
37. All technical parameters of LV motors shall comply data sheet –A for LV motors.



TITLE

**SPECIFIC TECHNICAL  
REQUIREMENTS  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS – 434 - 571 – A001A

VOLUME II B

SECTION C

REV 0

SHEET 8 OF 11

38. Filled up motor data sheet of motor (for each motor) and filled up electrical load data format (enclosed with the NIT specification) for each machine shall be submitted during detail engineering stage.
39. All the hand wheels shall be polished / Nickel - Chrome plated.
40. List of standard accessories (which will be supplied free of cost along with the machine) in terms of numbers only for each machine shall be indicated in the offer and included in bidder's scope of work. **Price for the same shall be taken care in the price bid, if any.**
41. Bidder to indicate the material of construction of major parts of the machines indicating relevant IS / BS no.

**7.0 SPECIFIC REQUIREMENTS REGARDING ERECTION / TESTING & COMMISSIONING**

Field quality plan for all machines shall be prepared by the bidder during detailed engineering stage as per agreed schedule and the same shall be approved by BHEL to facilitate handling of equipment, erection & commissioning.

**8.0 BID EVALUATION CRITERIA**

The bid shall be evaluated based on the price quoted for main machine, commissioning spares, tools and tackles, manufacturer's standard accessories and special accessories as per specification and any technical loading due to non adherence to the technical specification. However, the price for recommended spares and other special / optional accessories which are not included in bidder's scope of work shall not be considered for evaluation purpose.

**9.0 CONDITION OF REJECTION**

Bid may be rejected if the data which have asked in clause No. 5.0 above is not properly filled-up and submitted along with the bid with company seal.

**10.0 INSPECTION, TESTING AND CODES**

- 10.1 The machine offered shall conform to the latest relevant Indian / international Codes / Standards, their electrical drives shall conform to the latest Indian Electricity Rules and shall comply for the currently applicable statutory regulations and safety codes for the locality where the equipment shall be installed.
- 10.2 Each machine before despatch shall be shop assembled & tested for its performance in the presence of purchaser's representative. Vendor to ensure the proper quality checks during manufacturing & assembly of machine, including identification, co-relation & verification of material test certificates for critical components like gears, shafts, spindles, sleeves etc. and radiographic tests for welds and ultrasonic tests on forging/castings to ensure defects free components and furnish test procedure, reports & test certificates on shop tests.
- 11.0 Drawing / document distribution schedule is attached in the NIT specification. Bidder shall follow the same during detail engineering stage.



TITLE

**SPECIFIC TECHNICAL  
REQUIREMENTS  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS – 434 - 571 – A001A

VOLUME II B

SECTION C

REV 0

SHEET 9 OF 11

**ANNEXURE - II**

**Drawings / documents distribution schedule and MDL**

S.N.	DESCRIPTION	CUSTOMER / CONSULTANT	BHEL / Customer SITE	PEM (ENGINEERING)
1)	Drawings / documents during approval stage	10	Nil	6 – hard copy and 1 – soft copy (CD)
2)	Finally approved drawings / documents	10	9	6 – hard copy and 6 - softcopy (CD)
3)	As built drawings / documents	10	9	6 – hard copy and 6 - softcopy (CD)
4)	Approved erection / installation manual	10	9	6 – hard copy and 6 - softcopy (CD)
5)	Approved O & M manuals	10	9	6 – hard copy and 6 - softcopy (CD)

**Note:** The above requirement is minimum. However, exact quantities of drawings / documents requirement shall be informed to the successful bidder during detailed engineering stage for which no commercial implication shall be entertained by BHEL.

All drawings & documents shall be prepared in Autocad and submitted for review / approval in soft copies also. Catalogues shall be scanned for soft copy.

**Note:-** Manually prepared drawings are not acceptable.

Soft copy in CD Rom and Reproducible Tracings of all drawings / documents shall be submitted along with Final / As-Built submission.



TITLE

**SPECIFIC TECHNICAL  
REQUIREMENTS  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS – 434 - 571 – A001A

VOLUME II B

SECTION C

REV 0

SHEET 10 OF 11

**ANNEXURE III**

**Master Drawing List**

The successful bidder shall submit the following drawings / documents during detail engineering for approval /information:

**BASIC ENGINEERING DOC.**

Sl. No.	BHEL DRG.NO	DRAWING TITLE	REMARKS	SUBMISSION SCHEDULE - WEEK NUMBER FROM DATE OF LOI
1	PE-V0-434-571-A002	GA, Foundation Detail (as required) and Data sheet of Machine / Equipment with detailed BOM	APPROVAL	2
3	PE-V0-434-571-A001	Inspection Check List / Manufacturing Quality Plan of machine/equipment	APPROVAL	2

**List of dwg. /doc after approval of basic dwg. / doc:**

Sl. No.	BHEL DRG.NO	DRAWING TITLE	REMARKS	SUBMISSION SCHEDULE - WEEK NUMBER FROM DATE OF LOI
1	PE-V0-434-571-A003	O & M Manual for FQA LAB	INFORMATION	2 weeks after approval of basic dwg/doc.
2	PE-V0-434-571-A004	Erection Procedure for FQA LAB	INFORMATION	2 weeks after approval of basic dwg/doc.

- The above drawing list is tentative and shall be finalized with the successful bidder after placement of order. Every repeat submission within one (1) week. Response time by BHEL within three (3) weeks after receiving of drawing.
- Drawings shall be prepared in Auto-Cad latest edition. Required no. of hard and soft copies (editable) of the drawings shall be furnished as per requirement specified elsewhere in the specification.
- All the drawings and documents including general arrangement drawing, data sheet, calculation etc. to be furnished to the customer during detailed engineering stage shall include / indicate the following details for clarity w.r.t. Inspection, construction, erection and maintenance etc.:
  - All drawings and documents shall indicate the list of all reference drawings including general arrangement.
  - All drawings shall include / show plan, elevation, side view, cross - section, skin section, blow - up view; all major self-manufactured and bought out items shall be labeled and included in BOQ / BOM in tabular form.



TITLE

**SPECIFIC TECHNICAL  
REQUIREMENTS  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS – 434 - 571 – A001A

VOLUME II B

SECTION C

REV 0

SHEET 11 OF 11

- c) Painting schedule shall also be made as a part of general arrangement drawing of each equipment / items indicating at least 3 trade names.
- d) All the drawings required to be furnished to customer during detailed engineering stage shall include technical parameters, details of paints and lubrication, hardness and BOQ / BOM in tabular form indicating all major components including bought out items and their quantity, material of construction indicating its applicable code / standard, weight, make etc.

“Bidder to note that BHEL reserve the right for drg/doc submission through web based Document Management System. Bidder would be provided access to the DMS for drg/doc approval and adequate training for the same. Detailed methodology would be finalized during the kick-off meeting. Bidder to ensure following at their end.

- Internet explorer version – Minimum Internet Explorer 7
- Internet speed – 2 mbps (Minimum preferred)
- Pop ups from our external DMS IP (124.124.36.198) should not be blocked
- Vendor's Internal proxy setting should not block DMS application's link (<http://124.124.36.198/wrenchwebaccess/login.aspx>)”



## **SUB – SECTION – A-12**

### **SURFACE PREPARATION & PAINTING**

EPC PACKAGE FOR  
PATRATU SUPER THERMAL POWER STATION EXPANSION  
PHASE –I ( 3X 800MW)

TECHNICAL SPECIFICATION  
SECTION-VI  
BID DOC. NO.: CS:9585-001-2

17/PS-PEM-MAX		<div>एनटीपीसी NTPC</div>	
CLAUSE NO.	TECHNICAL REQUIREMENTS		
1.00.00	SPECIFICATION OF SURFACE PREPARATION & PAINTING		
1.01.00	Surface preparation methods and paint/primer materials shall be of the type specified herein. If the contractor desires to use any paint/primer materials other than that specified, specific approval shall be obtained by the contractor in writing from the employer for using the substitute material.		
1.02.00	All paints shall be delivered to job site in manufacturers sealed containers. Each container shall be labelled by the manufacturer with the manufacturer's name, type of paint, batch number and colour.		
1.03.00	Unless specified otherwise, paint shall not be applied to surfaces of insulation, surfaces of stainless steel/nickel/ copper/brass/ monel/ aluminum/ hastelloy/lead/ galvanized steel items, valve stem, pump rods, shafts, gauges, bearing and contact surfaces, lined or clad surfaces.		
1.04.00	All pipelines shall be Colour coded for identification as per the NTPC Colour-coding scheme, which will be furnished to the contractor during detailed engineering.		
1.05.00	SURFACE PREPARATION		
1.05.01	All surfaces to be painted shall be thoroughly cleaned of oil. Grease and other foreign material. Surfaces shall be free of moisture and contamination from chemicals and solvents.		
1.05.02	The following surface preparation schemes are envisaged here. Depending upon requirement any one or a combination of these schemes may be used for surface preparation before application of primer. <div>SP1            Solvent cleaning</div> <div>SP2            Application of rust converter (Ruskil or equivalent grade)</div> <div>SP3            Power tool cleaning</div> <div>SP4            Shot blasting (shot blasting shall be used as surface preparation method for hot worked pipes prior to application of primer)</div> <div>SP4*          Shot blast cleaning/ abrasive blast cleaning to SA21/2 (near white metal) 35-50 microns</div> <div>SP5            Shot blasting/ abrasive blasting.</div> <div>SP6            Emery sheet cleaning/Manual wire brush cleaning.</div>		
1.06.00	APPLICATION OF PRIMER/PAINT		
1.06.01	The paint/primer manufacturer's instructions covering thinning, mixing, method of application, handling and drying time shall be strictly followed and considered as part of this specification. The Dry film thickness (DFT) of primer/paint shall be as specified herein.		
1.06.02	Surfaces prepared as per the surface preparation scheme indicated herein shall be applied with primer paint within 6 hours after preparation of surfaces.		
1.06.03	Where primer coat has been applied in the shop, the primer coat shall be carefully examined, cleaned and spot primed with one coat of the primer before applying intermediate and finish coats. When the primer coat has not been applied in the shop, primer coat shall be applied by brushing, rolling or spraying on the same day		
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)		TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO. CS-9585-001-2	SUB-SECTION - A-12 SURFACE PREPARATION & PAINTING
Page 1 of 9			



1/PS-PEM-MAX				<div>एनटीपीसी NTPC</div>	
CLAUSE NO.		TECHNICAL REQUIREMENTS			
1.06.04		as the surface is prepared. Primer coat shall be applied prior to intermediate and finish coats.			
1.06.05		Steel surfaces that will be concealed by building walls shall be primed and finish painted before the floor is erected.Tops of structural steel members that will be covered by grating shall be primed and finish painted before the grating is permanently secured.			
1.06.05		Following are the Primer/painting schemes envisaged herein:			
		PS3 - Zinc Chrome Primer (Alkyd base) by brush/Spray to IS104.			
		PS3* - Zinc Chrome primer (Alkyd base) by dip coat.			
		PS4 - Synthetic Enamel (long oil alkyd) to IS2932.			
		PS5 - Red Oxide Zinc Phosphate primer (Alkyd base) to IS 12744			
		PS9 - Aluminium paint to IS 2339.			
		PS9* - Heat resistant Aluminium paint to IS-13183 Gr.-1			
		PS13 - Rust preventive fluid by spray, dip or brush.			
		PS14 - weldable primer-Deoxaluminate or equivalent.			
		PS16 - High Build Epoxy CDC mastic `15' .			
		PS17 - Aliphatic Acrylic Polyurethane CDE134 ,%V=40.0(min.)			
		PS18 - Epoxy based TiO2 pigmented coat			
		PS19 - Epoxy Zinc rich primer (92% zinc in dry film (min.), %VS=40.0(min.)			
		PS-20 - Epoxy based finish paint			
1.06.06		All weld edge preparation for site welding shall be applied with one coat of weldable primer.			
1.06.07		For internal protection of pipes/tubes, VCI pellets shall be used at both ends after sponge testing and ends capped. VCI pellets shall not be used for SS components and composite assemblies.			
1.06.08		SG membrane walls and other Flue gas swept pressure part surfaces shall be applied with appropriate primer for protection of surfaces during transit, storage and erection.			
1.06.09		a) All un-insulated equipments, pipes, valves etc covered in sub-section A-08 (Steam Turbine & Auxiliary system) shall be painted with paint not inferior to Epoxy resin based paints with minimum DFT of 150 micron. The paint shall be applied in three stages i.e. primer, intermediate and finish coats in following manner:			
		<div><div>▪</div>Primer coat – Epoxy based zinc phosphate</div> <div><div>▪</div>Intermediate - Epoxy based TiO2 pigmented coat</div> <div><div>▪</div>Finish coat - Epoxy based finish coat</div>			
		b) Equipment, pipes etc. with high temperature shall be painted with heat resistant aluminum paint (to be selected based on the service condition of component as per IS-13183). Two coats of paint shall be applied with total DFT 40 micron.			
		c) Surface preparation before painting shall be carried out according to requirement indicated in this sub-section and international standard			
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)		TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO. CS-9585-001-2		SUB-SECTION - A-12 SURFACE PREPARATION & PAINTING	
				Page 2 of 9	

1/PS-PEM-MAX			
CLAUSE NO.	TECHNICAL REQUIREMENTS	<div>एनटीपीसी NTPC</div>	
1.06.10	<p>A) Specification for the application of Epoxy coating for internal protection of DM tank &amp; other vessels/tanks (as applicable) shall be as follows:</p> <p>Primer : One coat of unmodified epoxy resin along with polyimide hardener.</p> <p>Paint : Two (2) coats unmodified epoxy resin along with Aromatic adduct hardener.</p> <p>Total thickness of primer and paint should not be less than 400 microns.</p> <p>B) Specification for application of chlorinated Rubber paint for external protection vessel, tanks, piping, valves &amp; other equipments shall be as follows:</p> <p>i) For Indoor vessel, tanks, piping, valves &amp; other equipments:</p> <p>(a) Surface preparation shall be done either manually or by any other approved method.</p> <p>(b) Primer coat shall consist of one coat of chlorinated rubber based zinc phosphate primer having minimum DFT of 50 microns.</p> <p>(c) Intermediate coat (or under coat) shall consist of one coat of chlorinated rubber based paint pigmented with Titanium dioxide with minimum DFT of 50 microns.</p> <p>(d) Top coat shall consist of one coat of chlorinated rubber paint of approved shade and colour with glossy finish and DFT of 50 microns.</p> <p>Total DFT of paint system shall not be less than 150 microns.</p> <p>ii) For Outdoor vessel, tanks, piping, valves &amp; other equipments:</p> <p>(a) Surface preparation shall be blast cleared using non-siliceous abrasive after usual wire brushing, which shall conform to Sa 2-1/2 Swiss Standard.</p> <p>(b) Primer coat shall consist of one coat of epoxy resin based zinc phosphate primer having minimum DFT of 100 microns.</p> <p>(c) Intermediate coat (or under coat) shall consist of epoxy resin based paint pigmented with Titanium dioxide with minimum DFT of 100 microns.</p> <p>(d) Top coat shall consist of one coat of epoxy paint suitable pigmented of approved shade and colour with glossy finish and DFT of 75 microns. Additionally finishing coat of polyurethane of minimum DFT of 25 microns shall be provided.</p> <p>The paint may be applied in one coat, in case high built paint is used, otherwise two coats shall be applied.</p> <p>Total DFT shall not be less than 300 microns.</p>		
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)		TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO. CS-9585-001-2	SUB-SECTION - A-12 SURFACE PREPARATION & PAINTING
		Page 3 of 9	



## 1.06.11 Primer/Painting Schedule

Sl. No	Description	Surface Preparation	Primer Coat			Intermediate Coat			Finish Coats			Total Min. Painting DFT (Microns)	Colour Shade
			Type of Primer	No. of Coats	Min. DFT / coat (Microns)	Type of coating	No. Coats	Min. DFT/ Coat (Microns)	Type of coating	No. Coats	Min. DFT/ Coat (Microns)		
A) Power Cycle Piping													
1.	All insulated Piping, fittings/ components, Pipe clamps, Vessels/Tanks, Equipments etc.	SP3/SP4	PS9*	1	20	-	-	-	PS9*	1	20	40	As per NTPC Colour shade/ coding scheme
	All un-insulated Piping, fittings/ components, Pipe clamps, Vessels/Tanks, Equipments etc.	SP3/SP4	PS 5	2	25	-	-	-	PS 4	3	35	155	
2.			SP3/SP4	PS 9*	1	20	-	-	-	PS9*	1	20	
		SP3/SP4	PS9*	1	20	-	-	-	PS9*	1	20	40	
3	Constant Load Hanger (CLH) and Variable Load Hanger (VLH)	SP4*	PS19	1	40	-	-	-	PS17	1	30	70	

PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)	BID DOC. NO. CS-9585-001-2	TECHNICAL SPECIFICATIONS SECTION VI, PART-B	TECHNICAL REQUIREMENTS	SUB-SECTION -A-12 Surface Preparation & Painting	Page 4 of 9



4	Piping hangers/ supports (other than (3) above. (un-insulated)	SP4 (SP6 - for cleaning of weld joints after erection,)	PS 5	1	40	PS 4	1	40	PS 17	1	40	120	
	Valves												
5.	Cast/Forge d	Design temperature < or equal to 60 degC	SP1/SP2/S P3	PS4/P S9	1	40	Polya mide Epoxy	1	100	PS17	1	40	180
		Design temperature above 60 degC and up to 200 degC	SP1/SP2/S P3	PS 9*	1	20	-	-	-	PS9*	1	20	40
		Design temperature above 200 degC	SP1/SP2/S P3	PS9*	1	20	-	-	-	PS9*	1	20	40
6.	All auxiliary Structural Steel components for pipe supports	Outside TG building and in SG envelope	SP4*	Inorga nic Ethyl Zinc Silicat e	1	75	PS18	1	75	a))Epoxy coat b)Final coat of paint PS17	2 1	35 30	250



		Within building	TG	SP4*	-do-	1	35	PS18	1	35	a) Epoxy coat b) Final coat of paint PS17	2 1	25 30	150
7.	Weld Edges			SP6 (Hand cleaning by wire brushing)	PS13 (Weldable primer)	1	25	-	-	-	-	-	-	25
<p>1. \$ The first 2 finished coats (total min. DFT of 70 microns) shall be done at shop and the 3rd finish coat (min. DFT 35 Microns) shall be applied at site.</p> <p>2. For valves below 65NB and temperature upto and including 540 DegC, Parkerizing/zinc phosphate corrosion resistant coating as per ASTM F1137 is also acceptable in lieu of Aluminum paint.</p> <p>3. For corrosion protection of threaded hanger rods and variable spring cages, electro galvanizing in full compliance to minimum Corrosion category C3 as per EN ISO12944 is also acceptable.</p> <p>4. For spring cages, 2 coats of 30 µm (min) zinc-rich epoxy resin primer with zinc content &gt; 80 weight% in dry film followed by 2 coats of 30 µm (min) top coat of Acrylic resin Co-polymerisate with a total combined minimum DFT of 120µm is also acceptable in lieu of above specified paint scheme.</p> <p>5. For corrosion protection for all inner parts of the hangers shall be at least in full compliance to Corrosion category C3 as per EN ISO12944.</p>														
<b>B) Steam Generator &amp; Auxiliaries:</b>														
1	All surfaces with temperature 95°C or less and which are insulated	SP3/SP4	PS 5	2	30	-	-	-	-	-	PS 4	2 \$	20 \$	100 \$
2	All surfaces with temperature above 95°C and which are insulated	SP3/SP4	PS9*	1	20	-	-	-	-	-	PS9*	1	20	40

EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)	BID DOC. NO. CS-9585-001-2	TECHNICAL SPECIFICATIONS SECTION VI, PART-B	TECHNICAL REQUIREMENTS	SUB-SECTION -A-12 Surface Preparation & Painting	Page 6 of 9
--	----------------------------	--	---------------------------	---	-------------



Note: 1) SG membrane walls and other Flue gas swept pressure part surfaces shall be applied with appropriate primer for protection of surfaces during transit, storage and erection.  
2) For valves below 65NB and temperature upto & including 545 Deg.C, Parkerizing/zinc phosphate corrosion resistant coating as per ASTM F1137 is also acceptable in lieu of Aluminum paint.

C) LOW PRESSURE PIPING													
1	All Pipes, components, fittings / valves, Equipments etc.	SP3/SP5	PS3/PS5	2	25	PS 4	1	30	PS 4	2	35	150	As per NTPC Colour shade/ coding scheme
2	Stainless steel surface, Galvanized steel surface and gun metal surface.	No Painting											
3	On the internal surface for pipes 1000 Nb and above	A coat of primer followed by hot coal-tar enamel or coal tar epoxy painting (cold) shall be applied.											



D) Fire Detection & Protection System, Compressed air system, Hydrogen generation plant and Air-conditioning & Ventilation System												
For Fire Detection & Protection System, Surface preparation and painting of Fire Water Storage Tanks, all Steel Surfaces (external) exposed to atmosphere (outdoor & indoor installation), Deluge Valves, Alarm Valves, Foam monitors, Water monitors, Foam Proportioning equipments, Foam makers, etc. should be as per the Part-B, Sub Section-A-18, Fire Detection & Protection System												
For Air Conditioning System, Surface preparation and painting of all the steel surfaces (external) exposed to atmosphere (outdoor & indoor installation), centrifugal fans – Casing etc. should be as per the Part-B, Sub Section-A-17, Air Conditioning System.												
For Ventilation System, Surface preparation and painting of all the steel surfaces (external) exposed to atmosphere (outdoor & indoor installation), centrifugal fans – Casing etc. should be as per the Part-B, Sub Section-A-30, Ventilation System.												
For compressed air system, Surface preparation and painting of all the steel surfaces should be as per the Part-B, Sub Section-A-16 compressed air system.												
For hydrogen generation plant, Surface preparation and painting should be as per the Part-B, Sub-Section-A-19 hydrogen generation plant.												
E) ESP												
1	All surfaces with surface temperature 95°C or less (with insulation)	SP3/SP4	PS3/PS5	1	25	-	-	-	PS 4	1	30	55
2	All surfaces with surface temperature above 95°C (with or without insulation)	SP3/SP4	PS5	2	30	-	-	-	-	-	-	60

**General Notes (Applicable for all above points A to E)**

- i) Painting specification for all surfaces with surface temperature 95°C or less (un-insulated) that are not covered above shall be same as that given in Civil Sub-section, Part-B, Section-VI for corrosion protection of steel structures.

EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)	BID DOC. NO. CS-9585-001-2	TECHNICAL SPECIFICATIONS SECTION VI, PART-B	TECHNICAL REQUIREMENTS	SUB-SECTION -A-12 Surface Preparation & Painting	Page 8 of 9
--	----------------------------	--	---------------------------	---	-------------



- ii) Painting specification for inside surfaces (such as inner surfaces of ducts/ tanks/ mills/ dampers/ ESP etc.) that are not covered specifically in above clauses, shall be provided with 2 coats of suitable primer i.e. PS5/ PS9 (Total DFT 60/40 micron) based on the temperature.

<b>F) FGD System</b>
<div>(i) Surface preparation shall be blast cleaned conforming to Sa 2-1/2 Swiss Standard. (ii) Primer coat shall consist of epoxy resin based zinc phosphate primer having minimum DFT of 100 microns. (iii) Intermediate coat (or under coat) shall consist of epoxy resin based paint pigmented with Titanium dioxide with minimum DFT of 100 microns. (iv) Top coat shall consist of one coat of epoxy paint suitable pigmented of approved shade and colour with glossy finish and DFT of 75 microns. Additionally finishing coat of polyurethane of minimum DFT of 25 microns shall be provided.</div>


EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)	BID DOC. NO. CS-9585-001-2	TECHNICAL SPECIFICATIONS SECTION VI, PART-B	TECHNICAL REQUIREMENTS	SUB-SECTION -A-12 Surface Preparation & Painting	Page 9 of 9
--	----------------------------	--	---------------------------	---	-------------



**ANNEXURE-V**

MFGR.'s LOGO	MANUFACTURER'S NAME AND ADDRESS	<b>MANUFACTURING QUALITY PLAN</b>		PROJECT :
		ITEM :	QP NO.: REV.NO.: DATE: PAGE: .... OF....	PACKAGE : CONTRACT NO. : MAIN-SUPPLIER:
		SUB-SYSTEM:		

SL. NO	COMPONENT & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK		REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD		AGENCY			REMARKS
					M	C / N					D*	M	C	
1.	2.	3.	4.	5.	6.		7.	8.	9.	D*	**	10.		11.

		<b>LEGEND:</b> * RECORDS, IDENTIFIED WITH "TICK" (✓) SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION. <b>** M:</b> MANUFACTURER/SUB-SUPPLIER C: MAIN SUPPLIER, N: NTPC <b>P:</b> PERFORM W: WITNESS AND V: VERIFICATION. AS APPROPRIATE, <b>CHP:</b> NTPC SHALL IDENTIFY IN COLUMN "N" AS 'W'	  <b>FOR NTPC USE</b>	DOC. NO.:		REV..... CAT.....	
MANUFACTURER/ SUB-SUPPLIER	MAIN-SUPPLIER						
SIGNATURE				REVIEWED BY	APPROVED BY	APPROVAL SEAL	

FORMAT NO.: QS-01-QAI-P-09/F1-R1

1/1


ENGG. DIV./QA&amp;I

EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800MW)	TECHNICAL SPECIFICATION SECTION – VI, PART-C BID DOC. NO.: CS-9585-001-2	GENERAL TECHNICAL REQUIREMENT	PAGE 78 OF 111
---	--	-------------------------------	----------------

**ANNEXURE-V**

SUPPLIER'S LOGO	SUPPLIER'S NAME AND ADDRESS	<b>FIELD QUALITY PLAN</b>		PROJECT :
		ITEM :	QP NO.:	PACKAGE :
		SUB-SYSTEM:	REV. NO.:	CONTRACT NO. :
			DATE:	MAIN-SUPPLIER:
			PAGE: .... OF....	

SL. NO	ACTIVITY AND OPERATION	CHARACTERISTICS / INSTRUMENTS	CLASS OF CHECK #	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD		REMARKS
1.	2.	3.	4.	5.	6.	7.	8.	9.	D*	10.

		<b>LEGEND:</b> * RECORDS, IDENTIFIED WITH "TICK" (✓) SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION. <b>LEGEND TO BE USED:</b> CLASS # : A = CRITICAL, B=MAJOR, C=MINOR; 'A' SHALL BE WITNESSED BY NTPC FQA, 'B' SHALL BE WITNESSED BY NTPC ERECTION / CONSTRUCTION DEPTT. AND 'C' SHALL BE WITNESSED BY MAIN SUPPLIER (A & B CHECK SHALL BE NTPC CHP STAGE)		DOC. NO.: REV.....		
MANUFACTURER/ SUB-SUPPLIER	MAIN-SUPPLIER					
SIGNATURE				FOR NTPC USE	REVIEWED BY	APPROVED BY

FORMAT NO.: QS-01-QAI-P-09/F2-R1

1/1

ENGG. DIV./QA&amp;I

EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800MW)	TECHNICAL SPECIFICATION SECTION – VI, PART-C BID DOC.NO.: CS-9585-001-2	GENERAL TECHNICAL REQUIREMENT	PAGE 79 OF111
---	---	-------------------------------	---------------



TITLE

TECHNICAL SPECIFICATION  
FOR  
FQA LAB MECHANICAL

SPECIFICATION NO. PE – TS - 434 - 571 – A001A

VOLUME II

SECTION C

REV 0

SHEET OF

VOL - II B  
ELECTRICAL

513079/2021/PS-PEM-MAX



TITLE :  
ELECTRICAL EQUIPMENT SPECIFICATION  
FOR  
FQA LAB MECHANICAL  
3X800 MW PVUNL PATRATU TPP PHASE-1

SPECIFICATION NO.

VOLUME NO. : II-B

SECTION :

REV NO. 00 : DATE : 03.08.2019

SHEET : 1 OF 3

TECHNICAL SPECIFICATION

FOR

FQA LAB MECHANICAL

(ELECTRICAL PORTION)



**TITLE :**  
**ELECTRICAL EQUIPMENT SPECIFICATION**  
**FOR**  
**FQA LAB MECHANICAL**  
**3X800 MW PVUNL PATRATU TPP PHASE-1**

SPECIFICATION NO.
VOLUME NO. : <b>II-B</b>
SECTION :
REV NO. <b>00</b> : DATE : 03.08.2019
SHEET : 2 OF 3

**1.0 EQUIPMENT & SERVICES TO BE PROVIDED BY BIDDER:**

- a) Services and equipment as per “Electrical Scope between BHEL and Vendor”.
- b) Any item/work either supply of equipment or erection material which have not been specifically mentioned but are necessary to complete the work for trouble free and efficient operation of the plant shall be deemed to be included within the scope of this specification. The same shall be provided by the bidder without any extra charge.
- c) Supply of mandatory spares as specified in the specifications of mechanical equipments.
- d) Electrical load requirement for FQA LAB MECHANICAL.
- e) All equipment shall be suitable for the power supply fault levels and other climatic conditions mentioned in the enclosed project information.
- f) Bidder to furnish list of makes for each equipment at contract stage, which shall be subject to customer/BHEL approval without any commercial and delivery implications to BHEL.
- g) Various drawings, data sheets as per required format, Quality plans, calculations, test reports, test certificates, operation and maintenance manuals etc shall be furnished as specified at contract stage. All documents shall be subject to customer/BHEL approval without any commercial implication to BHEL.
- h) Motor shall meet minimum requirement of motor specification.
- i) Vendor to clearly indicate equipment locations and local routing lengths in their cable listing furnished to BHEL.
- j) Cable BOQ worked out based on routing of cable listing provided by the vendor for “ both end equipment in vendor’s scope”shall be binding to the vendor with +10 % margin to take care of slight variation in routing length & wastages.

**2.0 EQUIPMENT & SERVICES TO BE PROVIDED BY PURCHASER FOR ELECTRICAL & TERMINAL POINTS:**

Refer “Electrical Scope between BHEL and Vendor”.

**3.0 DOCUMENTS TO BE SUBMITTED ALONG WITH BID**

- 3.1 The electrical specification without any deviation from the technical/quality assurance requirements stipulated shall be deemed to be complied by the bidder in case bidder

513079/2021/PS-PEM-MAX



**TITLE :**  
**ELECTRICAL EQUIPMENT SPECIFICATION**  
**FOR**  
**FQA LAB MECHANICAL**  
**3X800 MW PVUNL PATRATU TPP PHASE-1**

SPECIFICATION NO.

VOLUME NO. : **II-B**

SECTION :

REV NO. **00** : DATE : 03.08.2019

SHEET : 3 OF 3

furnishes the overall compliance of package technical specification in the form of compliance certificate/No deviation certificate.

- 3.2 No technical submittal such as copies of data sheets, drawings, write-up, quality plans, type test certificates, technical literature, etc, is required during tender stage. Any such submission even if made, shall not be considered as part of offer.

**4.0 List of enclosures :**

- a) Electrical scope between BHEL & vendor
- b) Customer (NTPC) specification for Motors
- c) Customer ( NTPC) specification for cable lugs and glands
- d) Quality plan for motors & NTPC quality assurance
- e) Datasheet A & C (Annexure- I)
- f) Sub vendor List for Motors & other Electrical items ( Annexure-II)
- g) Electrical Load data format (Annexure –III)
- h) BHEL cable listing format (Annexure –IV)

STANDARD ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR (FOR EPC PROJECTS) REV-0, DATE: 03.08.2019

PACKAGE : FQA LAB MECHANICAL

SCOPE OF VENDOR: SUPPLY

PROJECT : 3X800 MW Patratu STPP

S.NO	DETAILS	SCOPE SUPPLY	SCOPE E&C	REMARKS
1	415V MCC	BHEL	BHEL	240 V AC (supply feeder)/415 V AC (3 PHASE 4 WIRE) supply shall be provided by BHEL based on load data provided by vendor at contract stage for all equipment supplied by vendor as part of contract. Any other voltage level (AC/DC) required will be derived by the vendor.
2	Power cables	BHEL	BHEL	Cable size shall be derived by BHEL based on Electrical load data & shall be informed to vendor at contract stage. Vendor shall provide lugs & glands accordingly.
3	Any other/special type of cable like control, screened control, compensating, co-axial, prefab, MICC, fibre Optic cables etc.	Vendor	BHEL	
4	Cabling material (Cable trays, accessories ,cable tray supporting system, conduits etc.)	BHEL	BHEL	
5	Cable glands ,lugs, and bimetallic strip for equipment supplied by Vendor	Vendor	BHEL	1. Double compression Ni-Cr plated brass cable glands 2. Solder less crimping type heavy duty tinned copper lugs for power and control cables.
6	Motors alongwith fixing accessories	Vendor	-	Makes shall be subject to customer/ BHEL approval at contract stage.
7	Mandatory spares	Vendor	-	Vendor to quote as per specification.
8	Recommended O & M spares	Vendor	-	As per specification

NOTES:

1. Make of all electrical equipment/ items supplied shall be reputed make & shall be subject to approval of BHEL/customer after award of contract without any commercial implication.
2. All QPs shall be subject to approval of BHEL/customer after award of contract without any commercial implication.



# **SUB-SECTION – B-07**

## **MOTORS**

EPC PACKAGE FOR  
PATRATU SUPER THERMAL POWER STATION EXPANSION  
PHASE –I ( 3X 800MW)

TECHNICAL SPECIFICATION  
SECTION – VI, PART-B  
BID DOC NO. : CS-9585-001-2



PS-PEM-MAX					
CLAUSE NO.	TECHNICAL REQUIREMENTS				
	<p style="text-align: center;"><b>MOTORS</b></p>				
<b>1.00.00</b>	<b>GENERAL REQUIREMENTS</b>				
1.01.00	For the purpose of design of equipment/systems, an ambient temperature of 50 deg. Centigrade and relative humidity of 95% (at 40 deg C) shall be considered. The equipment shall operate in a highly polluted environment.				
1.02.00	All equipment shall be suitable for rated frequency of 50 Hz with a variation of +3% & -5%, and 10% combined variation of voltage and frequency unless specifically brought out in the specification.				
1.03.00	Contractor shall provide fully compatible electrical system, equipment, accessories and services.				
1.04.00	All the equipment, material and systems shall, in general, conform to the latest edition of relevant National and international Codes & Standards, especially the Indian Statutory Regulations.				
1.05.00	Paint shade shall be as per RAL 5012 (Blue) for indoor and outdoor equipment.				
1.06.00	The responsibility of coordination with electrical agencies and obtaining all necessary clearances for contractors equipment and systems shall be under the contractor scope.				
1.07.00	Degree of Protection  Degree of protection for various enclosures as per IEC60034-05 shall be as follows:-  i) Indoor motors - IP 54 ii) Outdoor motors - IP 55 iii) Cable box-indoor area - IP 54 iv) Cable box-Outdoor area - IP 55				
<b>2.00.00</b>	<b>CODES AND STANDARDS</b>  1) Three phase induction motors : IS/IEC:60034 2) Single phase AC motors : IS/IEC:60034 3) Crane duty motors : IS:3177, IS/IEC:60034 4) DC motors/generators : IS/IEC:60034 5) Energy Efficient motors : IS 12615, IEC: 60034-30				
<table><tr><td>EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW</td><td>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO. : CS-9585-001-2</td><td>SUB-SECTION-B-07 MOTORS</td><td>PAGE 1 OF 10</td></tr></table>		EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO. : CS-9585-001-2	SUB-SECTION-B-07 MOTORS	PAGE 1 OF 10
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO. : CS-9585-001-2	SUB-SECTION-B-07 MOTORS	PAGE 1 OF 10		



PS-PEM-MAX

CLAUSE NO.	TECHNICAL REQUIREMENTS		
	41 deg.C over inlet cooling water maximum temperature of 39 deg.C for thermal class 90 (Y) wet wound Boiler circulation pump motor.		
6.00.00	OPERATIONAL REQUIREMENTS		
6.01.00	Starting Time		
6.01.01	For motors with starting time upto 20 secs. at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be at least 2.5 secs. more than starting time.		
6.01.02	For motors with starting time more than 20 secs. and upto 45 secs. at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be at least 5 secs. more than starting time.		
6.01.03	For motors with starting time more than 45 secs. at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be more than starting time by at least 10% of the starting time.		
6.01.04	Speed switches mounted on the motor shaft shall be provided in cases where above requirements are not met.		
6.02.00	Torque Requirements		
6.02.01	Accelerating torque at any speed with the lowest permissible starting voltage shall be at least 10% motor full load torque.		
6.02.02	Pull out torque at rated voltage shall not be less than 205% of full load torque. It shall be 275% for crane duty motors.		
6.03.00	Starting voltage requirement		
	(a) Up to 85% of rated voltage for ratings below 110 KW		
	(b) Up to 80% of rated voltage for ratings from 110 KW to 200 KW		
	(c) Up to 85% of rated voltage for ratings from 201 KW to 1000 KW		
	(d) Up to 80% of rated voltage for ratings from 1001 KW to 4000 KW		
	(e) Up to 75 % of rated voltage for ratings above 4000KW		
	Except AOP & JOP motors running on D.G emergency supply, starting voltage shall be 80%.		
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)		TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO. : CS-9585-001-2	SUB-SECTION-B-07 MOTORS
			PAGE 3 OF 10

CLAUSE NO.	TECHNICAL REQUIREMENTS
7.00.00	<b>DESIGN AND CONSTRUCTIONAL FEATURES</b>
7.01.00	Suitable single phase space heaters shall be provided on motors rated 30KW and above to maintain windings in dry condition when motor is standstill. Separate terminal box for space heaters & RTDs shall be provided. However for flame proof motors, space heater terminals inside the main terminal box may be acceptable.
7.02.00	<p>All motors shall be either Totally enclosed fan cooled (TEFC) or totally enclosed tube ventilated (TETV) or Closed air circuit air cooled (CACA) type. However, motors rated 3000KW or above can be Closed air circuit water cooled (CACW). The method of movement of primary and secondary coolant shall be self-circulated by fan or pump directly mounted on the rotor of the main motor as per IEC 60034-6. However VFD driven motors can be offered with forced cooling type with machine mounted fan or pump driven by separate electric motor. Motors and EPB located in hazardous areas shall have flame proof enclosures conforming to IS: 2148 as detailed below</p> <p>(a) Fuel oil area : Group – IIB</p> <p>(b) Hydrogen generation : Group - IIC or (Group-I, Div-II as per plant area NEC) or (Class-1, Group-B, Div-II as per NEMA / IEC60034)</p>
7.03.00	<p>Winding and Insulation</p> <p>(a) Type : Non-hygroscopic, oil resistant, flame resistant</p> <p>(b) Starting duty : Two hot starts in succession, with motor initially at normal running temperature.</p> <p>(c) 11kV &amp; 3.3 kV AC motors : Thermal class 155 (F) insulation. The winding insulation process shall be total Vacuum Pressure Impregnated i.e. resin poor method. The lightning Impulse &amp; intertern insulation surge withstand level shall be as per IEC-60034 part-15.</p> <p>However winding insulation for wet wound Boiler circulation pump motor shall be thermal class 90 (Y) or better.</p> <p>(d) 240VAC, 415V AC &amp; 220V DC motors : Thermal Class ( B ) or better</p>
7.04.00	Motors rated above 1000KW shall have insulated bearings to prevent flow of shaft currents.
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO. : CS-9585-001-2
SUB-SECTION-B-07 MOTORS	PAGE 4 OF 10

PS-PEM-MAX

CLAUSE NO.	TECHNICAL REQUIREMENTS		
7.05.00	Motors with heat exchangers shall have dial type thermometer with adjustable alarm contacts to indicate inlet and outlet primary air temperature.		
7.06.00	Noise level for all the motors shall be limited to 85dB (A) except for BFP motor for which the maximum limit shall be 90 dB(A). Vibration shall be limited within the limits prescribed in IS/IEC 60034-14. Motors shall withstand vibrations produced by driven equipment. HT motor bearing housings shall have flat surfaces, in both X and Y directions, suitable for mounting 80mmX80mm vibration pads.		
7.07.00	In HT motors, at least four numbers simplex / two numbers duplex platinum resistance type temperature detectors shall be provided in each phase stator winding. Each bearing of HT motor shall be provided with dial type thermometer with adjustable alarm contact and preferably 2 numbers duplex platinum resistance type temperature detectors.		
7.08.00	Motor body shall have two earthing points on opposite sides.		
7.09.00	11 KV motors shall be offered with Separable Insulated Connector (SIC) as per IEEE 386. The offered SIC terminations shall be provided with protective cover and trifurcating sleeves. SIC termination kit shall be suitable for fault level of 25 KA for 0.17 seconds.		
7.10.00	3.3 KV motors shall be offered with dust tight phase separated double walled (metallic as well as insulated barrier) Terminal box. Suitable termination kit shall be provided for the offered Terminal box. The offered Terminal Box shall be suitable for fault level of 250 MVA for 0.12 sec. Removable gland plates of thickness 3 mm (hot/cold rolled sheet steel) or 4 mm (non-magnetic material for single core cables) shall be provided.		
7.11.00	The spacing between gland plate & center of terminal stud shall be as per Table-I.		
7.12.00	All motors shall be so designed that maximum inrush currents and locked rotor and pullout torque developed by them at extreme voltage and frequency variations do not endanger the motor and driven equipment.		
7.13.00	The motors shall be suitable for bus transfer schemes provided on the 11kV, 3.3 kV /415V systems without any injurious effect on its life.		
7.14.00	For motors rated 2000 KW & above, neutral current transformers of PS class shall be provided on each phase in a separate neutral terminal box.		
7.15.00	The size and number of cables (for HT and LT motors) to be intimated to the successful bidder during detailed engineering and the contractor shall provide terminal box suitable for the same.		
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO. : CS-9585-001-2	SUB-SECTION-B-07 MOTORS	PAGE 5 OF 10

PS-PEM-MAX

CLAUSE NO.	TECHNICAL REQUIREMENTS															
8.00.00	<p>The ratio of locked rotor KVA at rated voltage to rated KW shall not exceed the following (without any further tolerance) except for BFP motor.</p> <table><tr><td>(a) 50 kW to 110 kW</td><td>:</td><td>11.0</td></tr><tr><td>(b) From 110 KW &amp; upto 200 KW</td><td>:</td><td>9.0</td></tr><tr><td>(c) Above 200 KW &amp; upto 1000KW</td><td>:</td><td>10.0</td></tr><tr><td>(d) From 1001KW &amp; upto 4000KW</td><td>:</td><td>9.0</td></tr><tr><td>(e) Above 4000KW</td><td>:</td><td>6 to 6.5</td></tr></table>	(a) 50 kW to 110 kW	:	11.0	(b) From 110 KW & upto 200 KW	:	9.0	(c) Above 200 KW & upto 1000KW	:	10.0	(d) From 1001KW & upto 4000KW	:	9.0	(e) Above 4000KW	:	6 to 6.5
(a) 50 kW to 110 kW	:	11.0														
(b) From 110 KW & upto 200 KW	:	9.0														
(c) Above 200 KW & upto 1000KW	:	10.0														
(d) From 1001KW & upto 4000KW	:	9.0														
(e) Above 4000KW	:	6 to 6.5														
9.00.00	CW motor shall be designed with minimum power factor of 0.8 at design duty point.															
10.00.00	TYPE TEST															
10.01.00	HT MOTORS															
10.01.01	The contractor shall carry out the type tests as listed in this specification on the equipment to be supplied under this contract. The bidder shall indicate the charges for each of these type tests separately in the relevant schedule of Section - VII- (BPS) and the same shall be considered for the evaluation of the bids. The type tests charges shall be paid only for the test(s) actually conducted successfully under this contract and upon certification by the employer's engineer.															
10.01.02	The type tests shall be carried out in presence of the employer's representative, for which minimum 15 days notice shall be given by the contractor. The contractor shall obtain the employer's approval for the type test procedure before conducting the type test. The type test procedure shall clearly specify the test set-up, instruments to be used, procedure, acceptance norms, recording of different parameters, interval of recording, precautions to be taken etc. for the type test(s) to be carried out.															
10.01.03	In case the contractor has conducted such specified type test(s) within last ten years as on the date of bid opening, he may submit during detailed engineering the type test reports to the employer for waiver of conductance of such test(s). These reports should be for the tests conducted on the equipment similar to those proposed to be supplied under this contract and test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client. The employer reserves the right to waive conducting of any or all the specified type test(s) under this contract. In case type tests are waived, the type test charges shall not be payable to the contractor.															
10.01.04	Further the Contractor shall only submit the reports of the type tests as listed in "LIST OF TESTS FOR WHICH REPORTS HAVE TO BE SUBMITTED "and carried out within last ten years from the date of bid opening. These reports should be for															
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO. : CS-9585-001-2	SUB-SECTION-B-07 MOTORS	PAGE 6 OF 10													

PS-PEM-MAX

CLAUSE NO.	TECHNICAL REQUIREMENTS				
10.01.05	<p>the test conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client. However if the contractor is not able to submit report of the type test(s) conducted within last ten years from the date of bid opening, or in the case of type test report(s) are not found to be meeting the specification requirements, the contractor shall conduct all such tests under this contract at no additional cost to the employer either at third party lab or in presence of client/ employer's representative and submit the reports for approval.</p> <p><b>LIST OF TYPE TESTS TO BE CONDUCTED</b></p> <p><b>The following type tests shall be conducted on each type and rating of HT motor</b></p> <ul style="list-style-type: none"><li>(a) No load saturation and loss curves upto approximately 115% of rated voltage</li><li>(b) Measurement of noise at no load.</li><li>(c) Momentary excess torque test (subject to test bed constraint).</li><li>(d) Full load test (subject to test bed constraint)</li><li>(e) Temperature rise test at rated conditions. During heat run test, bearing temp., winding temp., coolant flow and its temp. shall also be measured. In case the temperature rise test is carried at load other than rated load, specific approval for the test method and procedure is required to be obtained. Wherever ETD's are provided, the temperature shall be measured by ETD's also for the record purpose.</li></ul>				
10.01.06	<p><b>LIST OF TESTS FOR WHICH REPORTS HAVE TO BE SUBMITTED</b></p> <p><b>The following type test reports shall be submitted for each type and rating of HT motor</b></p> <ul style="list-style-type: none"><li>(a) Degree of protection test for the enclosure followed by IR, HV and no load run test.</li><li>(b) Terminal box-fault level withstand test for each type of terminal box of HT motors only.</li><li>(c) Lightning Impulse withstand test on the sample coil shall be as per clause no. 4.3 IEC-60034, part-15</li><li>(d) Surge-withstand test on interturn insulation shall be as per clause no. 4.2 of IEC 60034, part-15</li></ul>				
<table><tr><td>EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW</td><td>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO. : CS-9585-001-2</td><td>SUB-SECTION-B-07 MOTORS</td><td>PAGE 7 OF 10</td></tr></table>		EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO. : CS-9585-001-2	SUB-SECTION-B-07 MOTORS	PAGE 7 OF 10
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO. : CS-9585-001-2	SUB-SECTION-B-07 MOTORS	PAGE 7 OF 10		

CLAUSE NO.	TECHNICAL REQUIREMENTS
10.02.00	<b>LT Motors</b>
10.02.01	LT Motors supplied shall be of type tested design. During detailed engineering, the contractor shall submit for employer's approval the reports of all the type tests as listed in this specification and carried out within last <i>ten</i> years from the date of bid opening. These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client.
10.02.02	However if the contractor is not able to submit report of the type test(s) conducted within last ten years from the date of bid opening, or in the case of type test report(s) are not found to be meeting the specification requirements, the contractor shall conduct all such tests under this contract at no additional cost to the employer either at third party lab or in presence of client/ employer's representative and submit the reports for approval.
10.02.03	<p><b>LIST OF TESTS FOR WHICH REPORTS HAVE TO BE SUBMITTED</b></p> <p><b>The following type test reports shall be submitted for each type and rating of LT motor of above 50 KW only</b></p> <ol style="list-style-type: none"> <li>1. Measurement of resistance of windings of stator and wound rotor.</li> <li>2. No load test at rated voltage to determine input current power and speed</li> <li>3. Open circuit voltage ratio of wound rotor motors ( in case of Slip ring motors)</li> <li>4. Full load test to determine efficiency power factor and slip.</li> <li>5. Temperature rise test.</li> <li>6. Momentary excess torque test.</li> <li>7. High voltage test.</li> <li>8. Test for vibration severity of motor.</li> <li>9. Test for noise levels of motor(Shall be limited as per clause no 7.06.00 of this section)</li> <li>10. Test for degree of protection and</li> <li>11. Over speed test.</li> </ol>
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO. : CS-9585-001-2
SUB-SECTION-B-07 MOTORS	PAGE 8 OF 10



PS-PEM-MAX

CLAUSE NO.	TECHNICAL REQUIREMENTS																				
12.	Type test reports for motors located in fuel oil area having flame proof enclosures as per IS 2148 / IEC 60079-1																				
10.03.00	All acceptance and routine tests as per the specification and relevant standards shall be carried out. Charges for these shall be deemed to be included in the equipment price.																				
10.04.00	The type test reports once approved for any projects shall be treated as reference. For subsequent projects of NTPC, an endorsement sheet will be furnished by the manufacturer confirming similarity and "No design Change". Minor changes if any shall be highlighted on the endorsement sheet.																				
<div>TABLE - I</div> <div>DIMENSIONS OF TERMINAL BOXES FOR LV MOTORS</div> <table><tr><th>Motor MCR in KW</th><th>Minimum distance between centre of stud and gland plate in mm</th></tr><tr><td>UP to 3 KW</td><td>As per manufacturer's practice.</td></tr><tr><td>Above 3 KW - upto 7 KW</td><td>85</td></tr><tr><td>Above 7 KW - upto 13 KW</td><td>115</td></tr><tr><td>Above 13 KW - upto 24 KW</td><td>167</td></tr><tr><td>Above 24 KW - upto 37 KW</td><td>196</td></tr><tr><td>Above 37 KW - upto 55 KW</td><td>249</td></tr><tr><td>Above 55 KW - upto 90 KW</td><td>277</td></tr><tr><td>Above 90 KW - upto 125 KW</td><td>331</td></tr><tr><td>Above 125 KW-upto 200 KW</td><td>203</td></tr></table> <p>For HT motors the distance between gland plate and the terminal studs shall not be less than 500 mm.</p> <p><b>PHASE TO PHASE/ PHASE TO EARTH AIR CLEARANCE:</b></p> <p>NOTE: Minimum inter-phase and phase-earth air clearances for LT motors with lugs installed shall be as follows:</p>		Motor MCR in KW	Minimum distance between centre of stud and gland plate in mm	UP to 3 KW	As per manufacturer's practice.	Above 3 KW - upto 7 KW	85	Above 7 KW - upto 13 KW	115	Above 13 KW - upto 24 KW	167	Above 24 KW - upto 37 KW	196	Above 37 KW - upto 55 KW	249	Above 55 KW - upto 90 KW	277	Above 90 KW - upto 125 KW	331	Above 125 KW-upto 200 KW	203
Motor MCR in KW	Minimum distance between centre of stud and gland plate in mm																				
UP to 3 KW	As per manufacturer's practice.																				
Above 3 KW - upto 7 KW	85																				
Above 7 KW - upto 13 KW	115																				
Above 13 KW - upto 24 KW	167																				
Above 24 KW - upto 37 KW	196																				
Above 37 KW - upto 55 KW	249																				
Above 55 KW - upto 90 KW	277																				
Above 90 KW - upto 125 KW	331																				
Above 125 KW-upto 200 KW	203																				
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO. : CS-9585-001-2																				
SUB-SECTION-B-07 MOTORS																					
PAGE 9 OF 10																					

513079/2021/PS-PEM-MAX

CLAUSE NO.	TECHNICAL REQUIREMENTS			
	<b>Motor MCR in KW</b>  UP to 110 KW  Above 110 KW and upto 150 KW  Above 150 KW	<b>Clearance</b>  10mm  12.5mm  19mm		
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)		TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO. : CS-9585-001-2		SUB-SECTION-B-07 MOTORS  PAGE 10 OF 10


**Cable glands**

Cable shall be terminated using double compression type cable glands. Testing requirements of Cable glands shall conform to BS:6121 and gland shall be of robust construction capable of clamping cable and cable armour (for armoured cables) firmly without injury to insulation. Cable glands shall be made of heavy duty brass machine finished and nickel chrome plated. Thickness of plating shall not be less than 10 micron. All washers and hardware shall also be made of brass with nickel chrome plating Rubber components shall be of neoprene or better synthetic material and of tested quality. Cable glands shall be suitable for the sizes of cable supplied/erected.

**Cable lugs/ferrules**

Cable lugs/ferrules for power cables shall be tinned copper solderless crimping type suitable for aluminium compacted conductor cables. Cable lugs and ferrules for control cables shall be tinned copper type. The cable lugs for control cables shall be provided with insulating sleeve and shall suit the type of terminals provided on the equipments. Cable lugs and ferrule shall conform to DIN standards

CUSTOMER :			PROJECT			SPECIFICATION :		
QUALITY PLAN			TITLE			NUMBER :		
BIDDER/ :			QUALITY PLAN			SPECIFICATION		
VENDOR			NUMBER PED-506-00-Q-006-REV-01			TITLE		
SYSTEM			ITEM AC ELECT. MOTORS BELOW 55KW (LV)			SECTION		
CAT.			REFERENCE DOCUMENT			AGENCY		
SHEET 1 OF 2			EXTENT OF CHECK			FORMAT OF RECORD		
CHARACTERISTICS			TYPE/ METHOD OF CHECK			P W V		
CHECK			VOLUME III			REMARKS		
COMPONENT/OPERATION			CAT.			SECTION		
SL. NO.			1			11		
2			3			9		
3			4			8		
4			5			7		
5			6			6		
6			7			5		
7			8			4		
8			9			3		
9			10			2		
10			11			1		
11			12			0		
12			13			0		
13			14			0		
14			15			0		
15			16			0		
16			17			0		
17			18			0		
18			19			0		
19			20			0		
20			21			0		
21			22			0		
22			23			0		
23			24			0		
24			25			0		
25			26			0		
26			27			0		
27			28			0		
28			29			0		
29			30			0		
30			31			0		
31			32			0		
32			33			0		
33			34			0		
34			35			0		
35			36			0		
36			37			0		
37			38			0		
38			39			0		
39			40			0		
40			41			0		
41			42			0		
42			43			0		
43			44			0		
44			45			0		
45			46			0		
46			47			0		
47			48			0		
48			49			0		
49			50			0		
50			51			0		
51			52			0		
52			53			0		
53			54			0		
54			55			0		
55			56			0		
56			57			0		
57			58			0		
58			59			0		
59			60			0		
60			61			0		
61			62			0		
62			63			0		
63			64			0		
64			65			0		
65			66			0		
66			67			0		
67			68			0		
68			69			0		
69			70			0		
70			71			0		
71			72			0		
72			73			0		
73			74			0		
74			75			0		
75			76			0		
76			77			0		
77			78			0		
78			79			0		
79			80			0		
80			81			0		
81			82			0		
82			83			0		
83			84			0		
84			85			0		
85			86			0		
86			87			0		
87			88			0		
88			89			0		
89			90			0		
90			91			0		
91			92			0		
92			93			0		
93			94			0		
94			95			0		
95			96			0		
96			97			0		
97			98			0		
98			99			0		
99			100			0		
100			101			0		
101			102			0		
102			103			0		
103			104			0		
104			105			0		
105			106			0		
106			107			0		
107			108			0		
108			109			0		
109			110			0		
110			111			0		
111			112			0		
112			113			0		
113			114			0		
114			115			0		
115			116			0		
116			117			0		
117			118			0		
118			119			0		
119			120			0		
120			121			0		
121			122			0		
122			123			0		
123			124			0		
124			125			0		
125			126			0		
126			127			0		
127			128			0		
128			129			0		
129			130			0		
130			131			0		
131			132			0		
132			133			0		
133			134			0		
134			135			0		
135			136			0		
136			137			0		
137			138			0		
138			139			0		
139			140			0		
140			141			0		
141			142			0		
142			143			0		
143			144			0		
144			145			0		
145			146			0		
146			147			0		
147			148			0		
148			149			0		
149			150			0		
150			151			0		
151			152			0		
152			153			0		
153			154			0		
154			155			0		
155			156			0		
156			157			0		
157			158			0		
158			159			0		
159			160			0		
160			161			0		
161			162			0		
162			163			0		
163			164			0		
164			165			0		
165			166			0		
166			167			0		
167			168			0		
168			169			0		
169			170			0		
170			171			0		
171			172			0		
172			173			0		
173			174			0		
174			175			0		
175			176			0		
176			177			0		
177			178			0		
178			179			0		
179			180			0		
180			181			0		
181			182			0		
182			183			0		
183			184			0		
184			185			0		
185			186			0		
186			187			0		
187			188			0		
188			189			0		
189			190			0		
190			191			0		
191			192			0		
192			193			0		
193			194			0		
194			195			0		
195			196			0		
196			197			0		
197			198			0		
198			199			0		
199			200			0		
200			201			0		
201			202			0		
202			203			0		
203			204			0		
204			205			0		
205			206			0		
206			207			0		
207			208			0		
208			209			0		
209			210			0		
210			211			0		
211			212			0		
212			213			0		
213			214			0		
214			215			0		
215			216			0		
216			217			0		
217			218			0		
218			219			0		
219			220			0		
220			221			0		
221			222			0		
222			223			0		
223			224			0		
224			225			0		
225			226			0		
226			227			0		
227			228			0		
228			229			0		
229			230			0		
230			231			0		
231			232			0		
232			233			0		
233			234			0		
234			235			0		
235			236			0		
236			237			0		
237			238			0		
238			239			0		
239			240			0		
240			241			0		
241			242			0		
242			243			0		
243			244			0		
244			245			0		
245			246			0		
246			247			0		
247			248			0		
248			249			0		
249			250			0		
250			251			0		
251			252			0		
252			253			0		
253			254			0		
254			255			0		
255			256			0		
256			257			0		
257			258			0		
258			259			0		
259			260			0		
260			261			0		
261			262			0		
262			263			0		
263			264			0		
264			265			0		
265			266			0		
266			267			0		
267			268			0		
268			269			0		
269			270			0		
270			271			0		
271			272			0		
272			273			0		
273			274			0		
274			275			0		
275			276			0		
276			277			0		
277			278			0		
278			279			0		
279			280			0		
280			281			0		
281			282			0		
282			283			0		
283			284			0		
284			285			0		
285			286			0		
286			287			0		
287			288			0		
288			289			0		
289			290			0		
290			291			0		
291			292			0		
292			293			0		
293			294			0		
294			295			0		
295			296			0		
296			297			0		
297			298			0		
298			299			0		
299			300			0		
300			301			0		
301			302			0		
302			303			0		
303			304			0		
304			305			0		
305			306			0		
306			307			0		
307			308			0		
308			309			0		
309			310			0		
310			311			0		
311			312			0		
312			313			0		
313			314			0		
314			315			0		
315			316			0		
316			317			0		
317			318			0		
318			319			0		
319			320			0		
320			321			0		
321			322			0		
322			323			0		
323			324			0		
324			325			0		
325			326			0		
326			327			0		
327			328			0		
328			329			0		
329			330			0		
330			331			0		
331			332			0		
332			333			0		
333			334			0		
334			335			0		
335			336			0		
336			337			0		
337			338			0		
338			339			0		
339			340			0		
340			341			0		
341			342			0		
342			343			0		
343			344			0		
344			345			0		
345			346			0		
346			347			0		
347			348			0		
348			349			0		
349			350			0		

		QUALITY PLAN		CUSTOMER :		PROJECT TITLE		SPECIFICATION : NUMBER :													
COMPONENT/OPERATION		CHARACTERISTICS CHECK		BIDDER/ :		QUALITY PLAN		SPECIFICATION :													
				VENDOR		NUMBER PED-506-00-Q-006, REV-01		TITLE :													
SHEET 2 OF 2		SYSTEM		CAT.		TYPE/ METHOD OF CHECK		EXTENT OF CHECK		REFERENCE DOCUMENT		ACCEPTANCE NORM		FORMAT OF RECORD		SECTION		VOLUME III			
SL. NO.		2		3		4		5		6		7		8		9		10		11	
1		3.NAMEPLATE DETAILS		MA		VISUAL		100%		IS-325 & DATA SHEET		IS-325 & DATA SHEET		INSPN. REPORT		2		1		-	
NOTES:  1 ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR. HOWEVER, BHEL SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON WHERE EVER CUSTOMER IS INVOLVED IN INSPECTION, (1) SHALL MEAN BHEL AND CUSTOMERS BOTH TOGETHER. 2 FOR EXHAUST/VENTILATION FAN MOTORS OF RATING UPTO 1.5KW , ONLY ROUTINE TEST CERTIFICATES SHALL BE FURNISHED FOR SCRUTINY.  <u>Legends for Inspection agency</u>  1. BHEL/CUSTOMER 2. VENDOR (MOTOR MANUFACTURER) 3. SUB-VENDOR (RAW MATERIAL/COMPONENTS SUPPLIER)  P. PERFORM W. WITNESS V. VERIFY																					
BHEL		PARTICULARS		BIDDER/VENDOR																	
		NAME																			
		SIGNATURE																			
		DATE																			
																				BIDDER'S/VENDORS COMPANY SEAL	

## MOTOR

TESTS/CHECKS TEMS/COMPONENTS	Visual	Dimensional	Make/Type/Rating /General Physical Inspection	Mech/Chem. Properties	NDT /DP/MPI/UT	Metallography	Electrical Characteristics	Welding/Brazing(WPS/PQR)	Heat Treatment
Plates for stator frame, end shield, spider etc.	Y	Y	Y	Y	Y				Y
Shaft	Y	Y	Y	Y	Y	Y			Y
Magnetic Material	Y	Y	Y	Y			Y		
Rotor Copper/Aluminium	Y	Y	Y	Y			Y		Y
Stator copper	Y	Y	Y	Y			Y		Y
SC Ring	Y	Y	Y	Y	Y		Y	Y	Y
Insulating Material	Y		Y	Y			Y		
Tubes, for Cooler	Y	Y	Y	Y	Y				Y
Sleeve Bearing	Y	Y	Y	Y	Y				Y
Stator/Rotor, Exciter Coils	Y	Y	Y				Y	Y	
Castings, stator frame, terminal box and bearing housing etc.	Y	Y	Y	Y	Y			Y	
Fabrication & machining of stator, rotor, terminal box	Y	Y			Y			Y	Y
Wound stator	Y	Y					Y	Y	
Wound Exciter	Y	Y					Y	Y	
Rotor complete	Y	Y					Y		
Exciter, Stator, Rotor, Terminal Box assembly	Y	Y					Y		
Accessories, RTD, BTD, CT, Space heater, antifriction bearing, gaskets etc.	Y	Y	Y						
Complete Motor	Y	Y	Y						
<b>Note:</b> 1. This is an indicative list of tests/checks. The manufacture is to furnish a detailed Quality Plan indicating the practices & Procedure followed along with relevant supporting documents during QP finalization. However, No QP for LT motor upto 50KW. 2. Additional routine tests for Flame proof motors shall be applicable as per relevant standard 3. Makes of major bought out items for HT motors will be subject to NTPC approval. Y1 = for HT Motor / Machines only.									

**MOTOR**

TESTS/CHECKS ITEMS/ COMPONENTS	Magnetic Characteristics	Hydraulic/Leak/Pressure Test	Thermal Characteristics	Run out	Dynamic Balancing	Routine & Acceptance tests as per IS-325/IS-4722 /IS- 9283/IS 2148/IEC60034/IEC 60079-I	Vibration	Over speed	Tan delta, shaft voltage & polarization index test	Paint shade, thickness & adhesion
Plates for stator frame, end shield, spider etc.										
Shaft										
Magnetic Material	Y		Y							
Rotor Copper/Aluminium										
Stator copper			Y							
SC Ring										
Insulating Material			Y							
Tubes for Cooler		Y								
Sleeve Bearing		Y								
Stator/Rotor, Exciter Coils										
Castings, stator frame, terminal box and bearing housing etc.										
Fabrication & machining of stator, rotor, terminal box										
Wound stator										
Wound Exciter										
Rotor complete				Y	Y					
Exciter, Stator, Rotor, Terminal Box assembly										
Accessories, RTD, BTD,CT, , Space heater, antifriction bearing, gaskets etc.										
Complete Motor						Y	Y	Y	Y1	Y
<p><b>Note:</b> 1. This is an indicative list of tests/checks. The manufacture is to furnish a detailed Quality Plan indicating the practices &amp; Procedure followed along with relevant supporting documents during QP finalization. However, No QP for LT motor upto 50KW.</p> <p>2. Additional routine tests for Flame proof motors shall be applicable as per relevant standard</p> <p>3. Makes of major bought out items for HT motors will be subject to NTPC approval. Y1 = for HT Motor / Machines only.</p>										

**LV MOTORS****DATA SHEET-A****ANNEXURE - I**

SPECIFICATION NO.

VOLUME II B

SECTION D


REV NO. 00 DATE 02.08.2019


SHEET 1 OF 1


- |      |   |   |  |
|------|---|---|--|
| 1.0  | Design ambient temperature                                    | : | 50 °C  |
| 2.0  | Maximum acceptable kW rating of LV motor                      | : | ≤200KW   |
| 3.0  | Installation (Indoors/ Outdoors)                              | : | As required  |
| 4.0  | Degree Of Protection (Indoor/Outdoor)                         | : | IP54/IP55  |
| 5.0  | Type of Cooling   | : | TEFC/CACA/TETV                                       |
| 6.0  | Details of supply system                                      |   |  |
|      | a) Rated voltage (with variation)                             | : | 415V ± 10%   |
|      | b) Rated frequency (with variation)                           | : | 50 Hz (Variation: +3% TO –5%)                        |
|      | c) Combined voltage & freq. variation                         | : | 10%  |
|      | d) System fault level at rated voltage                        | : | 50 kA for 1 sec                                      |
|      | e) Short time rating for terminal boxes                       |   |  |
|      | ○ 110kW & Above (Breaker controlled)                          | : | 50 kA for 1 sec                                      |
|      | ○ Below 110kW (SFU+ Contactor controlled)                     | : | 50 KA for 0.20 sec.                                  |
|      | f) LV System grounding  | : | Solidly  |
| 7.0  | Class of insulation   | : | Refer clause 7.03.00 of Customer Motor Specification |
| 8.0  | Minimum voltage for starting (As percentage of rated voltage) | : | Refer clause 6.03.00 of Customer Motor Specification |
| 9.0  | Power cables data   | : | Shall be given during Detailed engg.                 |
| 10.0 | Earth Conductor Size & Material                               | : | Shall be given during Detailed engg.                 |
| 11.0 | Space heater supply   | : | 240 V, 1Φ , 50 Hz                                    |
| 12.0 | Rating up to which Single phase motor                         | : | Acceptable upto 0.20 kW                              |
| 13.0 | Tests   | : | As per Customer motor spec. (enclosed)               |
| 14.0 | Energy efficient/ Flame proof motor                           | : | As per Customer spec. requirement                    |


- **Also detail Customer spec. for Motors to be referred as enclosed with the specification.**




CLAUSE NO.	Bidder's Name .....							
	<b>DE-1B</b>	<b>LT MOTORS</b>						
	<b>A.</b>	<b>GENERAL</b>						
	5.	Manufacturer & Country of origin. (Shall be as per approved QA make)						
	6.	Equipment driven by motor						
	7.	Motor type						
	8.	Quantity						
	<b>B.</b>	<b>DESIGN AND PERFORMANCE DATA</b>						
	18.	Frame size						
	19.	Type of duty						
	20.	Type of enclosure /Method of cooling/ Degree of						
	21.	Applicable standard to which motor generally						
	22.	Efficiency class as per IS 12615						
	23.	(a)Whether motor is flame proof	Yes/No					
		(b)If yes, the gas group to which it conforms as per IS:2148						
	24.	Type of mounting						
	25.	Direction of rotation as viewed from DE END						
	26.	Standard continuous rating at 40 deg.C. ambient temp. as per Indian Standard (KW)						
	27.	Derated rating for specified normal condition i.e. 50 deg. C ambient temperature (KW)						
	28.	Maximum continuous load demand of driven						
	29.	Rated Voltage (volts)						
	30.	Permissible variation of :						
		a. Voltage (Volts)						
		b. Frequency (Hz)						
		c. Combined voltage and frequency						
	31.	Rated speed at rated voltage and						
	32.	At rated Voltage and frequency:						
		a. Full load current						
	<table border="1"> <tr> <td>EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800 MW)</td> <td>TECHNICAL DATA SHEETS SECTION – VI, PART-G BID DOC. NO:CS-9585-001-2</td> <td>DB07: MOTORS</td> <td>PAGE 13 OF 17</td> </tr> </table>				EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800 MW)	TECHNICAL DATA SHEETS SECTION – VI, PART-G BID DOC. NO:CS-9585-001-2	DB07: MOTORS	PAGE 13 OF 17
	EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800 MW)	TECHNICAL DATA SHEETS SECTION – VI, PART-G BID DOC. NO:CS-9585-001-2	DB07: MOTORS	PAGE 13 OF 17				

CLAUSE NO.	Bidder's Name .....						
		b. No load current					
	33.	Power Factor at					
		a. 100% load					
		b. NO load					
		c. Starting.					
	34.	Efficiency at rated voltage and frequency,					
		a. 100% load					
		b. 75% load					
		c. 50% load					
	35.	Starting current (amps) at					
		a. 100 % voltage					
		b. 85% voltage					
		c. 80% voltage					
	36.	Minimum permissible starting Voltage (Volts)					
	37.	Starting time with minimum permissible voltage					
		a. Without driven equipment coupled					
		b. With driven equipment coupled					
	38.	Safe stall time with 100% and 110% of rated					
		a. From hot condition					
		b. From cold condition					
	39.	Torques :					
		a. Starting torque at min. permissible voltage(kg-					
		b. Pull up torque at rated voltage.					
		c. Pull out torque					
	d. Min accelerating torque (kg.m) available						
	e. Rated torque (kg.m)						
40.	Stator winding resistance per phase (ohms at 20						
41.	GD <sup>2</sup> value of motors						
<table border="1"> <tr> <td>EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800 MW)</td> <td>TECHNICAL DATA SHEETS SECTION – VI, PART-G BID DOC. NO:CS-9585-001-2</td> <td>DB07: MOTORS</td> <td>PAGE 14 OF 17</td> </tr> </table>				EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800 MW)	TECHNICAL DATA SHEETS SECTION – VI, PART-G BID DOC. NO:CS-9585-001-2	DB07: MOTORS	PAGE 14 OF 17
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800 MW)	TECHNICAL DATA SHEETS SECTION – VI, PART-G BID DOC. NO:CS-9585-001-2	DB07: MOTORS	PAGE 14 OF 17				

CLAUSE NO.	Bidder's Name .....			
	42.	No of permissible successive starts when motor is in hot condition		
	43.	Locked Rotor KVA Input		
	44.	Locked Rotor KVA/KW		
	45.	Vibration limit :Velocity (mm/s)		
	46.	Noise level limit (dBA)		
	<b>C.</b>	<b>CONSTRUCTIONAL FEATURES</b>		
	1.	Stator winding insulation		
		a. Class & Type		
		b. Winding Insulation Process		
		c. Tropicalised (Yes/No)		
		d. Temperature rise over specified maximum ambient temperature of 50 deg C		
		e. Method of temperature measurement		
		f. Stator winding connection		
	2.	Main Terminal Box		
		a. Type		
		b. Location(viewed from NDE side)		
		c. Entry of cables(bottom/side)		
		d. Recommended cable size(To be matched with cable size envisaged by owner)		
		e. Fault level (MVA),Fault level duration(sec)		
		f. Cable glands & lugs details (shall be suitable for		
	3.	Type of DE/NDE Bearing		
	4.	Motor Paint shade		
	5.	Weight of		
		a. Motor stator (KG)		
		b. Motor Rotor (KG)		
		c. Total weight (KG)		
	<b>D.</b>	<b>List of accessories.</b>		
	EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800 MW)		TECHNICAL DATA SHEETS SECTION – VI, PART-G BID DOC. NO:CS-9585-001-2	DB07: MOTORS  PAGE 15 OF 17


CLAUSE NO.	Bidder's Name .....			
	1.	Space Heaters (Applicable for 30 KW & above motor) (Nos./Power in watts/supply voltage)		
	2.	Terminal Box for Space Heater (Yes/No)		
	3.	Speed switch (Yes/No)		
	4.	Insulation of bearing (Yes/No)		
	5.	Noise reducer(Yes/No)		
	6.	Grounding pads		
		i) No and size on motor body		
		ii) Nos on terminal Box		
	7.	Vibration pads		
		i) Nos and size		
		ii) Location		
	8.	Any other fitments		
	<b>E.</b>	<b>List of curves.</b>		
	1.	Torque speed characteristic of the motor		
	2.	Thermal withstand characteristic		
	3.	Starting. current Vs. Time		
	4.	Starting. current Vs speed		
	5.	P.F. and Effi. Vs Load		
	<b>F.</b>	<b>Additional Data to be filled for each rating of DC Motor</b>		
	1.	Rated armature voltage (Volt)		
	2.	Rated field excitation (Amp)		
	3.	Permissible % variation in voltage		
	4.	Minimum Permissible Starting voltage (volt)		
	5.	At rated voltage		
		i)Full load Armature current.(Amp)		
		ii)Full load Field current (Amp)		
	EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800 MW)		TECHNICAL DATA SHEETS SECTION – VI, PART-G BID DOC. NO:CS-9585-001-2	DB07: MOTORS  PAGE 16 OF 17

CLAUSE NO.	Bidder's Name .....		
		iii) No load Armature current (Amp)	
6.		Full load Field current (Amp)	
7.		No load Armature current (Amp)	
8.		Minimum permissible field current (Amp) to avoid	
	i)	Maximum permissible voltage	
	ii)	Rated voltage	
	iii)	Minimum Permissible Voltage	
9.		Resistance (indicative Values) in ohm	
	i)	Armature winding (Arm + IP + Series) at 25	
	ii)	Field Winding at 25 deg. C	
10..		Inductance (indicative values)	
	i)	Armature winding	
	ii)	Field winding	
11		Value of trimmer resistance (ohm) to be connected in series with the shunt field to	
	i)	220 V DC	
	ii)	250 V DC	
	iii)	187 V DC	
12		Value of the external resistance (ohm) required to be connected in series with armature during starting only	
13		Technical data sheet for external resistance box	
14		GA drawing of motor	
15		Starting time calculation	
16		Starter resistance design calculation	
17		Electrical connection diagram of motor	
<p>EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800 MW)</p>			
<p>TECHNICAL DATA SHEETS SECTION – VI, PART-G BID DOC. NO:CS-9585-001-2</p>			
<p>DB07: MOTORS</p>			
<p>PAGE 17 OF 17</p>			

513079/2021/PS-PEM-MAX

Vendor to refer to this list for items in their scope only (as indicated in Electrical scope sheet between BHEL & Vendor)


ANNEXURE II

		PROJECT : PATRATU STPS ( 3X800 MW ) PACAKGE : EPC Sub Package: MOTORS & VVF Drive Panels CONTRACTOR : M/S BHEL CONT. NO. CS-9585-001-2				LIST OF ITEMS REQUIRING QP APPROVAL & ACCEPTABLE VENDOR ; CONTRACTOR-M/S BHEL			REF NO : 9585-001-QOE-R-01 REVISION NO. 00 DATE 20 <sup>th</sup> April 2017	
SL No.	ITEM	QP / INS CAT.	QP No:- 9585- 001- QOE-	QP SUB. SCH.	QP APPL SCHE DULE	SUB-SUPPLIERS	PLACE	SUB- SUPPL. APPL. STATUS AS PER NTPC	SC APPL SCHE DULE	REMARKS
1)	L T (415 V) Motors	Refer Note 1				ABB	FARIDABAD	A		UPTO 55KW
						ABB	BANGALORE	A		55KW - 200KW
						BHARAT BULEE	MUMBAI	A		RQP, FOR FLAME PROOF ALSO
						CGL	AHMEDNAGAR	A		FOR FLAME PROOF ALSO
						JYOTI	BARODA	A		
						KEC	BANGALORE	A		FOR FLAMEVPROOF ALSO
						KEC	HUBLI	A		UPTO 90KW: FOR FLAME PROOF ALSO
						LHP	SOLAPUR	A		UPTO 200KW
						MARATHON	KOLKATA	A		FOR FLAME PROOF ALSO
						NGEF	BANGALORE	A		UPTO 15KW
						SIEMENS	MUMBAI	A		
2)	HT MOTOR					BHEL	BIHOPAL	A		

Deptt.  
ed \* (pued) (pued)  
ed \* Distt - Raipur (pued)

169



		<b>PROJECT : PATRATU STPS (3X800 MW)</b> <b>PACAKGE : EPC</b> <b>Sub Package: MOTORS &amp; VVVF Drive Panels</b> <b>CONTRACTOR : M/S BHEL</b> <b>CONT. NO. CS-9585-001-2</b>				<b>LIST OF ITEMS REQUIRING QP APPROVAL &amp; ACCEPTABLE VENDOR ;</b> <b>CONTRACTOR-M/S BHEL</b>		<b>REF NO : 9585-001-QOE-R-01</b> <b>REVISION NO. 00</b> <b>DATE 20th April 2017</b>	
Sl. No.	ITEM	QP / INS CAT.	QP No:- 9585-001-	QP SUB. SCH.	QP APPL SCHE DULE	SUB-SUPPLIERS	PLACE	SUP. SUPPLIER APPL. STATUS AS	REMARKS

### NOTE 1 : FOR LT MOTORS

#### a) Less than 30 KW

Acceptance of Motor less than 30 KW is based on COC of the manufacturer & the contractor confirming as follows:  
 It is hereby confirmed that the above mentioned motor /motors was/ were manufactured taking care of NTPC specific requirements regarding ambient temp., voltage & frequency variation, hot starts, pull out torque, starting KVA/KW, temp. rise, distance between centre of stud & gland plate and tested in accordance with approved drawing /data sheets.

#### b) 30 KW -50KW

Acceptance of Motor rating between 30 KW & 50 KW is based on NTPC review of Routine Test inspection report as per IS 325 witnessed by main contractor along with COC of the manufacturer & the contractor confirming as follows:  
 It is hereby confirmed that the above mentioned motor /motors was/ were manufactured taking care of NTPC specific requirements regarding ambient temp., voltage & frequency variation, hot starts, pull out torque, starting KVA/KW, temp. rise, distance between centre of stud & gland plate, space heater and tested in accordance with approved drawing /data sheets.


#### c) Above 50 KW as per NTPC approved quality plan

Approval Conditions attached to above vendors-as applicable shall prevail.

#### General Notes:


- 1) Vendor list & category of the mandatory spares shall be as mentioned above.
- 2) For item not appearing in the above list, main contractor to approach NTPC for acceptable vendors & inspection categorization of the same.

- 3) NTPC Approval conditions to above identified vendors shall be adhered to. Vendor's approval conditions will be informed on request of Main Contractor.





*For*  
**(JATIN GAHLAWAT)**  
**BHEL**



		PROJECT : Patratu STPP (2X660 MW)				LIST OF ITEMS REQUIRING QP APPROVAL & ACCEPTABLE				REF NO : 9585-001-QOE-R-01 REVISION NO. 00 DATE 24 <sup>th</sup> April 2017	
		PACAKGE : EPC Sub Package: Electrical Equipment Supply & Erection CONTRACTOR : M/S BHEL CONT. NO. CS-9585-001-2				VENDOR Contractor-M/S BHEL					
Sl. No.	ITEM	QP / INS CAT	QP No:- 9578-001-QVE-	QP SUB. SCH.	QP APP L SCH EDU LE	SUB-SUPPLIERS	PLACE	SUB-SUPPLIER STATUS AS PER NTPC	SC AP PL SC HE DU LE	REMARKS	


13.	Junction boxes / Link Boxes/ Test Link Box/ Adopter box, Switch Boxes, Pull Boxes (Hot Dip Galvanized)	III				Main contractor approved sources with galvanization from NTPC approved sources (Note-2)		Noted		
14.	FRP Junction boxes	II	10			Main Contractor approved sources		Noted		

16.	Cable glands	III				Main contractor approved sources		Noted		
17.	Cable lugs	III				M/s Dowell M/s Billets Elektro Werke Ltd.	Mumbai Umbergaon	A A		









		<b>PROJECT : Patratu STPP (2X660 MW)</b> <b>PACAKGE : EPC</b> <b>Sub Package: Electrical Equipment Supply &amp; Erection</b> <b>CONTRACTOR : M/S BHEL</b> <b>CONT. NO. CS-9585-001-2</b>				<b>LIST OF ITEMS REQUIRING QP APPROVAL &amp; ACCEPTABLE VENDOR</b> <b>Contractor-M/S BHEL</b>				<b>REF NO : 9585-001-QOE-R-01</b> <b>REVISION NO. 00</b> <b>DATE 24<sup>th</sup> April 2017</b>	
Sl. No.	ITEM	QP / INS CAT	QP No:- 9578-001-QVE-	QP SUB. SCH.	QP APP L SCH EDU LE	SUB-SUPPLIERS	PLACE	SUB-SUPPLIER APPL STATUS AS PER NTPC	SC AP PL SC HE DU LE	REMARKS	
1.	M/s M J Engg, Delhi										
2.	M/s Jamna Metal, Delhi										
3.	M/s A.V. Engg, Kolkata										
4.	M/s Inar Profiles, Vishakapatnam										
5.	M/s Anand Udyog, Mumbai										
6.	M/s Techno Engg, Chandigarh										
7.	M/s Steelite Engg, Mumbai										
8.	M/s National Galvanizer, Kolkata										
9.	M/s Unistar Galvanizer, Kolkata										
10.	M/s B.P. Project, Kolkata										
11.	M/s Bajaj Pune										
12.	M/s Electrocare Industries, Mumbai										
13.	M/s B.G. Shirke, Pune										
14.	M/s Gurpreet Galvanizer, Hyderabad										
15.	M/s Sigma, Mumbai										
16.	M/s Radhakrishnan Shetty, Chennai										
17.	Karamlara Mumbai										
18.	Poona Galvanizers Pune										
19.	Neha Galvanizer- Kolkata										
20.	Unitech galvanizers- Hoogly										
21.	Gurpreet galvanizers- Hyderabad										
22.	DMP Projects- Kolkata										

Note-3 : VDE / CE / UL / CSA MARKING FOR PRODUCT QUALITY: SELF CERTIFICATION/VALID CERTIFICATION FROM THIRD PARTY AGENCY OR BIS APPROVAL LETTER WITH CML NO. FOR PRODUCT QUALITY SHALL BE SUBMITTED FOR NTPC'S INFORMATION



*Handwritten signature*  
 (JATIN GAHLAWAT)  
 BHEL

[illegible]



TITLE

TECHNICAL SPECIFICATION  
FOR  
FQA LAB MECHANICAL

SPECIFICATION NO. PE – TS - 434 - 571 – A001A

VOLUME III

SECTION D

REV 0

SHEET OF

VOL - III



TITLE

**TECHNICAL SPECIFICATION  
FOR  
FQA LAB MECHANICAL**

SPECIFICATION NO. PE – TS - 434 - 571 – A001A

VOLUME III

SECTION

REV 0

SHEET OF

**DOCUMENTS TO BE FURNISHED WITH OFFER FOR TECHNICAL EVALUATION**

- 1) SCHEDULE OF TECHNICAL DEVIATION (IF ANY)  
OR


‘NO DEVIATION CERTIFICATE’ – Clearly mentioning that bidder has considered ‘No - Deviation’ from the technical specification provided by BHEL.

- 2) PQR related documents.
- 3) SIGNED AND STAMPED COPY OF COMPLIANCE CUM CONFIRMATION CERTIFICATE.
- 4) Filled Electrical load list, duly signed and stamped
- 5) Un priced copy of price format indicating quoted/ not applicable against each row/column

**NOTE:**

i) NO OTHER DOCUMENTS OTHER THAN THOSE LISTED ABOVE ARE REQUIRED TO BE SUBMITTED FOR TECHNICAL EVALUATION. IN CASE ANY OTHER DOCUMENT IS FURNISHED, THE SAME WILL NOT BE TAKEN INTO CONSIDERATION FOR TECHNICAL EVALUATION.

513079/2021/PS-PEM-MAX

	<b>TECHNICAL SPECIFICATION FOR FQA LAB MECHANICAL 3X660 MW PATRATU STPP COMPLIANCE CUM CONFIRMATION CERTIFICATE</b>	SPEC. NO.: PE-TS-434-571-A001A VOLUME: III SECTION: REV. NO. 0
<p style="text-align: center;"><b><u>COMPLIANCE CUM CONFIRMATION CERTIFICATE</u></b></p> <p>The bidder shall confirm compliance with following by signing/ stamping this compliance certificate (every sheet) and furnish same with the offer.</p> <ol style="list-style-type: none"> <li>a) The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification &amp; there are no exclusions other than those mentioned under "exclusion" in section C and those resolved as per 'Schedule of Deviations', if applicable, with regard to same.</li> <li>b) There are no other deviations w.r.t. specifications other than those furnished in the 'Schedule of Deviations'. Any other deviation, stated or implied, taken elsewhere in the offer stands withdrawn unless specifically brought out in the 'Schedule of Deviations'.</li> <li>c) Bidder shall submit QP in the event of order based on the guidelines given in the specification &amp; QP enclosed therein. QP will be subject to BHEL/ CUSTOMER approval &amp; customer hold points for inspection/ testing shall be marked in the QP at the contract stage. Inspection/ testing shall be witnessed as per same apart from review of various test certificates/ Inspection records etc. This shall be within the contracted price with no extra implications to BHEL after award of the contract.</li> <li>d) All drawings/ data-sheets/ calculations etc. submitted along with the offer shall be considered for reference only, same shall be subject to BHEL/ CUSTOMER approval in the event of order.</li> <li>e) The offered materials shall be either equivalent or superior to those specified in the specification &amp; shall meet the specified/ intended duty requirements. In case the material specified in the specifications is not compatible for intended duty requirements then same shall be resolved by the bidder with BHEL during the pre - bid discussions, otherwise BHEL/ Customer's decision shall be binding on the bidder whenever the deficiency is pointed out.</li> </ol> <p>For components where materials are not specified, same shall be suitable for intended duty, all materials shall be subject to approval in the event of order.</p> <ol style="list-style-type: none"> <li>f) The commissioning spares shall be supplied on 'As Required Basis' &amp; prices for same included in the base price itself.</li> <li>g) All sub vendors shall be subject to BHEL/ CUSTOMER approval in the event of order.</li> <li>h) Guarantee for plant /equipment shall be as per relevant clause of GCC /SCC /Other Commercial Terms &amp; Conditions.</li> <li>i) In the event of order, all the material required for completing the job at site shall be supplied by the bidder within the ordered price and within purview of the tender specification even if the same are additional to approved billing break up, approved drawing or approved Bill of quantities.</li> <li>j) Schedule of drawings submissions, comment incorporations &amp; approval shall be as stipulated in the specifications. The successful bidder shall depute his design personnel to BHEL's/ Customer's/ Consultant's office for across the table resolution of issues and to get documents approved in the stipulated time.</li> </ol>		

513079/2021/PS-PEM-MAX



TITLE:

**TECHNICAL SPECIFICATION FOR  
FQA LAB MECHANICAL  
3X660 MW PATRATU STPP  
COMPLIANCE CUM CONFIRMATION  
CERTIFICATE**

SPEC. NO.: PE-TS-434-571-A001A

VOLUME: III

SECTION:

REV. NO. 0

- k) As built drawings shall be submitted as and when required during the project execution.
- l) The bidder has not tempered with this compliance cum confirmation certificate and if at any stage any tempering in the signed copy of this document is noticed then same shall be treated as breach of contract and suitable actions shall be taken against the bidder.

513079/2021/PS-PEM-MAX

LOAD TITLE	RATING (KW / A)		UNIT (U)/STN (S)	Nos.		VOLTAGE CODE*	FEEDER CODE**	EMER. LOAD (Y)	CONT.(C)/ INTT.(I)	STARTING TIME >5 SEC (Y)	LOCATION	BOARD NO.	CABLE		BLOCK CABLE DRG. No.	CONT ROL CODE	REMA RKS	LOAD No.	VERIFICATI ON FROM MOTOR DATASHEE T (Y/N)	KKS NO
	NAME PLATE	MAX. CONT. DEMAND (MCR)		SIZE CODE	Nos															
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
ANNEXURE-VI																				
NOTES: 1. COLUMN 1 TO 12 & 18 SHALL BE FILLED BY THE REQUISITIONER (ORIGINATING AGENCY); REMAINING COLUMNS ARE TO BE FILLED UP BY PEM (ELECTRICAL)/ CUSTOMER 2. ABBREVIATIONS : * VOLTAGE CODE (7):- (ac) A=11 KV, B=6.6 KV, C=3.3 KV, D=415 V, E=240 V (1 PH), F=110 V (cc): G=220 V, H=110 V, J=48 V, K=+24V, L=-24 V : ** FEEDER CODE (8):- U=UNIDIRECTIONAL STARTER, B=BI-DIRECTIONAL STARTER, S=SUPPLY FEEDER, D=SUPPLY FEEDER (CONTACTER CONTROLLED)																				
LOAD DATA (ELECTRICAL)	JOB NO.		434				ORIGINATING AGENCY				PEM (ELECTRICAL)									
	PROJECT TITLE		3X800 MW PATRATU STPP				NAME				DATA FILLED UP ON									
	SYSTEM		FQA LAB MECHANICAL				SIGN.				DATA ENTERED ON									
	DEPTT. / SECTION		MAX				SHEET 1 OF 1		REV. 00		DE'S SIGN. & DATE									



## **DELIVERY SCHEDULE**

**PROJECT: - 3 x 800 MW PVUNL PATRATU TPP PHASE-I**

**PACKAGE: - FQA Lab-Mechanical**

1. **Delivery Period: 210 days from the date of PO.** However, delivery Schedule shall be as per below:-

Within Five (05) months from date of CAT-1 approval of Primary drawing/documents or BHEL manufacturing clearance whichever is later.

In case date of CAT-1 approval of Primary drawing/documents is later than the date of BHEL manufacturing clearance then for delay analysis, any delay in submission/re-submission of Primary drawing/documents shall be reduced from the given delivery period of 05 months. Delay in BHEL's comments/approval beyond 18 days shall also be considered for delay analysis.

In case BHEL manufacturing clearance date is later than date of cat-1 approval of Primary drawing/documents, then for delay analysis submission/re-submission time of Primary drawing/document shall not be considered.

Further, please note the following :-

- a) The end period specified is for completion of the deliveries. Deliveries to start progressively so as to meet the completion schedule.
- b) The delivery conditions specified are for contractual LD purposes, however, BHEL may ask for early deliveries without any compensation thereof.
- c) Non-applicable drawings shall be decided during bid evaluation.
- d) Wherever schedule of drawings / documents submission / re-submission is stipulated in the Technical Specifications, same shall be superseded by delivery specified in NIT.

### **DRG SCHEDULE-**

**For Primary documents** - GA, Foundation Details (as required) and Data sheet of Machine/Equipment with detailed BOM & Inspection Checklist/ Manufacturing Quality Plan of Machine equipment. (Rev-0 of drawings shall be submitted within 21 days from PO & subsequent revisions within 10 days of comments received from BHEL. BHEL shall furnish comments/approval on each submission within 18 days from receipt.)

**For Secondary documents** - O & M Manual & Erection Procedure { within 30 days of issuance of MDCC }

## Letter head of Company (<Rs. 10 Cr value)

Ref.....

Date.....

To,

Bharat Heavy Electricals Limited

PEM, PPEI Building, Plot No 25,

Sector -16A, Noida (U.P)-201301

**Subject: - Certification regarding local content**

Reference: Tender Enquiry No-.....

Name of Package: .....

Dear Sir,

We hereby certify that items offered by us of .....(package name).....for.....(Project Name/Rate contract)..... meets the requirement of minimum local content in line with Cl. No..... of NIT No..... dated..... and the Public Procurement (Preference to Make in India), Order 2017 dated-15.06.2017, 28.05.2018 & 29.05.2019.

We further confirms that details of location at which the local value addition is made will be our registered works at .....(address of the works)

Yours very truly

..... (authorized signatory of company)

..... (firm name)

authorized signatory  
of company

An undertaking regarding Model Clauses (To be provided alongwith bid)

Reference:

**RA/Bid no:**

**Item:**

**Project:**

**TO WHOM SO IT MAY CONCERN**

This is with reference to Ministry of Finance circular dated 23.07.20 reg. restriction under rule 144 (xi) of GFR.

“I have read the clause regarding restrictions on procurement from a bidder of a country which shares a land border with India. I hereby certify that M/s .....is not from such a country and is eligible to be considered against Bid/RA no: .....”

Sign & Signature

Date:

Place: