

<div><div>बीएसईएल</div><div>BHEL</div></div>		PROJECT: 1 X 660 MW MAHAGENCO BHUSAWAL TPS										
		PACKAGE: LT XLPE POWER CABLE										
		GEM BID No.:-										
A	1.1KV, Cu conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables (Non Magnetic Hard drawn Aluminium Round Wire Armoured conforming to H4 grade for single core cables), INNER SHEATH: Extruded HRPVC compound conforming to type ST2 of IS: 5831 for multicore cable & no inner sheath for single core cables, OVERALL SHEATH: Extruded FRLS HRPVC compound conforming to type ST2 of IS: 5831 & black in colour.											
SL. NO.	ITEM CODE	ITEM DESCRIPTION	UOM	QUANTITY (IN METER)	DRUM LENGTH (IN METER)	HSN CODE	UNIT EX- WORKS PRICE (DULY PACKED) (INR)	TOTAL EX- WORKS PRICE (DULY PACKED) (INR)	FREIGHT CHARGES WITHOUT GST@% OF TOTAL EX WORKS (INR)	APPLICABLE GST RATE % ON (TOTAL EX WORKS + FREIGHT) (INR)	GST Amount on Total Ex- works + Freight (Rs.)	TOTAL FOR SITE PRICE (INR)
1	2	3	4	5	6	7	9	10	11	12	13	14
A1	507-28009-A	1C - 630- CU ARMOURED	METER	500	500	8544						
A2	507-28130-A	1C - 35-CU ARMOURED	METER	13500	500	8544						
B	GRAND TOTAL (Rs.)											

NOTE:-

- 1.The standard drum length shall be 500/1000 meters as indicated above. Tolerance on individual drum length shall be $\pm 5\%$.
2. Overall tolerance on total dispatched quantity of each size shall be (-) 2% and (+) 0% except where the total ordered quantity is one single drum length of 500/1000m, in which case it shall be -5% to 0%. Cables consumed for testing and inspection shall be to bidder's account.
3. For each individual cable size, one short length of not less than 200m may be accepted only in the final drum length to complete the supply (except where the total ordered quantity is one single drum length of 500/1000m). The overall tolerance limits stipulated above shall continue to apply (in case short lengths are accepted).
4. In case of the quantities cleared by BHEL for manufacturing are manufactured and offered for inspection by successful bidder in more than one batch, BHEL reserves the right to witness type testing on all batches without any price implications.
5. Unit price of cables quoted by bidder shall be inclusive of type test charges. No separate charges shall be payable for type tests.
6. For any clarification please refer Technical Specification No--PE-TS-415-507-E002 REV 00.
- 7- Quantity variation shall be as per clause of GeM Bid.