

2 x 660MW Udangudi STPP Stage-I - STATION LIGHTING SYSTEM					
BOQ CUM UNPRICE SCHEDULE FOR LIGHTING PANELS					
ITEM NO.	DESCRIPTION-MAIN EQUIPMENT	UNIT	QTY.	UNIT PRICE	TOTAL PRICE
1.0	Lighting Panels (LP)				
1.1	AC Normal / Emergency outdoor Type LP-A(12) [with timer]	Nos.	11		
1.2	DC Outdoor Type LP-D (6)	Nos.	8		

NOTES:

1. PVC shall be applicable (<https://ieema.org/wp-content/uploads/2020/07/lvswgr-jan-2019.pdf>) with upper ceiling limit of 20% & no negative ceiling limit.

TAMILNADU GENERATION & DISTRIBUTION CORPORATION LIMITED

2 x 660MW Udangudi STPP Stage-I

VOLUME – II


TECHNICAL SPECIFICATION FOR

LIGHTING PANELS

SPECIFICATION NO: PE-TS-435-558-E005A, REV-0




**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
NOIDA, UTTAR PRADESH, INDIA – 201301**

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-TS-435-558-E005A	
		VOLUME II	
		CONTENTS SHEET	
	2 x 660MW UDANGUDI STPP	REV. 00	DATE: 18.11.2024
		SHEET 1 OF 1	

CONTENTS


<u>S. NO.</u>	<u>DESCRIPTION</u>	<u>NO. OF SHEETS</u>
01	SECTION - I	
	COMPLIANCE CERTIFICATE	1
	SPECIFIC TECHNICAL REQUIREMENT	4
	DATA SHEET-A	4
	SUB-VENDOR LIST	5
	DATA SHEET-C	4
02	SECTION - II	
	GENERAL TECHNICAL REQUIRMENTS	10
	QUALITY PLAN	4
	PACKING SPECIFICATION	2

TOTAL NUMBER OF SHEETS: 39

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-TS-435-558-E005A	
		VOLUME II	
		SECTION - I	
	2 x 660MW UDANGUDI STPP	REV. 00	DATE: 18.11.2024
		SHEET 1 OF 10	

SECTION – I


SPECIFIC TECHNICAL REQUIREMENTS

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-TS-435-558-E005A	
		VOLUME II	
		SECTION - I	
	2 x 660MW UDANGUDI STPP	REV. 00	DATE: 18.11.2024
		SHEET 2 OF 10	

COMPLIANCE CERTIFICATE

The bidder shall confirm compliance to the following by signing/ stamping this compliance certificate and furnishing same with the offer.

1. The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusion/ deviation with regard to same.
2. There are no deviation with respect to specification other than those furnished in the 'schedule of deviations'.
3. Only those technical submittals which are specifically asked for in NIT to be submitted at tender stage shall be considered as part of offer. Any other submission, even if made, shall not be considered as part of offer.
4. Any comments/ clarifications on technical/ inspection requirements furnished as part of bidder's covering letter shall not be considered by BHEL, and bidder's offer shall be construed to be in conformance with the specification.
5. Any changes made by the bidder in the price schedule with respect to the description/ quantities from those given in BOQ-Cum-Price schedule of the specification shall not be considered (i.e. technical description & quantities as per specification shall prevail).

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-TS-435-558-E005A	
		VOLUME II	
		SECTION - I	
	2 x 660MW UDANGUDI STPP	REV. 00	DATE: 18.11.2024
		SHEET 3 OF 10	

1.0 SCOPE OF SUPPLY

- 1.1 Design, manufacture, assembly, inspection & testing at vendor's/ sub-vendor's works, proper packing and delivery to site of LIGHTING PANELS as mentioned in different sections of this specification, complete with all accessories for efficient and trouble-free operation.
- 1.2 Standard technical requirements of LIGHTING PANELS are indicated in Section-II. Project specific requirements/changes are listed in Section-I.
- 1.3 The stipulations of Section-I, followed by those of Data Sheet-A shall prevail and govern in case of conflict between the corresponding requirements of Section-I and Section-II.
- 1.4 Review of sub-vendor's documents by the vendor shall not relieve the vendor from the responsibility of design & supply.
- 1.5 The documents shall be in English language and MKS system of units.

2.0 BILL OF QUANTITIES:

- 2.1 Quantity requirements shall be as per BOQ-cum-price schedule as part of NIT.
- 2.2 Supplier to also give the following undertaking in the BOM: "The BoM provided herewith completes the scope (in content and intent) of material supply under PO No. -----, dated -----. Any additional material which may become necessary for the intended application of the supplied item(s)/package will be supplied free of cost in most reasonable time."


3.0 SPECIFIC TECHNICAL REQUIREMENTS

- 3.1 Lighting panel (LP) for controlling lights with additional provision for manual control shall be provided:

AC Outdoor lighting panel: With Timer or photocell

3.3 AC Normal Lighting Systems:

AC Normal lighting fixtures are fed through AC Lighting panels (ACLP) which are fed from Lighting Distribution Board (LDB).

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-TS-435-558-E005A	
		VOLUME II	
		SECTION - I	
	2 x 660MW UDANGUDI STPP	REV. 00	DATE: 18.11.2024
		SHEET 4 OF 10	

AC normal lighting panel as per details given below is envisaged:

Incomer type: TPN MCB
 Incomer rating: 63A
 Outgoing feeder type: SPN MCB
 Outgoing feeder rating: 20A
 Short circuit rating: 10kA
 ELCB in Incomer: Yes

3.5 DC Emergency Lighting Systems:

DC Emergency lighting fixtures fed through DC Emergency Lighting panels (DCELP) which are fed through DC emergency Lighting Distribution Board (DCELDB).

DCELPs as per details given below is envisaged:

Incomer type: DP MCB
 Incomer rating: 32A
 Outgoing feeder type: DP MCB
 Outgoing feeder rating: 20A

3.6 Lighting Panel

a) The Lighting panels shall be rated for 415 V, 3 phase, 4 wire, AC with neutral bus and suitable for either wall/column mounting. Outdoor panels shall have degree of protection of IP 55 and shall have a sloping canopy. Panels shall be constructed from CRCA sheet. Sheet thickness shall be 2.0 mm.

b) Lighting Panels shall be so constructed as to permit free access to the terminal connections and easy replacement of parts. Front access doors shall have padlocking arrangements.


c) Lighting panels shall have provision of cable entry from top and bottom, as required, with removable gland plates. Necessary double compression type brass cable glands, tinned copper/Aluminium cable lugs are to be furnished.

d) Two ground pads with M10 G.I. bolts and nuts shall be provided on each Lighting Panel for connection to 25 x 6 mm GS flat.

e) Each Lighting Panel shall be complete with designation and caution notice plates fixed on front cover and a circuit directory plate fixed on inside of the front cover. Circuit directory plate shall contain details of the points to be controlled by each circuit including the location of the point controlled, rating of the protective units and loading of each circuit. The plates shall be of anodized aluminium with inscriptions indelibly etched on it.

f) Bus bars shall be made of high conductivity copper/aluminium alloy. They shall be supported on insulators of material such as fiber reinforced polyester or epoxy cast resin. Bus bar shall be electrolytic grade hard drawn aluminium, colour coded for easy identification and designed for a maximum temperature of 90°C.

g) Incoming and outgoing circuits shall be terminated in suitable terminal blocks.

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-TS-435-558-E005A	
		VOLUME II	
		SECTION - I	
	2 x 660MW UDANGUDI STPP	REV. 00	DATE: 18.11.2024
		SHEET 5 OF 10	

h) All indicating lamps will be cluster LED type.

3.7 Lighting Panel Equipment

- a) Each lighting panel shall have an incoming TPN MCB with neutral link and a number of outgoing miniature circuit breakers (MCB).
- c) Panel access door shall be interlocked with incoming switch unit such that the door can be opened only when the switch is in OFF position. Means shall be provided to defeat this interlock.
- d) Contactors shall be air-break electromagnetic type fitted with arc shields.
- e) MCB shall be suitable for manual closing and opening and also automatic trip on overload and short circuit.
- f) Each lighting panel shall be provided with adequate number of outgoing MCBs for controlling fixtures. 5A, 3Pin sockets shall be fed from the lighting panel through separate circuits.

3.8 Terminals

Multi way terminal blocks of approved type, complete with screws, nuts, washers and marking strips shall be furnished for connection of incoming/outgoing wires.

Each terminal shall be suitable for connection upto 2 nos. 10 Sq.mm stranded aluminium conductors without any damage to the conductor or looseness of connectors.


3.9 Painting

Painting shall be carried out by approved process. After preparation of the under surface the equipment shall be painted with epoxy based paint by powder coating. The final thickness of paint film on sheet steel shall not be less than 85 microns. Final shade shall be RAL-7035.

All equipment shall be given touch-up paint as required after installation.

3.10 Miniature circuit breakers (MCB) shall have thermal elements for overload protection and an instantaneous magnetic trip to protect against severe faults. All MCBs provided shall be suitable for breaking capacity of 10 kA (minimum) at 240 V AC.

3.11 Contactors shall be of the air break type fitted with arc shields. Time switch shall be suitable for automatic switching ON and OFF of street lighting / flood lighting circuits. Time switch has 00 - 24 hours clock base. Time switch shall indicate actual time and shall permit accurate time setting. Time switch shall be provided with Ni-Cd gel battery.

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-TS-435-558-E005A	
		VOLUME II	
		SECTION - I	
	2 x 660MW UDANGUDI STPP	REV. 00	DATE: 18.11.2024
		SHEET 6 OF 10	

4.0 DOCUMENTATION

4.1 Documents required along with the technical offer: -

- Signed & Stamped copy of Compliance certificate.
- List of E&C Spares (If applicable).
- All PQR related documents.

4.2 Documents required after award of LOI/PO shall be follows (to be submitted by successful bidder):

DOCUMENTS SUBMISSION SCHEDULE

<i>BHEL Drawing No.</i>	<i>Drawing Title</i>	<i>Vendor Sub (Days)*</i>	<i>Bhel comment (Days)</i>	<i>Vendor Sub (Days)#</i>	<i>Bhel and Customer comment /approval (Days)</i>
Primary Documents					
PE-V2-435-558-E405	DATA SHEET OF LIGHTING PANEL	11	8	8	18
PE-V2-435-558-E902	QUALITY PLAN OF LIGHTING PANEL	11	8	8	18
PE-V2-435-558-E012	GA DRAWING & SCHEME DRAWING OF LIGHTING PANEL	11	8	8	18
Secondary Documents		11	8	8	18
PE-V2-435-558-E511	BILL OF MATERIAL				
PE-V2-435-558-E409	TYPE TEST REPORTS FOR LIGHTING PANELS				

NOTES:

a) * 1st submission within indicated days from date of purchase order
b) # Submission (within indicated days) after incorporating all BHEL comments
c) Primary documents shall be considered for Delay analysis
d) Vendor shall submit the dates for drawing/document submission/BHEL comments/ resubmission after approval of documents.



TECHNICAL SPECIFICATION FOR LIGHTING PANELS

2 x 660MW UDANGUDI STPP

SPECIFICATION NO. PE-TS-435-558-E005A

VOLUME II

SECTION - I

REV. 00

DATE: 18.11.2024

SHEET 7 OF 10

DATA SHEET –A

S. No.	Description	Unit	Value
1.0	SYSTEM DESIGN DATA		
1.1	Design ambient	°C	50
1.2	AC Supply		
a)	Rated voltage	V	415
b)	Rated frequency	Hz	50
c)	Voltage variation (permissible)	%	+10% to -10%
d)	Frequency variation (permissible)	%	+3% to -5%
e)	Combined voltage & frequency variation (sum of absolutes permissible)	%	10%
f)	System fault level & duration	kA, sec.	50kA for 1 sec.
1.3	DC Supply		
a)	Rated voltage	V	220
b)	Voltage variation (permissible)	%	+10% to -15%
c)	System fault level & duration	kA, sec.	25kA for 1 sec.
2.0	APPLICABLE STANDARDS		
	IS 60947 Low voltage switchgear and controlgear		
	IS 13703 Low voltage fuses for voltages not exceeding 1000V AC or 1500 V		
	IS 10118 Code of practice for selection, installation and maintenance of switchgear and controlgear		
	IS 60898 Electrical Accessories - circuit breakers for over protection for household and similar installations		
	IS 1901 Visual indicator lamps		
	IS:2551 Danger notice plates		
3.0	LIGHTING PANELS		
3.1	Application		[] Indoor [√] Outdoor [] Both
3.2	Type of sheet		CRCA
3.3	Sheet thickness (minimum)		2.0 mm
3.4	Degree of Protection		



TECHNICAL SPECIFICATION FOR LIGHTING PANELS

2 x 660MW UDANGUDI STPP

SPECIFICATION NO. PE-TS-435-558-E005A

VOLUME II

SECTION - I

REV. 00

DATE: 18.11.2024

SHEET 8 OF 10

a)	Outdoor panel		IPW-55, Weatherproof
b)	Canopy in outdoor panel		<input checked="" type="checkbox"/> Yes [] No
3.5	Bus bar material		High conductivity Copper/Aluminium Alloy
3.6	Earth bus bar required		<input checked="" type="checkbox"/> Yes [] No
3.7	Earth bus bar material (if applicable)		Aluminium
3.8	Gland Plate	mm	2.0
3.9	Earthing studs required		<input checked="" type="checkbox"/> Yes [] No
3.10	Hinged door with locking facility		<input checked="" type="checkbox"/> Yes [] No
3.11	AC Lighting Panel		
a)	Incomer rating	A	63A
b)	Type of Incomer		[] SFU <input checked="" type="checkbox"/> TPN MCB
c)	Earth Leakage Circuit Breaker (ELCB) in incomer required		[<input checked="" type="checkbox"/>] Yes [] No
d)	Type of Outgoing Feeders		<input checked="" type="checkbox"/> SPN MCB with neutral link [] TPN MCB
e)	Outgoing feeders rating	A	20
3.12	DC Lighting Panel		
a)	Incomer rating	A	32
b)	Type of Incomer		[] DP SFU [<input checked="" type="checkbox"/>] DP MCB
c)	Type of Outgoing Feeders		<input checked="" type="checkbox"/> DP MCB
d)	Outgoing feeders rating	A	20
4.0	COMPONENTS OF LIGHTING SYSTEM EQUIPMENT		
4.1	Miniature Circuit Breaker		
a)	SPN MCB rating (min)	A	Refer Sl. No. 3
b)	DP MCB rating (min)	A	Refer Sl. No. 3
c)	TPN MCB rating (min)	A	Refer Sl. No. 3
d)	Short time rating	kA	10



TECHNICAL SPECIFICATION FOR LIGHTING PANELS

2 x 660MW UDANGUDI STPP

SPECIFICATION NO. PE-TS-435-558-E005A

VOLUME II

SECTION - I

REV. 00

DATE: 18.11.2024

SHEET 9 OF 10

e)	Magnetic short circuit protection required		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
f)	Thermal overload protection required		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
4.2	Power Contactors		
a)	Coil voltage (nominal)		
	AC contactors	V	240
	DC contactors	V	220
b)	Current rating of contacts		
	Power	A	As per manufacturer data
	Control	A	As per manufacturer data
4.3	Timer		
4.3.1	Time switch		
a)	Type		Digital synchronous (with Ni-Cd gel battery)
b)	Range	hr	0-24
c)	Coil voltage rating	V	240
4.4	Selector switch		
a)	Type of selector switch		<input checked="" type="checkbox"/> Stay put <input type="checkbox"/> Wing knob
b)	Lockable		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
4.5	Indicating Lamps		
a)	Lens Colour		
	ON condition		Red
	OFF condition		Green
b)	Circuit voltage	V	240V
4.6	Cable Glands		By vendor for all incoming and outgoing cables
a)	Type		<input checked="" type="checkbox"/> Double compression <input type="checkbox"/> Single compression
b)	Material		Brass
c)	Nickel Plating provided		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No



TECHNICAL SPECIFICATION FOR LIGHTING PANELS

2 x 660MW UDANGUDI STPP

SPECIFICATION NO. PE-TS-435-558-E005A

VOLUME II


SECTION - I

REV. 00

DATE: 18.11.2024

SHEET 10 OF 10

4.7	Cable Lugs		By vendor for all incoming and outgoing cables
a)	Type		Crimping type/ ring type
b)	Material		Tinned copper
5.0	PAINTING		
5.1	Paint shade		
a)	LPs		RAL 7035
5.2	Paint Finish		
a)	Interior		[] Matt [✓] Semi-glossy
b)	Exterior		[✓] Semi-glossy [] Full-glossy
5.3	Paint Thickness	Microns	85 micron

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-TS-435-558-E005A	
		VOLUME II	
		SECTION - I	
	2 x 660MW UDANGUDI STPP	REV. 00	DATE: 18.11.2024
		SHEET OF	

ANNEXURE-1

SUB-VENDOR LIST

ITEM CODE	ITEM/SERVICE DESCRIPTION	SL NO.	VENDOR CODE	VENDOR NAME	ADDRESS	PHONE	REMARKS
ES1	AC CONTACTORS	1	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 amit.bhadauria@siemens.com	
	AC CONTACTORS	2	A35	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032	044-49681447	
	AC CONTACTORS	3	E1144	TELEMECHANIQUE/ SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	TAKEN OVER BY SCHNEIDER
	AC CONTACTORS	4	L01	L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015	011-41419554/59	
	AC CONTACTORS	5	B04	BCH	20/4, MATHURA ROAD, FARIDABAD, HARYANA-121006	0129-4293000	
ES2	AC LOAD BREAK SWITCH	1	A35	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032	044-49681447	
	AC LOAD BREAK SWITCH	2	L01	L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015	011-41419554/59	
	AC LOAD BREAK SWITCH	3	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 amit.bhadauria@siemens.com	
	AC LOAD BREAK SWITCH	4	E1076	KAYCEE	KAYCEE INDUSTRIES LTD., C/O-CMS COMPUTERS LTD., 35A, REAR BLDG., KILOKARI, NEW DELHI-110014	Rajiv Sharma-9312004687	
	AC LOAD BREAK SWITCH	5	C01	C&S ELECTRIC LTD.	222, OKHLA IND. ESTATE, PH-III, NEW DELHI-110020	011-3088 7520-29	
ES3	AC MCCB	1	C01	C&S ELECTRIC LTD.	222, OKHLA IND. ESTATE, PH-III, NEW DELHI-110020	011-3088 7520-29	
	AC MCCB	2	S03	SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	
	AC MCCB	3	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 amit.bhadauria@siemens.com	
	AC MCCB	4	A35	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032	044-49681447	
	AC MCCB	5	L01	L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015	011-41419554/59	
	AC MCCB	6	C02	CROMPTON GREAVES	RAIL TRANSPORTATION SYSTEMS,VANDANA BUILDING, 11, TOLSTOY MARG, TOLSTOY MARG, NEW DELHI, DL 110001	011 3041 6300	
ES7	AUXILIARY RELAYS	1	A24	ABB	14, MATHURA ROAD, FARIDABAD, HARYANA-121003	0129-2567580, 09871799449	
	AUXILIARY RELAYS	2	G01	ALSTOM LTD	A-7, SEC-65, NOIDA	0120-479 0000	
	AUXILIARY RELAYS	3	E1075	JYOTI LTD.	JYOTI LIMITED, E&CS DIVISION,3/15, BIDC, GORWA,VADODARA - 390 016, E-MAIL ID: ECS@JYOTI.COM	Ph. No.:+91-265-2281214 , Fax No.:+91-265-2281214	
	AUXILIARY RELAYS	4	E1099	OEN INDIA LTD	29/1479, VYTILLA, COCHIN - 682 019 KERALA, INDIA	Phone : +91 484 2301132, 2303709 Fax : +91 484 2302287, 2302221 sales@oenindia.com	
	AUXILIARY RELAYS	5	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 amit.bhadauria@siemens.com	
ES8	BIMETAL RELAYS	1	L01	L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015	011-41419554/59	
	BIMETAL RELAYS	2	A35	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032	044-49681447	
	BIMETAL RELAYS	3	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 amit.bhadauria@siemens.com	
	BIMETAL RELAYS	4	E1144	TELEMECHANIQUE/ SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	TAKEN OVER BY SCHNEIDER
ES11	CABLE GLANDS	1	E1201	ALLIED TRADERS & EXPORTERS	C-124 A, SECTOR-2, NOIDA -201 301, UTTAR PRADESH, INDIA	Mr. Vijay Mohan Sood +(91)-(120)-2525694 +(91)-(120)-3052594 +(91)-(11)-23287156 vijay_mohansood@yahoo.com	
	CABLE GLANDS	2	E1017	ARUP ENGG & FOUNDRY WORKS	391/119,PRINCE ANWAR SHAH ROAD, CALCUTTA-700068	033 2473 0850	
	CABLE GLANDS	3	E1206	BALIGA LIGHTING EQPT.PVT.LTD.	63A,CP RAMASWAMY ROAD, ALWARPET,P.B.No 6910, CHENNAI-600018	44-24995505,22680990-4	
	CABLE GLANDS	4	E1036	COMMET BRASS PRODUCTS	NUTAN CHEMICAL COMPOUND, WALBHAT ROAD, GOREGAON, MUMBAI-400063	91-022-26852961/62/63 comet@vsnl.net	
	CABLE GLANDS	5	DW08	DOWELLS	M/S. DOWELLS ELECTRICALS 47/47A, SATGURU INDUSTRIAL ESTATE. OFF AAREY ROAD, GOREGOAN (EAST). MUMBAI 400 063.	CEO : Mr. Jayantibhai S. Patel TEL: 022-32504770./022-29270876/ 022-29270878.	

ITEM CODE	ITEM/SERVICE DESCRIPTION	SL NO.	VENDOR CODE	VENDOR NAME	ADDRESS	PHONE	REMARKS
	CABLE GLANDS	6	E1044	ELECTROMAC INDUSTRIES	27/28AF NEW EMPIRE IND.ESTT., R.KRISHNA MANDIR RD.JB NGR ,ANDHERI(E),MUMBAI-400059	91-22-28324829 / 66919034 devang@electromacglands.com	
	CABLE GLANDS	7	I01	INCAB	HARE STREET,KOLKATA,WEST BENGAL-700001	91-33-2480161/62/63/64 Fax : 91-33-2485766	
ES12	CABLE LUGS	1	E1040	DOWELLS	M/S. DOWELLS ELECTRICALS 47/47A, SATGURU INDUSTRIAL ESTATE. OFF AAREY ROAD, GOREGOAN (EAST).	CEO : Mr. Jayantibhai S. Patel TEL: 022-32504770./022-29270876/ 033 2282 2540	
	CABLE LUGS	2	E1149	UNIVERSAL MACHINES LTD.	4,B.B.D.BAG (EAST) 90,STEPHEN HOUSE,5TH FLR CALCUTTA-700001		
ES13	D.C. MCCB	1	C02	CROMPTON GREAVES	RAIL TRANSPORTATION SYSTEMS,VANDANA BUILDING, 11, TOLSTOY MARG, TOLSTOY MARG, NEW DELHI, DL 110001	011 3041 6300	
	D.C. MCCB	2	L01	L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015	011-41419554/59	
	D.C. MCCB	3	A35	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL,	044-49681447	
	D.C. MCCB	4	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 amit.bhadauria@siemens.com	
ES14	EARTH LEAKAGE CB	1	L01	L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015	011-41419554/59	
	EARTH LEAKAGE CB	2	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 amit.bhadauria@siemens.com	
	EARTH LEAKAGE CB	3	A35	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032	044-49681447	
	EARTH LEAKAGE CB	4	S03	SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	
	EARTH LEAKAGE CB	5	C01	C&S ELECTRIC LTD.	222, OKHLA IND. ESTATE, PH-III, NEW DELHI-110020	011-3088 7520-29	
	EARTH LEAKAGE CB	6	A24	ABB	14, MATHURA ROAD, FARIDABAD, HARYANA-121003	0129-2567580, 09871799449	
	EARTH LEAKAGE CB	7	E1068	INDO ASIAN	B-24, PHASE - II , NOIDA - 201305, U.P.	120-3042222	
	EARTH LEAKAGE CB	8	E1088	MDS SWITCHGEAR LTD	314-317SHAH NAHAR ESTATE	011 - 25793021	
	EARTH LEAKAGE CB	9	E1120	S&S POWER SWITCHGEAR LTD,	NEW NO. 67, OLD NO. 19, DR. RANGA ROAD, MYLAPORE, CHENNAI - 600004	044 - 24988056, 044 - 24988057, 044 - 24988058	
ES20	DC CONTACTORS	1	S03	SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	
	DC CONTACTORS	2	E1030	BHEL (BHOPAL)	HEAVY ELECTRICAL PLANT		
	DC CONTACTORS	3	E1044	ELECTROMAC INDUSTRIES	27/28AF NEW EMPIRE IND.ESTT., R.KRISHNA MANDIR RD.JB NGR ,ANDHERI(E),MUMBAI-400059	91-22-28324829 / 66919034 devang@electromacglands.com	
	DC CONTACTORS	4	L01	L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015	011-41419554/59	
	DC CONTACTORS	5	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 amit.bhadauria@siemens.com	
	DC CONTACTORS	6	E1144	TELEMECHANIQUE/ SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	TAKEN OVER BY SCHNEIDER
	DC CONTACTORS	7	A35	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032	044-49681447	
ES21	CONTROL SWITCHES/ SELECTOR SWITCH	1	E1076	KAYCEE	KAYCEE INDUSTRIES LTD., C/O-CMS COMPUTERS LTD., 35A, REAR BLDG., KILOKARI, NEW DELHI-110014	Rajiv Sharma-9312004687	
	CONTROL SWITCHES/ SELECTOR SWITCH	2	A35	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032	044-49681447	
	CONTROL SWITCHES/ SELECTOR SWITCH	3	G01	ALSTOM LTD	A-7, SEC-65, NOIDA	0120-479000	
	CONTROL SWITCHES/ SELECTOR SWITCH	4	S03	SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	
	CONTROL SWITCHES/ SELECTOR SWITCH	5	SRC01	M/s Shrenik & Co.	39A/3, PANCHRATNA INDUSTRIAL ESTATE, SARKHEJ-BAVLA ROAD, CHANGODAR,		
	CONTROL SWITCHES/ SELECTOR SWITCH	6	RE05	RECOM PVT. LTD.	M/S RECOM PVT. LTD.,16A , 2ND FLOOR A, WING RAJ INDUSTRIAL COMPLEX, MILITARY	Mr. Chandrashekar Kamath (MD) : 09820249503	
ES25	DC SWITCH	1	A35	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032	044-49681447	
	DC SWITCH	2	E1076	KAYCEE	KAYCEE INDUSTRIES LTD., C/O-CMS COMPUTERS LTD., 35A, REAR BLDG., KILOKARI, NEW DELHI-110014	Rajiv Sharma-9312004687	
	DC SWITCH	3	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 amit.bhadauria@siemens.com	
ES26	DISTRIBUTION BOX	1	SRC01	M/S SHRENIK & CO.	39A/3, PANCHRATNA INDUSTRIAL ESTATE, SARKHEJ-BAVLA ROAD, CHANGODAR, AHMEDABAD – 382 213		
	FUSE BASE	1	E1068	INDO ASIAN	B-24, PHASE - II , NOIDA - 201305, U.P.	120-3042222	

ITEM CODE	ITEM/SERVICE DESCRIPTION	SL NO.	VENDOR CODE	VENDOR NAME	ADDRESS	PHONE	REMARKS
ES28	FUSE BASE	2	G01	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032	044-49681447	
	FUSE BASE	3	L01	L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015	011-41419554/59	
	FUSE BASE	4	C01	C&S ELECTRIC LTD.	222, OKHLA IND. ESTATE, PH-III, NEW DELHI-110020	011-3088 7520-29	
	FUSE BASE	5	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 ;amit.bhadoria@siemens.com	
	FUSE BASE	6	A24	ABB	14, MATHURA ROAD, FARIDABAD, HARYANA-121003	0129-2567580, 09871799449	
	FUSE BASE	7	S02	SPACEAGE SWITCHGEARS LTD.	68 & 13-A INDUSTRIAL DEVELOPMENT COLONY, MEHRAULI ROAD GURGAON, HARYANA-122001	0124-2302711, 4085091	
	FUSE BASE	8	S03	SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	
	FUSE BASE	9	G01	ALSTOM LTD	A-7, SEC-65, NOIDA	0120-479 0000	
	FUSE BASE	10	E1050	ESSEN DEINKI	FLAT NO. 502, SKYLINE HOUSE 85, NEHRU PLACE NEW DELHI	011-26217060	
ES29	HRC FUSES	1	E1068	INDO ASIAN	B-24, PHASE - II , NOIDA - 201305, U.P.	120-3042222	
	HRC FUSES	2	G01	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032	044-49681447	
	HRC FUSES	3	L01	L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015	011-41419554/59	
	HRC FUSES	4	C01	C&S ELECTRIC LTD.	222, OKHLA IND. ESTATE, PH-III, NEW DELHI-110020	011-3088 7520-29	
	HRC FUSES	5	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 ;amit.bhadoria@siemens.com	
	HRC FUSES	6	A24	ABB	14, MATHURA ROAD, FARIDABAD, HARYANA-121003	0129-2567580, 09871799449	
	HRC FUSES	7	S02	SPACEAGE SWITCHGEARS LTD.	68 & 13-A INDUSTRIAL DEVELOPMENT COLONY, MEHRAULI ROAD GURGAON, HARYANA-122001	0124-2302711, 4085091	
	HRC FUSES	8	S03	SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	
	HRC FUSES	9	G01	ALSTOM LTD	A-7, SEC-65, NOIDA	0120-479 0000	
	HRC FUSES	10	E1050	ESSEN DEINKI	FLAT NO. 502, SKYLINE HOUSE 85, NEHRU PLACE NEW DELHI	011-26217060	
ES31	GI WIRE & FLAT	1	I039	INDUSTRIAL PERFORATION (I) PVT.LTD.	MR. A. K. SAHA 327, R.N.GUHA ROAD, DUM DUM KOLKATA-West Bengal-India Phone- 9830241788 Pincode : 700028 Email : jpipl@cal2.vsnl.net.in	011 2737 3579	
	GI WIRE & FLAT	2	I070	INDIA ELECTRICALS SYNDICATE	Mr. Suresh Kumar Agarwal 55, Ezra Street, Kolkata-West Bengal-India Phone- 033-22354047 Pincode : 700001 Email : cabletray@vsnl.com	022-28511704	
	GI WIRE & FLAT	3	I072	INDMARK FORMTECH PVT. LTD.	Mr. Narendra R. Meher J Block, Plot No.-375, MIDC BHOSARI PUNE-MAHARASHTRA-INDIA Phone- 020-27130546 Pincode : 411026 Email : indmarkformtech@vsnl.net		
	GI WIRE & FLAT	4	P039	PREMIER POWER PRODUCTS (CAL) PVT. LTD.	Chatterjee International Centre, 33A, Jawaharlal Nehru Road, 6th Floor, Suit No. - 11A, Kolkata,- West Bengal-India Phone- 9331008739 Pincode : 700071 Email : hemantdaga@dagaventures.com		
	GI WIRE & FLAT	5	P050	PATNY SYSTEMS (P) LTD	PATNY PLAZA 160 , SARDAR PATEL ROAD SEUNDRABAD SECUNDRABAD-TELANGANA-INDIA Phone- 040-27902451 Pincode : 500003 Email : mr.mkt@patnysystems.com		
	GI WIRE & FLAT	6	P079	PASSIVE INFRA PROJECTS PVT. LTD.	MR. VARUN AGRAWAL 182, VAISHALI, PITAMPURA Delhi-DELHI-INDIA Phone- 9871183059 Pincode : 110088 Email : ATANU.SAHA@PASSIVEINFRA.COM		
	GI WIRE & FLAT	7	R036	RUKMANI ELECTRICAL & COMPONENTS PVT LTD	11A , MAHARISHI DEBENDRA ROAD 1ST FL , ROOM NO.4 KOLKATA-WEST BENGAL-INDIA Phone- Pincode : 700007 Email : maruthikabra@gmail.com		
	GI WIRE & FLAT	8	R037	RATAN PROJECTS & ENGINEERING CO. PVT.LTD.	MR. G.D. SINGHEE/MR. MAHESH SINGHEE 26, P.K. TAGORE STREET, MAIN BUILDING KOLKATA-WEST BENGAL-INDIA Phone- 9830177331 Pincode : 700006 Email : mahesh@ratans.com		

ITEM CODE	ITEM/SERVICE DESCRIPTION	SL NO.	VENDOR CODE	VENDOR NAME	ADDRESS	PHONE	REMARKS
	GI WIRE & FLAT	9	R041	RABI ENGINEERING WORKS PVT. LTD.	MR. TAPAN KUMAR SEN/MR. SIDDHARTHA 327, R.N. GUHA ROAD, DUM DUM, KOLKATA-WEST BENGAL-INDIA Phone- 9748753002 Pincode : 700028 Email : rabiengineering@gmail.com		
	GI WIRE & FLAT	10	R200	RAJASTHAN METAL SMELTING CO.	Mr. R. K. Tibrewala D-80, Road No. 7, V.K.I.A., Jaipur-Rajasthan-India Phone- 0141-2332269 Pincode : 302013 Email : info@rmscoindia.com		
	GI WIRE & FLAT	11	S210	SARAL INDUSTRIES	Mr. Y.K. Gupta L-1, L-2, Industrial Area-1 Sultanpur Road Rae Bareilly-Uttar Pradesh-India Phone- 0535-2702474 Pincode : 229010 Email : saralindustries@gmail.com		
	GI WIRE & FLAT	12		PARCO Engineers Pvt. Ltd.	401, skyline Epitom Building ,Near to Jolly Gym Khana, Kirol Road , Vidhyavihar, MH 400086 India		
	GI WIRE & FLAT	13	U019	UNITECH FABRICATORS and ENGINEERS PVT LTD	INDRAPRASHTHA APARTMENT 24 , M.B.RAOD , BIRATI KALABAGAN KOLKATA KOLKATA-WEST BENGAL-INDIA Phone- Pincode : 700051 Email : ufepl@vsnl.net; ufepl@rediffmail.com	022 - 26230814	
ES35	INDICATING LAMPS	1	B04	BCH	20/4, MATHURA ROAD, FARIDABAD, HARYANA-121006	0129-4293000	
	INDICATING LAMPS	2	C01	C&S ELECTRIC LTD.	222, OKHLA IND. ESTATE, PH-III, NEW DELHI-110020	6832259,6918834-37	
	INDICATING LAMPS	3	E1050	ESSEN DEINKI	FLAT NO. 502, SKYLINE HOUSE 85, NEHRU PLACE NEW DELHI	011-26217060	
	INDICATING LAMPS	4	E1153	VAISHNO(HOTLINE SWGR.& CONTROL)	G-19, SECTOR - 11, NOIDA - 201301, UTTAR PRADESH, INDIA	8377805157 9818338922	
	INDICATING LAMPS	5	A35	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032	9818338922	
	INDICATING LAMPS	6	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 amit.bhadoria@siemens.com	
	INDICATING LAMPS	7	S03	SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	
ES45	LIGHTING SWITCH , SOCKET & S/F UNIT	1	F04	ELEXPRO ELECTRICALS PVT/ LTD.	C 1/27 & 37 GIDC KABILPORE NAVSARI-396424	02637-265140, Mr. Jssk kumar	
	LIGHTING SWITCH , SOCKET & S/F UNIT	2	E1012	ANCHOR	STEEL HOUSE, B WING, PLOT NO. 24, MAHAL INDUSTRIAL ESTATE, MAHAKALI CAVES ROAD, NEAR PAPER BOX, ANDHERI (E), MUMBAI, MAHARASHTRA - 400093	022-30418888.	
	LIGHTING SWITCH , SOCKET & S/F UNIT	3	E1076	KAYCEE	KAYCEE INDUSTRIES LTD., C/O-CMS COMPUTERS LTD., 35A, REAR BLDG., KILOKARI, NEW DELHI-110014	Rajiv Sharma-9312004687	
	LIGHTING SWITCH , SOCKET & S/F UNIT	4	L01	L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015	011-41419554/59	
	LIGHTING SWITCH , SOCKET & S/F UNIT	5	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 amit.bhadoria@siemens.com	
	LIGHTING SWITCH , SOCKET & S/F UNIT	6	E1068	INDO ASIAN	B-24, PHASE - II , NOIDA - 201305, U.P.	120-3042222	
ES51	MCB	1	E1088	MDS SWITCHGEAR LTD	314-317SHAH NAHAR ESTATE	011 - 25793021	
	MCB	2	E1068	INDO ASIAN	B-24, PHASE - II , NOIDA - 201305, U.P.	120-3042222	
	MCB	3	S03	SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	
	MCB	4	E1120	S&S POWER SWITCHGEAR LTD,	NEW NO. 67, OLD NO. 19, DR. RANGA ROAD, MYLAPORE, CHENNAI - 600004	044 - 24988056, 044 - 24988057, 044 - 24988058	
ES61	SWITCH BOX	1	E1012	ANCHOR	STEEL HOUSE, B WING, PLOT NO. 24, MAHAL INDUSTRIAL ESTATE, MAHAKALI CAVES ROAD, NEAR PAPER BOX, ANDHERI (E), MUMBAI, MAHARASHTRA - 400093	022-30418888.	
	SWITCH BOX	2	F04	ELEXPRO ELECTRICALS PVT/ LTD.	C 1/27 & 37 GIDC KABILPORE NAVSARI-396424	02637-265140, Mr. Jssk kumar	
	SWITCH BOX	3	B05	BAJAJ ELECTRICALS	BAJAJ ELECTRICALS LTD. ENGINEERING & PROJECTS BU (NORTH) 3rd FLOOR, GULMOHARHOUSE, COMMUNITY CENTRE 161/B-4, GAUTAM NAGAR, YUSUF SARAI NEW DELHI – 110049	CONTACT PERSON : Mr. S. SREEMANY. SR. MANAGER (PROJECTS) CONTACT DETAILS : (+91) 9871025705. MAIL ID : srabans@bajajelectricals.com;	
	SWITCH BOX	4	A03	AJMERIA INDUSTRIES & ENGG. WORKS	AJMERIA INDL. AND ENGG. WORKS. AJMERIA HOUSE, A-61 / KHAIRANE MIDC. , TTC INDL. AREA, NAVI MUMBAI – 400705.	Tel : 022 27620299 / 97 / 96 'mail@ajmera.net	
	SWITCH BOX	5	SB02	S.B. ELECTRICAL ENGINEERING CORPORATION	03, SARDAR GRIHA BUILDING, LOHAR CHAWAL, MUMBAI-400002	022- 22069831; 022-66637259	
	TERMINAL BLOCKS	1	C01	WAGO-CONTROLS	C 27, GREATER NOIDA, SECTOR 58, C BLOCK, SECTOR 58, NOIDA, UTTAR PRADESH 201307	0120-2580409/10	
	TERMINAL BLOCKS	2	E1038	CONNECT WELL	309A/4, 3RD FLOOR, KALKAJI, OKHLA IND AREA PH-2, GOVINDPURI, NEW DELHI, DL 110019	9811881085 09871419996 011-65908877	

ITEM CODE	ITEM/SERVICE DESCRIPTION	SL NO.	VENDOR CODE	VENDOR NAME	ADDRESS	PHONE	REMARKS
ES62	TERMINAL BLOCKS	3	E1047	ELMEX CONTROLS PVT. LTD.	12,G.I.D.C.ESTATE,MUKARPURA ROAD,VADODARA-390010	9374631074	
	TERMINAL BLOCKS	4	E1050	ESSEN DEINKI	FLAT NO. 502, SKYLINE HOUSE 85, NEHRU PLACE NEW DELHI	011-26217060	
	TERMINAL BLOCKS	5	E1142	TECHNOPLAST	OPP.I.M.INTER COLLEGE, BEGUM SARAI KHURD ROAD, AMROHA - 244221, U.P.	PH:- 05922 264006 CELL NO:- 9012676000, 9319520799, 9319582467	
	TERMINAL BLOCKS	6	PME-01	M/s PHOENIX MECANO LTD.,	388 BHARE, TALUKA MULSHI, POST GHOTAWADE, PIRANGOOT, INDUSTRIAL AREA, PUNE-412115	TEL:- +912066745000 Awasthi(09971119006) Tel: ++91 20 6674 5103, Mobile: +91 90499 95985, Fax: ++91 20 6674 5126 contact person : Vishwa bandhu E-mail:d.gupta@pmipl-online.com ;admin@pmipl-online.com	
	TERMINAL BLOCKS	7	E1050	ESSEN DEINKI	FLAT NO. 502, SKYLINE HOUSE 85, NEHRU PLACE NEW DELHI	011-26217060	
ES63	TIMERS - PNEUMATIC	1	B04	BCH	20/4, MATHURA ROAD, FARIDABAD, HARYANA-121006	0129-4293000	
	TIMERS - PNEUMATIC	2	G01	ALSTOM LTD	A-7, SEC-65, NOIDA	0120-479 0000	
	TIMERS - PNEUMATIC	3	L01	L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015	011-41419554/59	
	TIMERS - PNEUMATIC	4	E1144	TELEMECHANIQUE/ SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	TAKEN OVER BY SCHNEIDER
	TIMERS - PNEUMATIC	5	S03	SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	
	TIMERS - PNEUMATIC	6	E01	ELECTRONIC AUTOMATION PVT. LTD.	20, KHB INDUSTRIAL AREA YELAHANKA BANGLORE-560064	080 -28567561 / 080 -28567562 / 080 -42802345	
ES64	TIMERS - ELECTRONIC	1	E1050	ESSEN DEINKI	FLAT NO. 502, SKYLINE HOUSE 85, NEHRU PLACE NEW DELHI	011-26217060	
ES65	TRANSDUCERS	1	E1021	AUTOMATIC ELECTRIC LTD.	ADDRESS : 96 AB LONAVLA INDUSTRIAL ESTATE NANGARGAON, LONAVLA-410401	Phone : +91 2114323665 Fax : +91 2114273482	
	TRANSDUCERS	2	E1202	SOUTHERN TRANSDUCERS	INTERTECH B-83, FLATTED FACTORY COMPLEX, NEAR MODI MILLS, OKHLA, NEW DELHI-110020	Mr. Gurmohit Singh 011-41020365 / 9891402128	
ES79	RCCB	1	C01	C&S ELECTRIC LTD.	222, OKHLA IND. ESTATE, PH-III, NEW DELHI-110020	011-3088 7520-29	
	RCCB	2	S03	SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002	0124-3940400	
	RCCB	3	S01	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA	0124-2842000, 9873424331 amit.bhadauria@siemens.com	
	RCCB	4	A35	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032	044-49681447	
	RCCB	5	L01	L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015	011-41419554/59	
	RCCB	6	C02	CROMPTON GREAVES	RAIL TRANSPORTATION SYSTEMS,VANDANA BUILDING, 11, TOLSTOY MARG, TOLSTOY MARG, NEW DELHI, DL 110001	011 3041 6300	
ES80	PVC WIRES	BIS APPROVED MAKE					
ES86	PHOTOELECTRIC SWITCH	REPUTED MAKE					

NOTE: Make of all the equipment / instrument under this specification shall be subjected to owner's approval in the event of order. Owner reserves the right to accept/ reject any make or sub-vendor and to add new sub-vendors for the project after award of contract. Approval, rejection or addition of makes shall not have any price implication to the owner after award of contract.



TECHNICAL SPECIFICATION FOR LIGHTING PANELS

2 x 660MW UDANGUDI STPP

SPECIFICATION NO. PE-TS-435-558-E005A

VOLUME II

SECTION - II

REV. 00

DATE: 18.11.2024

SHEET 1 OF 4

DATA SHEET –C

S. No.	Description	Unit	Value
1.0	SYSTEM DESIGN DATA		
1.1	Design ambient	°C	
1.2	AC Supply		
a)	Rated voltage	V	
b)	Rated frequency	Hz	
c)	Voltage variation (permissible)	%	
d)	Frequency variation (permissible)	%	
e)	Combined voltage & frequency variation (sum of absolutes permissible)	%	
f)	System fault level & duration	kA, sec.	
1.3	DC Supply		
a)	Rated voltage	V	
b)	Voltage variation (permissible)	%	
c)	System fault level & duration	kA, sec.	
2.0	APPLICABLE STANDARDS		
	IS 60947	Low voltage switchgear and controlgear	
	IS 13703	Low voltage fuses for voltages not exceeding 1000V AC or 1500 V	
	IS 10118	Code of practice for selection, installation and maintenance of switchgear and controlgear	
	IS 60898	Electrical Accessories - circuit breakers for over protection for household and similar installations	
	IS 1901	Visual indicator lamps	
	IS:2551	Danger notice plates	
3.0			
3.1	Application		
3.2	Type of sheet steel		
3.3	Sheet metal thickness (minimum)		
3.4	Degree of Protection		



TECHNICAL SPECIFICATION FOR LIGHTING PANELS

2 x 660MW UDANGUDI STPP

SPECIFICATION NO. PE-TS-435-558-E005A

VOLUME II

SECTION - II

REV. 00

DATE: 18.11.2024

SHEET 2 OF 4

a)	Indoor panel		
b)	Outdoor panel		
c)	Canopy in outdoor panel		
3.5	Bus bar material		
3.6	Earth bus bar required		
3.7	Earth bus bar material (if applicable)		
3.8	Gland Plate	mm	
3.9	Earthing studs required		
3.10	Hinged door with locking facility		
3.11	AC Lighting Panel		
a)	Incomer rating	A	
b)	Type of Incomer		
c)	Earth Leakage Circuit Breaker (ELCB) in incomer required		
d)	Type of Outgoing Feeders		
e)	Outgoing feeders rating	A	
3.12	DC Lighting Panel		
a)	Incomer rating	A	
b)	Type of Incomer		
c)	Type of Outgoing Feeders		
d)	Outgoing feeders rating	A	
4.0	COMPONENTS OF LIGHTING SYSTEM EQUIPMENT		
4.1	Miniature Circuit Breaker		
a)	SPN MCB rating (min)	A	
b)	DP MCB rating (min)	A	
c)	TPN MCB rating (min)	A	
d)	Short time rating	kA	



TECHNICAL SPECIFICATION FOR LIGHTING PANELS

2 x 660MW UDANGUDI STPP

SPECIFICATION NO. PE-TS-435-558-E005A

VOLUME II


SECTION - II

REV. 00

DATE: 18.11.2024

SHEET 3 OF 4

e)	Magnetic short circuit protection required		
f)	Thermal overload protection required		
4.2	Power Contactors		
a)	Coil voltage (nominal)		
	AC contactors	V	
	DC contactors	V	
b)	Current rating of contacts		
	Power	A	
	Control	A	
4.3	Timer		
4.3.1	Time switch		
a)	Type		
b)	Range	hr	
c)	Coil voltage rating	V	
4.4	Selector switch		
a)	Type of selector switch		
b)	Lockable		
4.5	Indicating Lamps		
a)	Lens Colour		
	ON condition		
	OFF condition		
b)	Circuit voltage	V	
4.6	Cable Glands		
a)	Type		
b)	Material		
c)	Nickel Plating provided		

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-TS-435-558-E005A	
		VOLUME II	
		SECTION - II	
	2 x 660MW UDANGUDI STPP	REV. 00	DATE: 18.11.2024
		SHEET 4 OF 4	

4.7	Cable Lugs		
a)	Type		
b)	Material		
5.0	PAINTING		
5.1	Paint shade		
a)	LDBs		
b)	LPs		
5.2	Paint Finish		
a)	Interior		
b)	Exterior		
5.3	Paint Thickness	Microns	

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-SS-999-558-E005A	
		VOLUME II	
		SECTION II	
		REVISION: 00	DATE: 18.11.2024
		SHEET 1 OF 11	

SECTION – II

STANDARD TECHNICAL REQUIREMENTS

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-SS-999-558-E005A	
		VOLUME II	
		SECTION II	
		REVISION: 00	DATE: 18.11.2024
		SHEET 2 OF 11	

1.0 INTENT OF SPECIFICATION

- 1.1 The requirements given in specification shall be fully complied with.
- 1.2 The “design” shall broadly cover the selection of components, materials, sizes etc. for the equipment of supply in vendor’s scope. Complete responsibility of establishing the correctness of equipment design rests with the vendor.
- 1.3 It is not the intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respects to high standards of design, engineering and workmanship, and shall be capable of performing required function in a manner acceptable to Purchaser, who will interpret the meaning of drawings and specifications and shall be entitled to reject any work or material, which in his judgement is not in full accordance herewith.
- 1.4 Make of all equipment and components shall be to the approval of Purchaser.

2.0 CODES & STANDARDS

- 2.1 The material shall comply with all currently applicable safety codes and statutory regulations of India as well as of the locality where the material is to be installed.
- 2.2 The material, construction, manufacture, inspection and testing shall conform to the latest revisions of standards as specified in Data Sheet A.
- 2.3 In case of conflict between the applicable reference standard and this specification, stringent requirement shall govern.

3.0 DESIGN REQUIREMENTS

3.1 LIGHTING PANELS (LPs)

3.1.1 General Requirements of Lighting Panels

- a) LPs shall be totally enclosed, suitable for electrical system data as specified in Data Sheet A. The LP shall be suitable for mounting on wall / column / structure.
- b) Panels shall be suitable for outdoor application as per Data Sheet A.
- c) All components of the LP shall be fully mounted inside the panel. LPs shall have only one operational front. Door shall be provided to give full access to all the components. Door shall have padlocking arrangement.
- d) LPs shall consist of dust and vermin proof cubicles without the use of louvers.
- e) Good quality synthetic rubber / neoprene gaskets shall be put around the door. The door when closed, shall compress the gasket uniformly.

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-SS-999-558-E005A	
		VOLUME II	
		SECTION II	
		REVISION: 00	DATE: 18.11.2024
		SHEET	3 OF 11

- f) The LPs shall be designed to prevent contact with live parts when the front door is open.
- g) All busbars (phase, neutral, positive, negative as applicable) within a panel shall be of the same size.
- h) All control wiring inside the panels shall be carried out with 1100 V grade, PVC insulated flexible copper wire of 2.5 sq. mm size.
- i) The rated continuous current of the equipment and components shall be as given in Datasheet-A. These ratings shall be obtained with the components mounted in their housing as in service without exceeding the permissible temperature rise.
- j) Each LP shall be fitted with M.S. mounting brackets.
- k) Panel shall be suitable for top / bottom cable / conduit entries. However, outdoor LPs shall have bottom cable / conduit entry. Removable undrilled gland plate of sheet steel shall be provided for entry of cables. Minimum thickness of gland plate shall be as per Data Sheet-A. The gland plate shall be of adequate size having knock-outs for requisite number cable connections. Gland plate shall be provided with gasket.
- l) The lighting panel shall be complete with copper busbars, and shall incorporate incomer and outgoing circuits as per Data Sheet-A. Number of outgoing circuits shall be as per BOQ.
- m) Each lighting panel shall be fitted with two GI earth studs located in accessible position on the outside of the panel on opposite sides.
- n) All metal parts of the panel except current carrying parts shall be bonded together electrically to the earthing stud.
- o) Each panel shall be fitted with phase barriers of fireproof insulating material in such a manner that it is not readily possible for personnel to touch the phase busbars. Insulating sheet shall be fitted around the MCBs such that only the surface and toggle of the MCBs are available on the front.
- p) The supply of cable lugs for power and control cable connections forms part of the supply of equipment.
- q) Each panel shall be provided with a circuit directory plate with inscriptions neatly typed and laminated, fitted on the inside of door.

3.1.2 Type of Lighting Panels

- a) LP-A (n) - AC Lighting Panel
- b) LP-D (n) - DC Lighting Panel

NOTE: (n) indicates number of outgoing circuits.

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-SS-999-558-E005A	
		VOLUME II	
		SECTION II	
		REVISION: 00	DATE: 18.11.2024
		SHEET 4 OF 11	

3.1.3 AC Lighting Panel (LP-A)

- LPs shall be provided with incomer and requisite number of outgoing circuits as per Data Sheet-A. Number of outgoing circuits shall be as per BOQ.
- Separate neutral shall be available at terminal block for each outgoing circuit.
- Construction of AC Normal and AC Emergency panels shall be same.

3.1.4 DC Lighting Panels (LP-D)

- LPs shall be provided with incomer and requisite number of outgoing circuits as per Data Sheet-A. Number of outgoing circuits shall be as per BOQ.

4.0 COMPONENTS OF LDB/WDB AND LIGHTING PANEL

4.1 MINIATURE CIRCUIT BREAKERS

- The use of miniature circuit breakers (MCBs) combining thermal overload and magnetic short circuit protection shall be application for the outgoing circuits of Lighting Panels.
- MCBs shall have suitable rating as specified in Data Sheet A.
- MCBs shall be suitable for housing in the lighting panel and for connection of copper link bus bar at the incoming and copper lugs at the outgoing ends.
- The terminals of MCB and ON/OFF positions shall be clearly and indelibly marked.

4.2 CONTACTORS

- Contactors shall be of the air break type, electromagnetic type fitted with arc shields.
- The operating coil shall be suitable for satisfactory operation in the range of 85% - 110% of nominal voltage specified under the Data Sheet A. The coil shall be tropicalized having insulation not less than class 'E'.
- Electrically independent auxiliary contacts not less than 2NO + 2NC for interlocking and indication shall be fitted to individual power contactor.
- All springs shall be made out of a corrosion proof material.

4.3 RELAYS

- Relays shall be provided on the various circuits as per schemes. Relays shall be flush mounted on front of the board. Relay case shall be painted with dull black or egg shell black enamel and with back connected terminals. Metal cases and frames of relay shall be earthed.

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-SS-999-558-E005A	
		VOLUME II	
		SECTION II	
		REVISION: 00	DATE: 18.11.2024
		SHEET 5 OF 11	

- b) All relays shall be of withdrawable type with built-in testing facilities, with provision for inspection, maintenance and replacement. Where built-in test facility is not provided for a particular relay, separate suitable test block shall be provided on the board for this purpose.
- c) Relay performance shall not alter due to mechanical shock or vibration or external magnetic field which may be present at the place of mounting.
- d) Each relay shall not have less than two independent pairs of contacts.

4.4 TIMERS

4.4.1 Time Switch

- a) Time switch shall be suitable for automatic switching ON and OFF of street lighting / flood lighting circuits.
- b) Time switch have 00 - 24 hrs clock base.
- c) Time switch shall indicate actual time and shall permit accurate time setting.
- d) Time switch shall be rugged, independent of normal fluctuations of voltage / frequency and free from maintenance.
- e) Contact rating, clock accuracy, rated voltage rating and frequency rating of timer shall be suitable to its application.
- f) Time switch shall be provided with Ni-Cd battery.
- g) Time switch shall be suitable for mounting inside the panel.

4.4.2 On/Off Delay Timer

- a) On delay timer shall be required for continuation of DC supply for a limited duration when the AC Emergency supply has been restored and DG set is under stabilisation.
- b) Timer shall be fully static and suitable for operation on normal frequency and system voltage.
- c) Timer shall have high setting accuracy, high repeat accuracy, low reset time and low power consumption.
- d) Timer shall have the time setting range as mentioned in Data Sheet A.

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-SS-999-558-E005A	
		VOLUME II	
		SECTION II	
		REVISION: 00	DATE: 18.11.2024
		SHEET 6 OF 11	

e) Timer shall be suitable for mounting inside the panel.

4.5 SELECTOR SWITCHES

- a) The rating and other features of the switches shall be suitable for the application. The number of positions and the number of contacts required for each switch shall be as indicated in the schemes
- b) Selector switches shall be stay put type, provided with properly designated escutcheon plates clearly marked to show operating position.
- c) Terminals carrying potential above 120 Volts shall be shrouded to prevent accidental contact with personnel.
- d) Ammeter selector switches shall have make before break contacts.
- e) The switches shall be suitable for semi-flush mounting with the front plate and operating handle projecting out. All connection to the switches shall be from the back.
- f) The arrangement for front mounting of these devices shall be such as to make them reasonably dust free so as not to interfere with normal operation.

4.6 INDICATION LAMPS

- a) Indication lamps shall be complete with lens covers and holders.
- b) Each lamp shall be fitted with a durable resistance integrally wired in series with the lamp. Alternatively, lamps with built in transformers are acceptable.
- c) The lamp cover (lens) shall be translucent of appropriate colour.
- d) Bulbs and covers shall be interchangeable, easily replaceable from the front without the need for any special means.
- e) Terminals having potential above 120V shall be shrouded to prevent contact with personnel.
- f) Terminals shall be suitable for ring type copper cable lugs of size depending upon the circuit rating.

4.7 CABLE GLANDS

- a) Whether specifically mentioned or not, cable glands of suitable sizes shall be supplied along with each equipment for power and control cables.
- b) Rubber components used in the gland shall be of neoprene.
- c) Name / trade name of manufacturer, type no. and applicable range of outer diameter of cable shall be engraved / indelibly printed on the cable gland.

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-SS-999-558-E005A	
		VOLUME II	
		SECTION II	
		REVISION: 00	DATE: 18.11.2024
		SHEET 7 OF 11	

4.8 CABLE LUGS

- a) All equipment shall be supplied with the power and control cable lugs of suitable size, whether specifically mentioned or not.
- b) Name / trade name and size of lug shall be engraved/ indelibly printed on each cable lug.

4.9 TERMINALS

- a) Terminals shall be stud type of copper material.
- b) Terminals shall be provided with transparent cover(s).
- c) Separate terminals shall be available for each termination of loop-in and loop-out power connections.

5.0 LABELING

- 5.1 Labels to identify all the Main assemblies, Sub-assemblies and components of the LPs shall be provided.
- 5.2 Name and rating plate / marking shall be provided as required by relevant standard applicable to each component / assembly to be identified.
- 5.3 Labels shall be of two colour, three layer plastic material with matt or semi matt finish or of the anodised aluminium sheet.
- 5.4 All labels other than "Danger" or "Warning" labels shall have black lettering on a white background. Danger labels shall be as per applicable standard and shall not be affixed on to removable parts.
- 5.5 All labels shall be securely fixed on to the equipment by means of self tapping screws or other approved means.
- 5.6 Stick-on type labels of good quality and permanent mounting shall be acceptable for internally mounted components only.
- 5.7 A list of all such items to be labeled and text and type of labels to be provided is given below:

a) BOARD DESIGNATION (MAIN EQUIPMENT LABEL)

- i. **Inscription :**
Designation and LP number for LPs.
- ii. **Location :**
Top centre in the front of the LP.

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-SS-999-558-E005A	
		VOLUME II	
		SECTION II	
		REVISION: 00	DATE: 18.11.2024
		SHEET 8 OF 11	

iii. **Material :**

3 Layer plastic material, fixation by self tapping, non-rusting screws, black inscription on white back ground.

b) OUTGOING - FEEDER DESIGNATION

i. **Inscription :** Module number, LP number / purpose.

ii. **Material :**

Black engraving on white anodised aluminium plate of thickness 1.6 mm or more. Plate to be secured with screws.

c) COMPONENT DESIGNATION

i. **Inscription :** Letter symbol / Legend as assigned in schemes.

ii. **Location :** Near or on the component

iii. **Material :** Stick-on type

5.8 CIRCUIT DIAGRAM / DIRECTORY PLATE

- A diagram is to be prepared for fixing to the inside cover of every lighting panel giving details of the points controlled by each circuit.
- The circuit list shall be typed or printed stating the location of the equipment served, rating of the protective unit and the circuit loadings.
- The list shall be mounted on the inside of the cover door and shall be protected by an acrylic sheet cover to be easily removable to permit circuit modifications.

6.0 SURFACE TREATMENT

- All metal parts and the surfaces (exterior & interior) of equipment, unless stated otherwise in case of reflectors, shall be degreased by dipping in hot alkaline solution and rubbed with wire brush to remove oil & scale from them & then rinsed in water. Alternatively, they may be shot / sand blasted.
- Parts shall be pickled by dipping in hydrochloric acid tank to remove the rust from the surfaces formed during storage of sheets & then rinsed to remove traces of the acid. The cleaning and pretreatment of all metal parts shall be as per applicable standard.
- The surfaces to be painted shall then be prepared by phosphatizing to protect them from further rusting & to create a good bond with the paint. The pretreatment shall conform to the applicable standard.

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-SS-999-558-E005A	
		VOLUME II	
		SECTION II	
		REVISION: 00	DATE: 18.11.2024
		SHEET 9 OF 11	

- 6.4 All parts shall then be subjected to a coat of red oxide primer paint.
- 6.5 All inside and outside surfaces of panel shall be spray painted with synthetic enamel of the shade and minimum thickness as per Data Sheet A.
- 6.6 Electrostatic or powder painting shall be acceptable subject to purchaser's approval.
- 6.7 Wherever possible, finished parts shall be coated with peelable compound by spraying method to protect the finished product from scratches, grease, dirty and oily spots during handling and transportation.

7.0 PACKING

- 7.1 Packing procedure shall conform to the following:
- The equipment shall be properly packed before dispatch. The packing shall prevent damage to the contents while handling and lengthy period of outdoor storage.
 - The equipment shall be wrapped in weather proof packing using polythene sheets/ air bubble sheets/ thermocol sheets and then secured in wooden packing cases. Wood for wooden packing cases/ crates shall be chemically treated to prevent deterioration due to fungi and attack by termites, borers, and any other kind of infection.
 - The equipment shall be secured by fixing base plate/ frame with the help of bolt and nuts etc. to bottom frame of the wooden packing cases/ crates. Suitable cushioning material like rubberised coir (min. 50 mm thick & 100 mm wide) shall be provided on the bottom support. Gap between the panel and casing shall be filled with rubberised coir with distance between consecutive supports less than 500mm.
- 7.2 Specification for the sea worthy packing, if enclosed, for the export jobs shall form part of the specification.

8.0 INSPECTION & TESTING

- 8.1 Bidder shall confirm compliance with the BHEL Standard Quality Plan (PE-QP-999-558-E002) without any deviations. At contract stage, the successful bidder shall submit the same QP for BHEL/ ultimate customer's approval. In case bidder has reference QP agreed with ultimate customer, same can be submitted for specific project after award of contract for BHEL/ ultimate customer's approval. There shall be no commercial implication to BHEL on account of any changes in QP during contract stage.

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-SS-999-558-E005A	
		VOLUME II	
		SECTION II	
		REVISION: 00	DATE: 18.11.2024
		SHEET	10 OF 11

- 8.2 All the components and completely assembled equipment shall be tested as per the latest edition of standards. Charges for these tests shall be deemed to be included in equipment price.
- 8.3 All the specified type and routine tests shall be carried out to verify the rating and performance of the equipment. Where valid type test certificates in evidence of equipment performance claimed are available & approved by purchaser, the requirements for conducting type tests may be waived. The general arrangement of object under test shall be to purchaser's approval.
- 8.4 Functional testing shall be carried out for Lighting Panels.
- 8.5 All manufacturing processes viz. machining, sheet forming, electroplating, wire routing, cleating & crimping, assembly, surface preparation shall conform to good manufacturing practices.
- 8.6 Inspection for dimensional & visual checks especially of the following, with respect to contract drawings, documents & standards shall be conducted:
- General sturdiness & rigidity of equipment.
 - Surface finishing.
 - Gasketting.
 - Inter-changeability.
 - Constructional features viz. location, accessibility & marking of components, segregation, accessibility to live parts (shrouding) etc.
 - Completeness of scope.
- 8.7 Safety interlocking verification shall be done.
- 8.8 Equipment shall be liable for rejection if tolerances on the values of dimensions, power consumption, impedances, temperature rise etc. exceed the specified values by purchaser and / or standards.


9.0 TOOLS AND TACKLE

- 9.1 Tools & tackle which are essential to facilitate assembly, adjustments, erection, maintenance & dismantling of equipment shall be provided as part of equipment supplied.
- 9.2 The above tools shall be supplied along with the initial consignment of equipment so as to be available prior to erection but may not be used for erection purposes.
- 9.3 Vendor shall also submit a list of recommended tools and tackle. Acceptance of these tools and tackle shall not be a binding on the purchaser.
- 9.4 Schedule of tools & tackle shall be filled up by bidder.

	TECHNICAL SPECIFICATION FOR LIGHTING PANELS	SPECIFICATION NO. PE-SS-999-558-E005A	
		VOLUME II	
		SECTION II	
		REVISION: 00	DATE: 18.11.2024
		SHEET 11 OF 11	


10.0 SPARES

- 10.1 Mandatory spares (if applicable) are indicated in BOQ-cum-price schedule.
- 10.2 Erection & commissioning spares are included in the bidder’s scope of supply. Bidder to furnish list of E&C spares in the relevant schedules of the Bid Form and Price Schedules.

	MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS	STANDARD QUALITY PLAN		SPEC. NO :	DATE:
		CUSTOMER :		QP NO.: PE-QP-999-558-E002, R-2	DATE:
		PROJECT:		PO NO.:	DATE:
		ITEM: LIGHTING PANEL	SYSTEM:	SECTION:II	SHEET 1 OF 4

SL NO.	COMPONENT & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK		REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD		AGENCY			REMARKS
1	2	3	4	5	6		7	8	9	*	**			
					M	C/ N				D	M	C	N	
1.0	Raw Material	(a)Material (b)Thickness (c) Surface Finish (d) Chemical Composition	MA	V/M	100%	Sample	Manuf. Std./ Approved Document	Manuf. Std./ Approved Document	Test Certificate	√	P	V		
2.0		Verification of make, type, Size & rating of component like indicating lamps, PB's, contactors, relays, switches etc.	MA	Visual	100%	Sample	Approved drg. & Datasheet	Approved drg. & Datasheet	Test Certificate	√	P	V		Component to be of approved make.
LIGHTING PANELS														
3.0	Final Inspection	1.Dimensions	MA	Measurement	100%	10%	Approved drg./ Datasheet	Approved drg./ Datasheet	Insp. Report	√	P	W		
		2. Paint shade/ Paint Finish & thickness	MA	Visual/ measurement	100%	10%	Approved drg./ Datasheet	Approved drg./ Datasheet	Insp. Report	√	P	W		
		3. Verification of GA	CR	Visual	100%	100%	Approved drg.	Approved drg.	Insp. report	√	P	W		
		4. Verification of BOM	CR	Visual	100%	100%	Approved drg.	Approved drg.	Insp. report	√	P	W		
		5. Functional tests (incl. wiring cont.)	MA	Elect	100%	100%	Approved drg	Approved drg.	Insp. report	√	P	W		
		6.HV/ IR/ HV	MA	Elect	100%	100%	HV -2.5KV AC for 1 minute IR - >50 MOHM	HV -2.5KV AC FOR 1 MINUTE IR - >50 M OHM	Insp. report	√	P	W		

BHEL				BIDDER/ SUPPLIER		FOR CUSTOMER REVIEW & APPROVAL			
ENGINEERING		QUALITY		Sign & Date		Doc No:			
Prepared by:	Sign & Date	Name	Sign & Date	Name		Reviewed by:	Sign & Date	Name	Seal
Reviewed by:	Sign & Date	Name	Sign & Date	Name		Approved by:	Sign & Date	Name	Seal


	MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS	STANDARD QUALITY PLAN		SPEC. NO :	DATE:
		CUSTOMER :		QP NO.: PE-QP-999-558-E002, R-2	DATE:
		PROJECT:		PO NO.:	DATE:
		ITEM: LIGHTING PANEL	SYSTEM:	SECTION:II	SHEET 2 OF 4

SL.NO.	COMPONENT & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK		REFERENCE DOCUMENT	ACCEPTAN CE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
1	2	3	4	5	6		7	8	9	*	**		
					M	C/ N				D	M	C	N
		6. Degree of protection (including explosion proof if any)	MA	Scrutiny of type test certificates	1/rati ng	1/rati ng	IS 13947 or equivalent	IS 13947 or equivalent	Test certificate	√	P	V	
		7. Temperature rise test (for complete assembled LDB/ LP)	MA	Scrutiny of type test certificates	1/rati ng	1/rati ng	IS 8627 or equivalent	IS 8627 or equivalent	Test certificate	√	P	V	

BHEL					
ENGINEERING			QUALITY		
Prepared by:	Sign & Date	Name	Checked by:	Sign & Date	Name
Reviewed by:	19/03/2020	Devendra Singh	Reviewed by:	19/03/2020	Kusum Gautam
	19/03/2020	Praveen Dutta		19/03/2020	Ritesh Kumar Jaiswal

BIDDER/ SUPPLIER	
Sign & Date	
Seal	

FOR CUSTOMER REVIEW & APPROVAL			
Doc No:			
	Sign & Date	Name	Seal
Reviewed by:			
Approved by:			


	MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS	STANDARD QUALITY PLAN		SPEC. NO :		DATE:	
		CUSTOMER :		QP NO.: PE-QP-999-558-E002, R-2		DATE:	
		PROJECT:		PO NO.:		DATE:	
		ITEM: LIGHTING PANEL		SYSTEM:		SECTION:II	

		d) Z Volt/ Z Sckt	CR	Test	100%	100%	IS 11171 & Approved Datasheet	IS 11171 & Approved Datasheet	Insp. report	√	P	V		
--	--	-------------------	----	------	------	------	-------------------------------	-------------------------------	--------------	---	---	---	--	--

SL.NO.	COMPONENT & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK		REFERENCE DOCUMENT	ACCEPTANC E NORMS	FORMAT OF RECORD	AGENCY			REMARKS
1	2	3	4	5	6		7	8	9	*	**		
					M	C/ N				D	M	C	N





5.0	PACKING	As per BHEL Appd. Drg./Packing Procedure	MA	Visual	100%	100%	Appd. Packing Drg./ Packing procedure	As per Annexure -I	Insp. report	√	P	W	-	
-----	---------	--	----	--------	------	------	---------------------------------------	--------------------	--------------	---	---	---	---	--

BHEL						BIDDER/ SUPPLIER		FOR CUSTOMER REVIEW & APPROVAL			
ENGINEERING			QUALITY			Sign & Date		Doc No:			
Prepared by:	Sign & Date	Name	Checked by:	Sign & Date	Name	Seal		Reviewed by:	Sign & Date	Name	Seal
Reviewed by:	19.03.2020	Devendra Singh	Reviewed by:	19.03.2020	Kusum Gautam			Approved by:			
	19/3/2020	Praveen Dutta		19/3/2020	Ritesh Kumar Jaiswal						

	MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS	STANDARD QUALITY PLAN		SPEC. NO :	DATE:
		CUSTOMER :		QP NO.: PE-QP-999-558-E002, R-2	DATE:
		PROJECT:		PO NO.:	DATE:
		ITEM: LIGHTING PANEL	SYSTEM:	SECTION:II	SHEET 4 OF 4

NOTES: -	
(A)	THE INSPECTION SHALL BE CARRIED OUT ONCE FOR THE MATERIAL OFFERED FOR INSPECTION IN ONE LOT. FOR SUBSEQUENT LOTS AGAINST THE SAME PROJECT, THE MATERIAL CAN BE ACCEPTED BASED ON CERTIFICATE OF COMPLIANCE FURNISHED BY THE VENDOR.
(B)	BHEL RESERVES THE RIGHT FOR CONDUCTING REPEAT TEST, IF REQUIRED.
(C)	AFTER PACKING AND PRIOR TO ISSUE OF MDCC, PHOTOGRAPHS OF COMPLETE MATERIAL (TO BE DISPATCHED) SHALL BE SENT TO BHEL- PURCHASE GROUP FOR REVIEW.
(D)	ENGG. TO ENSURE THAT ALL CUSTOMER REQUIREMENTS HAVE BEEN TAKEN CARE OF IN QP & TECH. SPECIFICATION DURING ISSUE OF PURCHASE INDENT.
(E)	IN CASE THERE ARE ANY CHANGES IN QP COMMENTED BY CUSTOMER AT CONTRACT STAGE, THE SAME SHALL BE CARRIED OUT BY THE BIDDER WITHOUT ANY IMPLICATION TO BHEL/ CUSTOMER.
(F)	PROJECT SPECIFIC QP TO BE DEVELOPED BASED ON CUSTOMER REQUIREMENT.
(G)	FOR EXPORT JOB, PACKING SHALL BE AS PER BHEL SEAWORTHY PACKING SPECIFICATION.

LEGENDS:
 *RECORDS, IDENTIFIED WITH "TICK"(✓) SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION,
 ** M: SUPPLIER/ MANUFACTURER/ SUB-SUPPLIER, C: MAIN SUPPLIER/ BHEL/ THIRD PARTY INSPECTION AGENCY, N: CUSTOMER,
 P: PERFORM, W: WITNESS, V: VERIFICATION, AS APPROPRIATE
 MA: MAJOR, MI: MINOR, CR: CRITICAL

BHEL				BIDDER/ SUPPLIER		FOR CUSTOMER REVIEW & APPROVAL			
ENGINEERING		QUALITY		Sign & Date		Doc No:			
	Sign & Date	Name		Sign & Date	Name		Sign & Date	Name	Seal
Prepared by:		Devendra Singh	Checked by:		Kusum Gautam				
Reviewed by:		Praveen Dutta	Reviewed by:		Ritesh Kumar Jaiswal				

PACKING SPECIFICATION FOR LIGHTING PANELS

ANNEXURE-I

LIGHTING PANELS shall be despatched in “Crate Packing” using wood.

1.0 PREPARATION OF PACKING CASES:

1.1 DIMENSIONS:

- 1.1.1 Minimum number of planks shall be used for a shook.
- 1.1.2 Thickness of planks for Front, rear, top and bottom sides and binding, jointing battens shall be 25/20mm +2/-3 mm
- 1.1.3 Horizontal, vertical, diagonal planks shall be given for binding
- 1.1.4 Width of binding planks shall be minimum 100mm
- 1.1.5 Distance between any 2 binding planks shall be less than 750mm
- 1.1.6 Diagonal planks shall be used in between vertical binding planks when distance between inner to inner of vertical planks is more than 750mm
- 1.1.7 Distance of the outer edges of these planks from the edge of case shall be less than 250mm.
- 1.1.8 Diagonal planks are not required for top planks and width side, if the width of pallet is less than 750mm.

1.2 JOINTING OF PLANKS:

Single length planks shall be used for cubicles whose overall length is less than 2400 mm. For cubicles of length more than 2400 mm, jointing is permitted. The jointing shall be done with one single or maximum of 2 planks of wood same as other planks of width 250 mm (minimum) with two rows of nails on either side of the joint in zigzag manner. From the joint along height side, it shall be of lap joint with overlap of at least the width of plank.

1.3 PERMISSIBLE DEFECTS

Wood shall be free from knots, bows, visible sign of infection and any kind of decay caused by insects, fungus, etc.

End splits: Longest end splits at each end shall be measured and lengths added together. The added length shall not exceed 60mm per meter run of shook's. Wood pins shall be used to prevent further development of split.

Surface cracks: Surface cracks with a maximum depth of 3mm are permissible. A continuous crack of any depth all along the length is not allowed.

1.4 OTHER MATERIALS

1.4.1 NAILS

Nails of suitable dia and length shall be used for joining the planks.

1.4.2 BLUE NAILS

If applicable, these shall be used for nailing bituminized Kraft paper/hessian cloth to the planks.

1.4.3 HOOP IRON STRIPS

These are used for strapping the boxes. The material shall be free from rust. If sufficient nailing is done for bigger boxes, strapping need not be done.

PACKING SPECIFICATION FOR LIGHTING PANELS

1.4.4 CLIPS

These shall be used for strapping the hoop iron strips on the boxes.

1.4.5 BRACKETS

Brackets of suitable dimension shall be used for nailing to the corners of cubicle boxes. The brackets shall be of mild steel of suitable thickness. The brackets shall be of "L" shape. Two holes shall be provided towards the end of each side for screwing /nailing.

1.4.6 MULTI LAYERED CROSS LAMINATED POLYTHELENE FILM

Multi Layered Cross Laminated Polyethylene Film shall be used to make covers to the jobs individually. The cross lamination gives qualities of extra toughness, together with flexibility and lightness coupled with good weather resistance to ultra violet rays.

1.4.7 RUBBERISED COIR:

The rubberized coir is used as cushioning material. For the packing of loose items, items are to be arrested by using rubberized coir.

1.4.8 FASTENERS

Bolts, double nuts, spring washers will have to be used to hold the job to the bottom plank of the box so that there shall be no jerk on the LIGHTING PANELS during transit.

1.4.9 PACKING SLIP:

Packing slip kept in the polyethylene bag shall be placed in the box at appropriate place. In addition, one more packing slip covered in polyethylene cover and packing slip holder shall be nailed to front / rear of case.

1.4.10 MARKING PLATE:

Marking on the packing case shall be done as per the manufacturer standard.



**2 x 660 MW UDANGUDI STPP PROJECT
PRE-QUALIFICATION REQUIREMENTS
FOR DISTRIBUTION BOARDS**

PE-PQ-435-558-E005

REVISION NO. 00 DATE 10/12/2024

SHEET NO. 1 OF 1

ITEMS : LDBs/ WDBs/ Lighting Panels

SCOPE: Supply: YES; Erection & Commissioning: NO.

1	Vendor should be designer & manufacturer of Lighting Panels.
2	Availability of temperature rise and degree of protection test certificates conducted at independent lab or witnessed by third party for Lighting Panels.
3	Availability of test reports (witnessed by third party) to establish in-house capability to carry out all Functional tests, HV test, IR measurement as per relevant IS for Lighting Panels.
4	Option -1: One (1) no. performance certificates for min. two (2) years of trouble-free operation for Lighting panels. Performance certificate should be from end user only. Performance certificates should not be more than ten (10) years old from the date of techno- commercial bid opening. OR Option -2: Repeat order received from One (1) purchaser/end user for Lighting panels during last 10 years provided the gap between awards of two PO's is minimum 2 years.
5	Capacity of manufacturing 10 nos. Lighting Panels per month.
6	Manufactured and supplied at least 20 nos. lighting panels in one or more orders.
7	(Minimum 2 nos. purchase order for the Lighting Panels shall be submitted which should not be more than five (5) years old from the date of techno- commercial bid opening for establishing continuity in business.

Notes:-

1. The credentials for LP's should pertain to min 63A incomer rating.
2. In place of Lighting Panels, documents submitted for wall mounted electrical JB's & feeder pillars etc. (with min. rating 63A) shall also be considered.
3. Consideration of offer shall be subject to customer's approval of bidders, if applicable.
4. Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
5. Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder/collaborators to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
6. After satisfactory fulfillment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.

PREPARED BY:

Nidhi
10/12/2024

NAME: NIDHI RAWAT
DESIGNATION:
MANAGER

CHECKED BY:

Ayan
10.12.24

NAME: AYAN SAHA
DESIGNATION: DGM

REVIEWED BY:

Sandeep
10/12/2024

NAME: SANDEEP LODH
DESIGNATION: AGM

APPROVED BY:

Debasisa
10/12/24

NAME: DEBASISA RATH
DESIGNATION: GM (DH)