

Ventilation System Package for 2 X 660 MW Meja Thermal Power Project		
Tender Ref : 77/15/6097/ANA dtd. 07.08.2015		
Sl. No.	Bidder's Queries	BHEL-ISG Reply
1	In the given input specifications, Supply, E&C of cables, cable trays with all required accessories are in vendor scope, as these items have never been supplied by us to other ventilation packages.	Scope of electrics shall be as mentioned in our enquiry specification. We shall not accept any deviation. The scope of electrics mentioned is for the concerned package only.
2	In the given Price Format, Sl. No. III of B.2, DISTRIBUTION BOARDS, please clarify for which equipment, as per our equipment's the control panel section is covering the panels and components required, the LT panels section is not understandable as some of the components are duplicated and some of the components are not required, please clarify what to be filled .	Bidder shall fill only applicable spares items required for the respective equipments supplied by bidder.
3	Please send us the relevant layouts/drawings/data of positioning of fans, control panels and grids for earthing in different areas for enabling us to calculate the cabling, cabling trays, etc. BHEL has requested to provide a lump sum calculated amount in the price format for ventilation system for the same	• Please note the relevant layouts have been submitted along with the enquiry. Bidder shall locate the equipments related to ventilation package as per system requirement in line with layouts submitted. • Bidder shall note that Supply, laying and termination of cables (power /control/instrumentation) along with cable trays (which includes tray supports, accessories like glands, lugs etc) between <u>bidder supplied equipments</u> are in the scope of ventilation system supplier. • As already mentioned in the specification, Earthing for all equipments (which are supplied by bidder for this package) shall be in scope of bidder. Bidder shall connect the earthing to the to the nearest grid which is available in each floor of buildings/TP's. Nearest earth grid is supplied by BHEL in each floor of the building/TP's. • Bidder shall supply only applicable spares items required for the respective equipments supplied by bidder.