
	PRE-QUALIFYING REQUIREMENTS (TECHNICAL) – CONDENSER ONLOAD TUBE CLEANING SYSTEM (COLTCS)	DOCUMENT NO: PE-TS-426-165-N002
		REVISION NO: 00 DATE: 20/01/2021
		SHEET: 1 of 2
FORM NO. PEM 6100-0	ENQUIRY NO.: PE/PG/THD/E-6599/2020 DATED 05.02.2021	
	PROJECT: 2X660 MW KHURJA TG PKG	
	PACKAGE: COLTCS	
	<p>The bidder should have designed, manufactured, erected and commissioned COLTCS with ball collecting strainer having diameter of not less than 2100 mm, which is in successful operation in at least one (1) station for a minimum period of one (1) year prior to 17.09.2019 and bidder is in business of COLTCS on continuous basis.</p>	
	<p>1. The Bidders shall furnish following support documents for assessment of Bidder w.r.t. PQR as indicated at Sl. No. 1 above:</p> <p>A. Bidder's Experience list of COLTCS for last 5 years (as on the enquiry/NIT date) for assessment of bidder for supplying the COLTCS on regular basis for establishing business continuity in enclosed format- Annexure-1.</p> <p>Bidder shall furnish the PO copy of at least one executed Contract as indicated in the experience list.</p> <p>B. In support of successful performance of COLTCS for one year, bidder shall furnish Satisfactory Performance feedback certificates from End Customer (Owner) (in English) for at least one successfully executed contract which has been in use for at least One year prior to 17.09.2019, indicating salient features like year of commissioning of COLTCS, rating of project, Size of COLTCS, project name etc., date of issue of certificate and name/ designation of the certificate issuer for power plant/similar application industry.</p> <p>Notes:-</p> <p>N1 - Purchase order copy, supporting drgs/technical data sheets etc. are to be submitted along with the bid for which the bidder intends to furnish the performance feedbacks for reference purpose only.</p> <p>Any additional document required in support of above documents to establish the correlation between the above documents and the supplied item shall be provided by the bidder.</p>	
	2. Bidder to note that the arrangement of bidding (joint bid partners/ collaborator/ MOU partner/ licensing company etc.) once offered to BHEL as a part of bidding documents cannot be changed till the execution of the project.	
3. Purchase order for spare items shall not be considered as repeat order qualifying criteria.		
4. Consideration of offer shall be subject to customer's approval of bidders, if applicable.		
5. Bidder to submit all supporting documents in English, If documents submitted by bidder are in language other than English, a self-attested English translated		

PREPARED BY:	REVIEWED BY:	APPROVED BY:
NAME:	NAME:	NAME:
DESIGNATION / DEPT.:	DESIGNATION / DEPT.:	DESIGNATION / DEPT.:

	PRE-QUALIFYING REQUIREMENTS (TECHNICAL) – CONDENSER ONLOAD TUBE CLEANING SYSTEM (COLTCS)	DOCUMENT NO: PE-TS-426-165-N002
		REVISION NO: 00 DATE: 20/01/2021
		SHEET: 2 of 2

	document should also be submitted.
	6. Vendor may also qualify based on the credential of principal meeting package specific qualifying requirements having technical valid collaboration/licensing agreement/MOU/Indian subsidiaries.
	7. Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder/collaborators to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
	8. After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.

PREPARED BY:	REVIEWED BY:	APPROVED BY:
NAME:	NAME:	NAME:
DESIGNATION / DEPT.:	DESIGNATION / DEPT.:	DESIGNATION / DEPT.:

EXPERIENCE LIST**EQUIPMENT/PACAKAGES :** COLTCS**Vendor :**

SL. NO.	PROJECT	CUSTOMER/ CONSULTANTS	YEAR OF SUPPLY	SIZE (MM)	CAPACITY (Cub. M/ Hr)	QTY	MATERIAL OF CONSTRUCTION (HOUSING/STRAINER ELEMENT)	QUALITY OF WATER HANDLED	Performance feedback certificate from end user (enclosed/not enclosed)	

COMPANY SEAL

FORMAT FOR FILLING THE DETAILS OF PROVENNESS

* Bidder to strike out whichever is not applicable

S. No.	Item Description	Installation-1
I.	CONDENSER ON LOAD TUBE CLEANING SYSTEM (COLTCS) (Refer Cl. 5.0 (iii), sub-section-A-1, Part-A, Section-VI of Bid Documents)	
1.01.00	Name, Address, Telephone No. manufacturer	
1.02.00	Name of the Station and its Location	
1.03.00	Client Name and its Address, Fax No. & Tel. Nos.	
1.04.00	Name and Designation of the responsible person in Client's Organisation	
1.05.00	Contract No. & Date	
1.06.00	Capacity in MW of Unit and No. of Units	
1.07.00	Starting Date of Work/ Date of Order	
1.08.00	Scheduled Date of Completion	
1.09.00	Actual Date of Completion	
1.10.00	Date of Commissioning of System/Package	
1.11.00	(a) Whether the System/Equipments are in Successful Operation for a minimum period of one (1) year prior to the date of techno- commercial bid opening	Yes/No
	(b) Whether the system/equipments are in successful operation as on the date of techno-commercial bid opening	Yes/No
1.12.00	Date of Commencement of Successful	

FORMAT FOR FILLING THE DETAILS OF PROVENNESS

Operation

1.13.00 Brief Scope of Work

S. No.	Item Description	Installation-1
1.14.11	Brief Technical Particulars of the System/Package/Equipments :	
	(i) Designed by	
	(ii) Manufactured by	
	(iii) Erected by	
	(iv) Commissioned by	
	(v) C.W Flow through Condenser (cum/hr.)	
	(vi) No. of Balls per Charge	
	(vii) Whether separate system provided for each Condenser Half	
	(viii) Method of Ball Sorting	
	(ix) Ball Collecting Strainer diameter (mm)	
	(x) Make	