



Ref: E-5820/2017/CORRIGENDUM-1

Date: 05/01/2018

DUE DATE
15/01/2018
10:00 HRS (IST)

Our Ref:

- (i) Enq No.: E-5820/2017 dated 03/01/2018
- (ii) Project Name: 2X660 MW ENNORE SEZ TPP
- (iii) Package Name: AUX. PRDS

Subject: Corrigenda regarding amendment No.-01 to APRDS technical specification (PE-TS – 412-142-N101).

Dear All,

Corrigendum – 1 issued due to amendment No.-01 to APRDS technical specification no. PE-TS –412-142-N101. Amendment No.-01 to APRDS technical specification are appended below.

Kindly submit your best offer before due date and time by considering all corrigendum.

Thanking You

With regards
For & on behalf of BHEL

Santosh 05/01/18
(SANTOSH KUMAR VERMA)
DY. MANAGER/ PG-IV
PEM, BHEL, Noida

कृपया प्रेषित करें :	Please reply to :	फ़ोन Phone No:
बीएचईएल, पीएस-पीईएम	BHEL, PS-PEM,	91-120 – 436 8536
पीपीआई भवन	PPEI Building,	
प्लॉट नं २५, सेक्टर १६ ए	Plot No.25, Sector 16A,	
नोएडा - २०१ ३०१ उ प्र	Noida-201301 (U.P.)	
भारत	INDIA	

पंजीकृत कार्यालय	Registered Office :
बीएचईएल हाउस	BHEL House,
सीरी फोर्ट	Siri Fort,
नयी दिल्ली – ११० ०४९	New Delhi-110049
भारत	INDIA

CORRIGENDA-1, dated 05/01/2018, Enquiry Ref. No. : E-5820/2017 dated 03/01/2018, Due Date of opening 15/01/2018 10:00 HRS (IST)

TANGEDCO-2X660MW ENNORE
AMENDEMENT NO-01 TO APRDS TECHNICAL SPECIFICATION (PE-TS –412-142–N101)

S. No.	Enquiry Specification			Specification Requirement	To be read as
	Volume / Section	Title	Page Reference		
1	Section II/ Sl.no.4.0/ Point no.9	QUALITY PLAN FOR CONTROL VALVE (PNEUMATIC) (QP No. PE-QP-412-145-I 006)	Sheet 5 of 8	FL factor	Clause stands withdrawn
2	Section I/ Customer specification/Cl. no.11.02.01/General point no. 4(b) & 4(c)	Control Valve Construction and sizing / General	Sheet 356	a. The liquid pressure recovery factor(FL)... sever flashing/cavitation services. b. The liquid pressure recovery factor(FL)... low flashing/cavitation services.	Clause 4(a) & 4(b) stands withdrawn