



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-2-Mar-24

CORRIGENDUM- 01

PROJECTs	:	3X40 MW RAMMAM STAGE-III HYDRO ELECTRIC PROJECT
PACKAGE	:	DOUBLE GIRDER EOT CRANES UPTO 100T CAPACITY
ENQUIRY NO	:	GEM/2024/B/4665197 Dated: 20-02-2024
SUBJECT	:	DUE DATE EXTENSION

Type of Corrigendum			
Technical Corrigendum -	<input type="checkbox"/>	Commercial Corrigendum -	<input checked="" type="checkbox"/>

Bidders are requested to go through the following -

- Due date is being extended from 02.03.2024 to 11.03.2024 (04.00PM). Bid opening shall be done at 04:30 PM on the due date.
- Refer BHEL Replies to Pre-Bid Queries.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

SUMEET SAHAY
Manager/BOP



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

BHEL Replies to Pre-Bid Queries

Sl. No	Volume/Section	Clause No./ Sheet No.	Specification Requirement	Pre-Bid Queries/ Clarifications	Resolution/ Clarification
1.	Specific Technical Requirement - Technical Data sheet A	Sr. No. 1.6.2/Page No. 9 of 134	Aux Hoists A.Rated SWL – Tonnes – 25T	Please clarify and confirm for Auxiliary Hoist capacity	Auxiliary Hoist capacity shall be 10T, in line with Clause no II. Page no 51 of 134 and Compliance drg no PE-DG-414-501-A002 at page no 22 of 134
2.	Specific Technical Requirement – Compliance drawings- Customer Specific Requirement (PE-DC-414-501-A004)	II. BF. Valve House Crane / Page No.51 of 134	A)Capacity (in Tonnes) b)Auxiliary Hook – 10 T		