



Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)

**Project Engineering
Management**

**OPEN TENDER ENQUIRY FOR MISC PUMPS (VERTICAL) FOR 1X 800 MW GSECL
WANAKBORI STPP UNIT 8**

Ref No. : PE/PG/WAN/E-5371/2016

Date: 11.11.2016

CORRIGENDUM/ ADDENDUM- 1

Tender Enquiry no.: PE/PG/WAN/E-5371/2016
Date: 27.10.2016

DUE DATE
18 NOV 2016
02:00 PM


Sir,
Please find attached amendment-1 to the technical specification for **MISC PUMPS (VERTICAL)** along with this corrigendum.

The bidders who have already submitted their bids for the said tender enquiry, may go through the corrigendum and in case it is felt required, may furnish revised bid with envelopes duly superscribed as "Revised bid (only to be considered)"

All bidders are requested to visit BHEL websites www.bhel.com (Tender Notifications Section) OR www.bhelpem.com (http://www.bhelpem.com/Tenders_Rev/NewTenders.aspx), all future corrigendum, addendums, amendments, if any, for this tender shall be hosted only on above websites

Thanking you,

Yours faithfully,
For and on behalf of BHEL


11/11/2016
SHRI PRAKASH YADAV / SHRI PRAKASH YADAV
(Sr. ENGINEER/Project Group-11)
BHEL, Noida-201301

Please reply to:

**Shri Prakash Yadav-Sr.Engr.
PGI-I**

Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)
Tel No. 0120-4213621

GSECL

1X800MW WANAKBORI TPS UNIT-8

AMENDMENT NO : 1

**TECHNICAL SPECIFICATION
FOR
MISCELLANEOUS PUMPS**

Specification No. : PE-TS-408-100-N001A (REV. 0)



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
PPEI BUILDING, SECTOR 16 A
NOIDA - 201301**

	TECHNICAL SPECIFICATIONS MISCELLANEOUS PUMPS	SPECN. NO.:	PE-TS-408-100-N001A		
	AMENDMENT NO 1	REV. NO.	0	DATE:	11/11/2016

1.0 With reference to S.No. 2.1 & 2.2 for Jackwell pumps of Datasheet A, Section 1D of Technical Specification, please consider the Specification amended as below:

Clause as mentioned in Technical Specification	Ammended Clause
Jackwell Pump capacity = 1190 CuM/ Hr	Jackwell Pump capacity = 1110 CuM/ Hr
Jackwell pump total dynamic head = 56 MWC	Jackwell pump total dynamic head = 55 MWC

2.0 Revised GUARANTEE SCHEDULE FOR MISC. PUMPS VERTICAL against Section IIIA of Technical Specification is attached with this amendment No. 1. All Bidders to submit the Guarantees as per the revised Schedule.

