

	AMENDMENT ON TECHNICAL SPECIFICATION FOR DM PLANT		SPECIFICATION NO.: PE-TS-410-163-A001
			AMENDMENT NO # 4
	1X800 MW TSGENCO KOTHAGUEDEM TPS STAGE –VII, PALONCHA		
			REV. NO. 00 DATE: 21/08/2015
			Page 1 of 1

The following modifications with respect to Technical Specification for **DM PLANT**, BHEL's Technical specification no PE-TS-410-163-A001 shall apply.

Bidder to note that existing clauses/page numbers as appearing in the specification stands deleted and clauses/page numbers as mentioned in "Modified to" column shall be applicable and complied by the bidder.

MODIFIED CLAUSES/PAGE NUMBERS.

Sl no.	Vol. No.	Section/ Description	Clause no	Page no	Existing	Modified to
1.	IIB	C1	2.0	10 OF 630	SCOPE OF SUPPLY (MECHANICAL) New clause added.	In addition to the items as indicated in technical specification, following shall also be in Bidder's scope: • One (1) number Electrically Operated Monorail Hoist of minimum 1.0 Ton safe working capacity and complete with all accessories for handling of Backwash Water Disposal Pumps within Backwash Waste Sump cum Pump House. • One (1) number Electrically Operated Monorail Hoist of minimum 1.0 Ton safe working capacity and complete with all accessories for handling of Neutralised Effluent Disposal Pumps located on neutralisation pit.
2.	IIB	C1	3.0, 4)	14 OF 630	200 meter DM water piping from DM plant to DM Water storage tanks.	Bidder to terminate DM water piping from DM plant (from outlet of each Mixed bed) to DM water storage tank at 5 meters from DM plant building. The coordinate of this terminal point shall be E- 347.7065, N- 835.5305. The line size shall be Ø114.3X3.05 (Stainless steel ASTM A312 TP 304 (ERW)). The other details of this terminal point shall be as per P&ID of Condensate transfer system Rev 03 (BHEL DRG. NO. PE-DG-410-100-N109) attached herewith as Annexure –A.
