



An ISO 9001
Company

Bharat Heavy Electricals Limited

(High Pressure Boiler Plant)

Tiruchirappalli – 620014, TAMIL NADU, INDIA

MATERIALS MANAGEMENT

TITLE CORRIGENDUM for NIT_35332	Phone: +91 431 2577457 / 2574156 Fax : +91 431 252 XX XX Email : rksamy@bheltry.co.in
--	---

	Reference Number: Enquiry EOI/NLC/2x660MW	Enquiry Date: 01.11.2017	Due date for submission of quotation: 28.11.2017
--	---	------------------------------------	---

You are requested to quote the Enquiry number date and due date in all your correspondences. This is only a request for quotation and not an order

CORRIGENDUM

Details of Corrigendum
Due date for the tender Enquiry No. EOI/NLC/2x660 MW is extended up to 28.11.2017
All other terms and conditions as published in the NIT 35332 remain unaltered.

BHEL commercial terms & conditions with Price Bid formats and all annexure can be downloaded from BHEL web site <http://www.bhel.com> or from the Government tender website <http://tenders.gov.in> (public sector units) Bharat Heavy Electricals Limited) under enquiry reference “EOI/NLC/2x660MW”

Tenders should reach us before 14:00 hours on the due date Technical bid will be opened at 14:30 hours on the due date Tenders would be opened in presence of the tenderers who have submitted their offers and who may like to be present.	Yours faithfully, For Bharat Heavy Electricals Limited
---	--

CORRIGENDUM No - 1. DT: 09.11.2017

**THERMAL POWER STATION-II , SECOND EXPANSION PROJECT (2X660 MW),
PHASE-1 AT NEYVELI**

**SUPER CRITICAL PULVERIZED LIGNITE FIRED STEAM GENERATOR &
AUXILIARIES PACKAGE (SE-1)**

Tender No. CO CONTS/0033E/TS II-2nd EXPN/PH-I/SE-1/SG/2017 Dt. 30.10.2017

The following Clause of the EOI are modified as below:

A) S.No.2,3 & 4 at Clause 2.4, Page 4 of EOI Document:

2.4 TENTATIVE PARAMETERS

Sl. No.	Description	Unit	Tentative Values (Existing)	Tentative Values (Modified)
2.	Main Steam pressure at Super heater outlet	Ksc (a)	270	281
3.	Main Steam Temperature at Super Heater Outlet	° C	600 ± 5	603
4.	Steam Temperature at Re Heater Outlet	° C	600 ± 5	603

B) Capacity of the Unit at Form D-6, Page 2/10, (Page 139) of DJU format:

Existing	Modified as
WHEREAS M/s ----- (Bidder) is submitting its proposal in response to the aforesaid Invitation for Bid by the Purchaser for Steam Generator & Auxiliaries Package for TPS II Second Expansion STPP Phase-I (2X800 MW) , against the purchaser's Bidding Documents No.XXXXXX	WHEREAS M/s ----- (Bidder) is submitting its proposal in response to the aforesaid Invitation for Bid by the Purchaser for Steam Generator & Auxiliaries Package for TPS II Second Expansion STPP Phase-I (2X 660MW) , against the Purchaser's Bidding Documents No. XXXXX

All other Terms and Conditions of the Tender remain unaltered. For further Details / Corrigendum visit our Website www.nlcindia.com.


CHIEF GENERAL MANAGER / CONTRACTS