

Ref No. : PE/PG/RTC/E-6434/2020/CORRIGENDA/02

Date:19.05.2020

CORRIGENDA / ADDENDUM-02

SUBJECT: TENDER ENQUIRY FOR RATE CONTRACT OF PLATE HEAT EXCHANGERS AS PER TECHNICAL SPECIFICATION NO. PE-RC-999-179-N003 (REV 0)

OUR REF: TENDER ENQUIRY NO: PE/PG/RTC/E-6434/2020, Dtd.05.05.2020

Please find BHEL's clarification on vendor's technical query-

Bidders technical query-	BHEL's clarification
Some variation in Guaranteed Performance Parameters i.e. ACW Side Outlet Temperature achieved as per our calculation is slightly varying as compared to ACW Side Outlet temperature given in Sr No 3.3 of Technical Specification No PE-RC-999-179-N003 (REV 0)	"The bidder to consider the Heat load of primary or secondary side, whichever is higher in deciding the Heat Transfer Area."

All bidders are requested to visit the website www.bhel.com (Tender Notifications Section) OR www.bhelpem.com. All future corrigenda/ amendment and due date extension, if any, for this tender shall be hosted only on above websites.

Thanking You,

**With Regards,
For & on behalf of BHEL**

Sd/-
**SUMEET SAHAY
DY.MGR/CMM**

Please reply to:
**Sh SUMEET SAHAY
DY.MGR/CMM**
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)
Tel No.0120-4213532, 09999498202