

Ref No. : PE/PG/RTC/E-6527/2020/CORRIGENDA/03

Date: 06.10.2020

CORRIGENDA / ADDENDUM-06

SUBJECT: TENDER ENQUIRY FOR FRAMEWORK AGREEMENT (RATE CONTRACT) OF LT XLPE POWER CABLES AS PER TECHNICAL SPECIFICATION NO. PE-RC-999-507-E002, REV 02

OUR REF: TENDER ENQUIRY NO: [PE/PG/RTC/E-6527/2020, DTD-17.09.2020](#)

DUE DATE
09.10.2020
BY 02.00PM

In reference to tender for FRAMEWORK AGREEMENT (RATE CONTRACT) OF LT XLPE POWER CABLES invited vide Enquiry No. PE/PG/RTC/E-6527/2020 dtd 17/09/2020, please find reply to vendor's query-

SL NO	VENDOR'S QUERY	BHEL REPLY
1	In NIT at Page No-69 , Sr.No.10(ii) -Multi-core cables under topic Armour (Attached), it is mentioned that "Project specific requirement for Type 'a' or 'b' shall be informed later". for making quotation clarity required please	BOQ Schedule 1.1 (A1-A37) is round/strip armoured as per IS-7098 (Part-1) table 6 and method shall be informed during detailed engineering as per project requirement. Bidder may consider the stringent of the two.

Vendors are requested to quote accordingly.

All bidders are requested to visit the website www.bhel.com (Tender Notifications Section) OR www.bhelnem.com. All future corrigenda/ amendment and due date extension, if any, for this tender shall be hosted only on above websites.

Thanking You,
With Regards,
For & on behalf of BHEL

SUMEET SAHAY
MGR/CMM

Please reply to:
Sh Sumeet Sahay, Manager
CMM
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)
Tel No.0120-4213532, 09999498202