

Ref No. : E-4941/2015 dated 15.07.2015

Date: 14.09.2015

CORRIGENDUM/ ADDENDUM-4

Our Ref : TENDER ENQUIRY NO: E-4941/2015 dated 15.07.2015
Package : SELF CLEANING STRAINERS
Project : 2 X 500 MW NEW NEYVELI TPP (TG)

This is in reference to the above Tender Enquiry No: E-4941/2015 dated 15.07.2015, please note the following:

With reference to technical specification (Vol-IIB) for SCS packages, please find enclosed the amendment to technical specification (Vol-IIB).

Thanking You,

With Regards,
For & on behalf of BHEL

Swati Rawat
Swati Rawat
Sr. Engineer/PG-II-2
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM, Noida-201301 (U.P.)
Tel No. 0120-4368624

Please reply to:
Swati Rawat (Sr. Engr/PG-II-2)
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM, Noida-201301 (U.P.)
Tel No. 0120-4368624

	TECHNICAL SPECIFICATIONS SCS	SPECN. NO.: PE-TS-402-165-N003			
	AMENDMENT NO. 1	REV. NO.	0	DATE:	10.09.15

1.0 With reference to S.No. 4.1 of Datasheet A, Section D, Vol IIB of Technical Specification, please consider the Specification amended as below:

Clause as mentioned in Technical Specification	Amended Clause
Filter body/ housing: Carbon Steel as per IS:210 Gr. FG 260 with epoxy painted inside	Filter body/ housing: Carbon Steel as per IS 2062 Gr. B with epoxy painted inside.