

Ref: PE/PG/EN1/E-5416/2016/Corrigendum/04

Date: 06/FEB/2017

DUE DATE
21-FEB-2017
BY 02.00 PM (IST)

Subject: Extension of due date of bid submission & Pre Bid Technical clarifications for tender of GENERATOR CIRCUIT BREAKER of 2X660 MW ENNORE SEZ STPP

Our Tender Enquiry No. E-5416/2016 dated 28.12.2016 for GENERATOR CIRCUIT BREAKER OF 2X660 MW ENNORE SEZ STPP

This is in reference to the subject Tender Enquiry please consider:

- (1) Pre Bid Technical clarifications asked by Bidder(Attached).
- (2) The due date for bid submission (Part I & Part II) of subject tender has been extended up to 21.02.2017 by 02:00 PM.

Thanking You

With regards
For & on behalf of BHEL



AMIT MEENA

Sr Engineer | PG II-2, BHEL PEM | Noida
E-MAIL: amitmeena@bhelpem.co.in
Ph. No. +91-120-4213613, +91 8800579479

Please reply to:
Amit Meena (Sr. Engr/PG-II-2)
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM, Noida-201301 (U.P.)
Tel No. 0120-4213613

DEVIATION & CLARIFICATION					
No.	Specification	Paragraph	Description	Deviation and Clarification	BHEL reply
1	PE-TS-412-510-E001	§ 3.00.02	In addition an emergency operating lever shall be supplied to allow manual opening and closing of the circuit-breaker.	We do not provide any devices for emergency operations. A crank is provided inside cubicle but it is only for maintenance.	Noted. However, crank shall be suitable for manual opening and closing of the circuit breaker.
2	PE-TS-412-510-E001	§ 3.00.09	An anodized aluminium nameplate, black anodized and laser engraved,	Our nameplate is in aluminium alloy material, white letters on blue background.	Bidder to comply to the technical specification.
3	PE-TS-412-510-E001	§ 3.00.11	i. Conductors shall be of highly-conductive copper.	The conductor is highly -conductive copper or aluminum.	Bidder to comply to the technical specification.
4	PE-TS-412-510-E001	3.05.01	Short circuit switch	We do not have any such switch as per our standard design to avoid any misuse at site. However, manual mounted short cct bar can be provided.	Noted.
5	PE-TS-412-510-E001	4.02.00	Routine Tests: i) Stored Energy system Tests	Not applicable as our offered GCB is with spring mechanism.	Noted.
6	PE-TS-412-510-E001	4.03.00	Site Tests: i) Stored Energy system Test ii) Power Frequencies withstand Voltage Test	i) Not applicable ii) Shall be conducted by IPBD manufacturer during whole system testing.	Noted.
7	PE-TS-412-510-E001		Mandatory Spare Parts List: i) Hydraulic oil for operating Mechanism. ii) Carbon Cleaning Brush	i) Not applicable. ii) Carbon Cleaning Brush not applicable	i) Noted. ii) Bidder to comply to the technical specification.