

Ref No.: PE/PG/NB2/E-6393/2020/CORRIGENDA/01

Date: 06/03/2020

**CORRIGENDA - 01**

**PROJECT: 3x660 MW NABINAGAR STPP.**

**PACKAGE: GYPSUM DEWATERING SYSTEM**

**TENDER ENQUIRY NO: PE/PG/NB2/E-6393/2019, DATED 28/02/20**

With reference to above mentioned tender, please note the following point.

- 1) "The material and thickness of the liners of slurry pumps shall ensure a minimum service life of 2 years before replacement. All the wear parts of the pump shall be guaranteed for a minimum wear life of not less than 14000 hours. Refer Clause 4.5.19, Sheet 12 OF 19, Sub-Section C1, Section-I."

With Regards,  
For & on behalf of BHEL



AMIT KUMAR  
SR. ENGR/PG-III

Please reply to:

**AMIT KUMAR SR. ENGR, PG-III**  
**Sh. P.K. GAUTAM, SR. DGM/PG-III**

Power Project Engineering Institute Building  
HRD & ESI Complex Plot No. 25, Sector -16 A,  
BHEL-PEM, Noida-201301 (U.P.), Tel No. 0120-4368780