

Ref No. : PE/PG/RTC/E-6369/2019/CORRIGENDA/01

Date: 10.02.2019

CORRIGENDA / ADDENDUM-01

SUBJECT: TENDER ENQUIRY FOR RATE CONTRACT OF NEUTRAL GROUNDING RESISTOR AS PER TECHNICAL SPECIFICATION NO. PE-TS-999-506-E001,REV(00)

OUR REF: TENDER ENQUIRY NO: [PE/PG/RTC/E-6369/2019, DTD-29.01.2020](#)

DUE DATE
17.02.2020
BY 14:00PM

1. The last date of submission of offer against tender for Rate Contract of NEUTRAL GROUNDING RESISTOR invited vide Enquiry No PE/PG/RTC/E-6369/2020, DTD-29.01.2020 has been extended till **17.02.2020, 14.00PM**. Part I Bid opening will be done on **17.02.2020, 15.00PM**. All bidders are requested to visit the website www.bhel.com (Tender Notifications Section) OR www.bhelpem.com. All future corrigenda/ amendment and due date extension, if any, for this tender shall be hosted only on above websites.
2. Refer attached Annexure-I to this corrigenda/addendum for prospective project list. Project list is indicative only, BHEL may ask for delivery anywhere in India for any of the project added in the prospective project/ existing projects during RC period.
3. Please note the following for technical clarifications :

Vendor Query	BHEL's reply
Clause 5.2.2 & 5.2.3 : These clauses are 'Not Applicable', as the Neutral Connection is by Copper Flat thru Roof Mounted Terminal Bushings and not by Cable.	As per Clause 2.3 of section-I, the requirements of Section-I shall prevail and govern in case of conflict between the corresponding requirements of Section-I and Section-II. Since, Clause 5.6 of Datasheet A of section-I clearly states that the connection between NGR & Transformer is through copper flat, it is understood that cable box is not required for the same.
Clause 5.2.5 : This clause needs to be modified to match with Para 4.3 of Data Sheet A.	As per Clause 2.3 of section-I, the requirements of Section-I shall prevail and govern in case of conflict between the corresponding requirements of Section-I and Section-II.
Clause 5.1.2 : "Minimum Two Banks in parallel" to be read as "With 2 Parallel Paths" as per Para 1.10 of Data Sheet-A.	As per Clause 2.3 of section-I, the requirements of Section-I shall prevail and govern in case of conflict between the corresponding requirements of Section-I and Section-II.

Thanking You,

With Regards,

For & on behalf of BHEL

SUMEET SAHAY

DY MGR/CMM

Please reply to:

**Sh Sumeet Sahay, Dy Manager
CMM**

Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)
Tel No.0120-4213532, 09999498202

**ANNEXURE- I TO CORRIGENDA/ADDENDUM-01 FOR NIT(PE/PG/RTC/E-6369/2019 ,
Dtd.29/01/2020)**

**LIST OF PROJECTS FOR NEUTRAL GROUNDING RESISTOR
(RATE CONTRACT)**

Sl.no	TITLE	REMARKS
1	3x200 MW+ 3x500 MW+ 1x500 MW NTPC Korba STPS Stage-I, II & III- FGD	
2	3X660 MW NABINAGAR FGD	
3	3x200MW + 3x500 MW Ramagundam (FGD) STPP, Stage-I & II	
4	2 x 660 MW NTPC TALCHER	