



Ref No. : PE/PG/KAR/E-4552/14/CORRIGENDA/01

Date : 22.09.2014

CORRIGENDA / ADDENDUM-01

SUBJECT: 3X660 MW NORTH KARANPURA STP Project.

OPEN (GLOBAL) TENDER ENQUIRY FOR "SELF CLEANING STRAINERS"

Our Ref : ENQUIRY No : PE/PG/KAR/E-4552/2014, Dtd. 03.09.2014

DUE DATE
07.10.2014
BY 10:00A.M. IST

Bidders are requested to refer amended Data Sheet-A (Vol-IIB/Technical Specification) given below for the subject enquiry.

You are requested to refer this Data Sheet-A during preparation of your offer and submit your offer considering this amended Data Sheet-A.

Amended Data Sheet-A is enclosed with this letter.

It has been also decided at BHEL-PEM to extend the due date for submission of offer upto **07.10.2014 (10:00 A.M. IST)**.

Kindly submit your offer on or before the due date.

Thanking You

For & on Behalf of BHEL,

Ashish Kumar Gupta
22/09/14
Ashish Kumar Gupta
Sr. Engineer/PG-III



BHARAT HEAVY ELECTRICALS LIMITED

AMENDEMENT NO-01 TO
NORTH KARANPURA STPP (3 X 660 MW)
VOL-IIB- TECHNICAL SPECIFICATION- SCS (PE-TS-405-165-N003)

SL. NO	ENQUIRY SPECIFICATION				SPECIFICATION REQUIREMENT	TO BE READ AS
	Sec/ part	Sub Sec	Page No.	Clause No.		
1	Vol-IIB/Sec-D	Data sheet-A	1 of 7	2.4	Flow Through Filter for 800 NB Normal—3014 CubM/Hr Maximum – 3617 CubM/Hr	Flow Through Filter for 800 NB Normal—3150 CubM/Hr Maximum – 3780 CubM/Hr
2	Vol-IIB/Sec-D	Data sheet-A	1 of 7	2.4	Flow Through Filter for 350 NB Normal — 693 CubM/Hr Maximum – 832 CubM/Hr	Flow Through Filter for 350 NB Normal — 820 CubM/Hr Maximum – 984 CubM/Hr

Amish
22/09/14