

Ref: PE/PG/EN1/E-5416/2016/Corrigendum/02

Date: 25/JAN/2017

DUE DATE
06-FEB-2017
BY 02.00 PM (IST)


Subject: Amendment in Technical Specification clause for tender of GENERATOR CIRCUIT BREAKER of 2X660 MW ENNORE SEZ STPP

Our Tender Enquiry No. E-5416/2016 dated 28.12.2016 for GENERATOR CIRCUIT BREAKER OF 2X660 MW ENNORE SEZ STPP

Specification reference	Existing Clause	Clause shall be read as
Section-II, PE-SS-999-510-E001, Clause 5.02.00	TYPE TESTS All equipment offered should be of type-tested design. Offered model of GCB should have been type tested as per latest version of standard IEC/ IEEE 62271-37-013. Series isolator and earth switch should have been type tested as per IEC 62271-102.	"All equipment offered should be of type tested design. Offered model of GCB should have been type tested as per standard IEEE C37.013. Series isolator and earth switch should have been type tested as per IEC 62271-102."

Thanking You

With regards
For & on behalf of BHEL



AMIT MEENA

Sr Engineer | PG II-2, BHEL PEM | Noida
E-MAIL: amitmeena@bhelpem.co.in
Ph. No. +91-120-4213613, +91 8800579479

Please reply to:
Amit Meena (Sr. Engr/PG-II-2)
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM, Noida-201301 (U.P.)
Tel No. 0120-4213613