

Ref No. : PE/PG/RTC/E-6477/2020 dtd 15/07/2020/CORRIGENDA/03

Date: 04.08.2020

CORRIGENDA / ADDENDUM-03

**SUBJECT: TENDER ENQUIRY FOR FRAMEWORK AGREEMENT (RATE CONTRACT) OF LT PVC CONTROL CABLES
AS PER TECHNICAL SPECIFICATION NO. PE-RC-999-507-E004, REV 00
OUR REF: TENDER ENQUIRY NO: PE/PG/RTC/E-6477/2020, DTD-15.07.2020**

In reference to tender for FRAMEWORK AGREEMENT (RATE CONTRACT) OF LT PVC CONTROL CABLES invited vide Enquiry No. PE/PG/RTC/E-6477/2020 dtd 15/07/2020, please find clarifications-

SL NO.	VENDOR'S QUERY	BHEL REPLY
1	As per BOQ - Item A.4 – 5Cx4sq.mm (strip). But as per IS-1554 5Cx4 SQMM cable should be round wire armoured. Kindly confirm the requirement.	AS per IS-1554 , round wire/strip armoring is envisaged based on “dia under armor” (i.e. if dia under armor is less than 13 mm it shall be round wire else strip). Also “dia under armor” varies vendor to vendor based on their manufacturing. Now, for Item A.4 – 5Cx4sq.mm (strip), as it is a borderline case where some manufacturer’s “dia under armor” is more than 13mm hence IEEMA factors (conductor, insulation & armoring) for this item A.4-5Cx4sq.mm (strip) shall be applicable.
2	Further, if it is wire armoured, then the factor given in price schedule should also change.	Further, if “dia under armor” is less than 13mm, round wire armoring shall be applicable and IEEMA factors (conductor, insulation & armoring) shall be applicable as per line item no. B.12, 5C - 4- ARMoured (ROUND WIRE).

All bidders are requested to visit the website www.bhel.com (Tender Notifications Section) OR www.bhelpem.com & <https://bhel.abcpocure.com>. All future corrigenda/ amendment and due date extension, if any, for this tender shall be hosted only on above websites.

Thanking You,

With Regards,

For & on behalf of BHEL

SUMEET SAHAY

MGR/CMM

Please reply to:

Sh SUMEET SAHAY, Manager/ CMM
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)
Tel No.0120-4213532, 9999498202