

Ref No. : PE/PG/RTC/E-6477/2020/CORRIGENDA/04

Date: 05.08.2020

CORRIGENDA / ADDENDUM-04

**SUBJECT: TENDER ENQUIRY FOR FRAMEWORK AGREEMENT (RATE CONTRACT) OF LT PVC CONTROL CABLES
AS PER TECHNICAL SPECIFICATION NO. PE-RC-999-507-E004, REV 00**

OUR REF: TENDER ENQUIRY NO: [PE/PG/RTC/E-6477/2020, DTD-15.07.2020](#)

In reference to the tender enquiry for (Framework Agreement) Rate Contract of **LT PVC CONTROL CABLES** invited vide Enquiry No PE/PG/RTC/E-6477/2020, DTD-15.07.2020, please find the following clarification-

Sl. No.	Bidder's Query	BHEL Reply
1	Your annexure 1A mentioned %age implications w.r.t. inner & outer sheath of basic price of cable and not covered insulation. In case of HR PVC outer-sheath, insulation shall be type C. Kindly confirm the %age implication for type C insulation.	In case, outer sheath insulation is HR-PVC, all the parameters (i.e. insulation, inner sheath etc.) shall be selected accordingly (Refer Datasheet-A). Further, due to this variation % implication on basic price shall be as per sl. no. (2) of the Annexure-1A i.e. 3%.

All bidders are requested to consider the same while quoting. Vendors who have already submitted their offer may revisit their offer in line with above clarifications.

All bidders are requested to visit the website www.bhel.com (Tender Notifications Section) OR www.bhelpem.com. All future corrigenda/ amendment and due date extension, if any, for this tender shall be hosted only on above websites.

Thanking You,

With Regards,

For & on behalf of BHEL

SUMEET SAHAY

MGR/CMM

Please reply to:

**Sh Sumeet Sahay, Manager
CMM**

Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)
Tel No.0120-4213532, 09999498202