

Ref No. : PE/PG/RTC/E-6373/2019/CORRIGENDA/05

Date: 18.03.2020

**CORRIGENDA / ADDENDUM-05**

**SUBJECT: TENDER ENQUIRY FOR RATE CONTRACT OF DISTRIBUTION BOARDS AS PER TECHNICAL SPECIFICATION NO. PE-RC-999-558-E005(REV-0)**

**OUR REF: TENDER ENQUIRY NO: PE/PG/RTC/E-6373/2019, DTD-01/02/2020**

|                   |
|-------------------|
| <b>DUE DATE</b>   |
| <b>21.03.2020</b> |
| <b>BY 14:00PM</b> |

All the bidders are requested to note the following regarding cable size of LDB & LP :

1. Cable size of LDB and LP incomers are provided in Corrigendum-04 Dtd.11.03.2020.
2. LDB outgoing cable size shall be same as LP incomer cable size.
3. Tentative LP outgoing cable size are :
  - AC LP outgoing : 2.5 / 4.0 sq.mm Cu wire
  - DC LP outgoing : 2.5 sq.mm Cu wire.
  - SLP outgoing : 3.5 C X 25 sq.mm

Thanking You,

**With Regards,**

**For & on behalf of BHEL**

**SUMEET SAHAY**

**DY.ENGINEER/CMM**

Please reply to:

**Sh SUMEET SAHAY**

**DY.ENGINEER/CMM**

Power Project Engineering Institute Building  
HRD & ESI Complex Plot No. 25, Sector -16 A,  
BHEL-PEM,Noida-201301 (U.P.)  
Tel No.0120-4213532, 09999498202