

Ref No. : PE/PG/RTC/E-5966/2018/CORRIGENDA/05

Date: 20.07.2018

**CORRIGENDA / ADDENDUM-05**

**SUBJECT: TENDER ENQUIRY FOR RATE CONTRACT OF PLATE HEAT EXCHANGER AS PER TECHNICAL SPECIFICATION NO. PE-RC-999-179-N001 (REV 0)**

**OUR REF: TENDER ENQUIRY NO: [PE/PG/RTC/E-5966/2018, DTD-01.06.2018](#)**

Please find enclosed Amendment I to Technical Specification. Bidders are requested to follow the same while quoting. All bidders are requested to visit the website [www.bhel.com](http://www.bhel.com) (Tender Notifications Section) OR [www.bhelpem.com](http://www.bhelpem.com). All future corrigenda/ amendment and due date extension, if any, for this tender shall be hosted only on above websites.

Thanking You,

**With Regards,**

**For & on behalf of BHEL**

**SUMEET SAHAY**

**DY MGR/CMM**

Please reply to:

**Sh Sumeet Sahay, Dy Manager  
CMM**

Power Project Engineering Institute Building  
HRD & ESI Complex Plot No. 25, Sector -16 A,  
BHEL-PEM, Noida-201301 (U.P.)  
Tel No.0120-4213532, 09999498202

# **RATE CONTRACT OF PLATE HEAT EXCHANGERS**

## **AMENDMENT NO. 1**

### **TO TECHNICAL SPECIFICATION FOR RATE CONTRACT OF PLATE HEAT EXCHANGER**

**Specification No. : PE-RC-999-179-N001 (REV. 0)  
SECTION-IB**



**BHARAT HEAVY ELECTRICALS LIMITED  
POWER SECTOR  
PROJECT ENGINEERING MANAGEMENT  
PPEI BUILDING, SECTOR 16 A  
NOIDA - 201301**

|                                                                                   |                                                               |                   |                                       |  |
|-----------------------------------------------------------------------------------|---------------------------------------------------------------|-------------------|---------------------------------------|--|
|  | <b>TECHNICAL SPECIFICATIONS<br/>PLATE TYPE HEAT EXCHANGER</b> |                   | <b>SPECN. NO.:</b> PE-RC-999-179-N001 |  |
|                                                                                   |                                                               |                   |                                       |  |
|                                                                                   | <b>AMENDMENT NO. 1</b>                                        | <b>REV. NO.</b> 0 | <b>DATE:</b> 19.07.2018               |  |

  

|     |                                                                                                                                                                          |
|-----|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1.0 | With reference to Clause .No. 1.7 of Datasheet A, for Type-I PHE in Group-A, Section IB, of Technical Specification, please consider the Specification amended as below: |
|-----|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

  

|     |                                     | Existing                    | Amended                     |
|-----|-------------------------------------|-----------------------------|-----------------------------|
|     |                                     | Type-I                      | Type-I                      |
| 1.7 | Maximum permitted Length of the PHE | 5000 mm (excluding Reducer) | 6600 mm (excluding Reducer) |