

GLOBAL TENDER FOR CONTROL VALVES OF 2X660 MW ENNORE SEZ
STPP

Ref No. : E-4875/2015/CORRIGENDUM/02

Date: 01.07.2015

CORRIGENDUM/ ADDENDUM-2

Subject: Technical clarification for Control Valves of 2X660MW Ennore SEZ STPP

Ref: Tender Enquiry No. E-4875/2015 dated 02.06.2015 of Control Valves for 2X660MW ENNORE SEZ STPP

This is in reference to the subject Tender Enquiry please note following:

Following clauses given on page no. 11 of 135 (Specific Technical Requirements, Vol. IIB, Sec. C of technical specification PE-TS-412-145-I104) to be read as:

20) The Liquid pressure recovery factor (FL) shall be 0.995 or better for severe Flashing/cavitation services. Bidder to furnish applicable catalogues in support of the same.

Applicable Tag No.: FDV-14


21) The Liquid pressure recovery factor (FL) shall be 0.985 or better for low Flashing/cavitation services. Bidder to furnish applicable catalogues in support of the same.

Applicable Tag Nos.: CDV-39, CDV-67, CDV-72, DRV-2, DRV-5, DRV-15, DRV-18, DRV-28, DRV-31, DRV-34, DRV-37, DRV-48, DRV-53, DRV-59, DRV-65, DRV-68

Thanking You,

With Regards,

For & on behalf of BHEL


Rajeev Kumar

Sr. Engineer/PG-II-2

Please reply to:

Rajeev Kumar (Sr.Engr/PG-II-2)

Power Project Engineering Institute Building

HRD & ESI Complex Plot No. 25, Sector -16 A,

BHEL-PEM,Noida-201301 (U.P.)

Tel No. 0120-4213582