

Project Engineering
Management

Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)



Ref. No. PE/PG/OP1/E-4590/2014-01
Enquiry No.: PE/PG/OP1/E-4590/14
Date: 22/10/2014

2X660 MW IB, BANHARPALLI UNITS 3 & 4
SCREENED CONTROL CABLES

CORRIGENDA/ADDENDA-1

Dear Sirs,

Please find the clarifications as per the attached 'Annexure-I' for subject enquiry. Bidders are requested to quote accordingly.

Thanking you,
Yours faithfully,
For and on behalf of BHEL


22.10.14

ROHIT JUNEJA
(ENGINEER/Project Group-II-1)

ROHIT JUNEJA
ENGINEER/PG-II-1,
BHEL/PS-PEM
POWER PROJECT ENGINEERING INSTITUTE,
PLOT NO. 25, SECTOR - 16A, NOIDA (UP)
(OFF) 0120-4368848.

Regd. Office:
BHEL House
Siri Fort
New Delhi-110049

ANNEXURE-I
ODISHA POWER GENERATION COMPANY LIMITED
2 X 660 MW IB TPP BANHARPALLI UNITS 3&4
SCREENED CONTROL CABLES
TECHNICAL SPECIFICATION NO. - PE-TS-391-507-E004 R0

S. No.	Reference Section	Clause No. of	Specific Requirement/ Change
1	Datasheet-A	11 (b)	Shall be read as- Drain wire Size (sq.mm.): "Seven (7) strand 20 AWG (0.51 sq. mm.)" .
		12 (b)	Shall be read as- Inner sheath Thickness : "As per IS-1554 Part I"
2	ANNEXURE A1, BOQ-cum-Price schedule, Main Supply	Note no. 7.	Shall be read as- "Standard drum length shall be 1000 metres upto 12P & Standard drum length shall be 500 metres above 12P. The tolerance of drum length shall be $\pm 5\%$. Short lengths of individual cable size not less than 300m may be accepted only in the final drum length to complete the supply within the overall variation limit stipulated above.
3	Section-C	4.3 (i)	Shall be read as- Refer Quality Plan and Annexure to QAP for Type tests, Acceptance tests & Routine tests requirement.
4	Annexure to QAP	3 (I)	Shall be read as- Reference Standard: VDE 0472/ IS 10810 Pt 6/ ADS
		3 (VIII)	Shall be read as- Reference Standard: VDE 0472/ IS 5831
		3 (IX)	Hot Set test: Not applicable for screened control cables.
		4(II), 4 (III) & 7 (IV)	Shall be read as- Test Conduction required as: T, A


22.10.14

(ROHIT JUNEJA)