



**BHARAT HEAVY ELECTRICALS LIMITED**  
**PROJECT ENGINEERING MANAGEMENT, NOIDA**

Date-18-Mar-26

**CORRIGENDUM- 02**

|            |   |   |
|------------|---|---|
| PROJECT    | : | 3X200+3X500+1x500 MW NTPC KORBA TPP-FGD |
| PACKAGE    | : | HVAC FOR FGD                            |
| ENQUIRY NO | : | 77/25/6318/SAN DATED 06.03.2026         |
| SUBJECT    | : | PRE-BID CLARIFICATION                   |

|                         |                                     |                          |                          |
|-------------------------|-------------------------------------|--------------------------|--------------------------|
| Type of Corrigendum     |                                     |                          |                          |
| Technical Corrigendum - | <input checked="" type="checkbox"/> | Commercial Corrigendum - | <input type="checkbox"/> |

Bidders are requested to note the following -

- Refer below pre-bid clarification

| Pre-Bid Query   | BHEL Reply   |
|---|--|
| The rating of Motor of AHU in the approved Data sheet is 15KW/20 HP. However, the same is mentioned as 37 KW in the Price schedule item No 1b2. Kindly clarify. | Motor rating shall be 15KW (4 pole) as per Technical Datasheet of AHU enclosed with the Technical Specification. Accordingly, 37 KW Motor rating mentioned in the Price Format to be read as 15.0 KW |

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,  
For and on behalf of BHEL

Sanjeev Kumar  
Engineer/BOP