



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-14-Sep-26

CORRIGENDUM- 02

PROJECTs	:	2 X 660 MW MAHAGENCO Koradi TPP
PACKAGE	:	AIR CONDITIONING SYSTEM
ENQUIRY NO	:	77/26/6133/SAN Dated 27.08.2026
SUBJECT	:	TENDER DUE DATE EXTENSION + PRE-BID Clarifications.

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☒

Bidders are requested to note the following -

1. Due date & time of bid submission has been extended up to 18.09.2026 @ 12.00 PM. Bid opening shall be done at 04:00 PM on the due date.
2. Refer below BHEL Replies to Pre-Bid Queries

Sr. No.	Bidders Query	BHEL Reply
1.	Item no. 1 of AC Plant 1: 315 TR Screw Chiller: The Chiller shall be flooded type as against DX type; since DX type chillers are not available in these capacities.	As per technical specification clause no. 4.13.03 & 4.13.04 of sub-section C-2A (stamp running page 60 of 604) and Price format clause A- (2) of annexure-I, flooded type chiller is also acceptable.
2.	The List of Makes (Sub Vendor list) needs to be modified since it is not in line with the availability.	
a)	The Make of condenser & Chiller & the Compressor do not tally with each other.	The makes shall be in line with the technical specifications. However, as per the technical specifications, in case the Bidder intends to propose any additional vendor during the contract stage, the same shall be proposed within 4 weeks of the LOI with relevant credentials. This shall be subject to BHEL & MAHAGENCO approval without any commercial and delivery implications."
b)	The Cooling coil of AHUs shall be of the makes of the AHU manufacturer.	
c)	The makes of the Air handling units: Zeco/Edgetech/Waves to	



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

	be included as against Blue Star/ Cool Tech/ V M Engg/ Hyderabad Pollution/ Advance Ventilation.	
d)	Cooling tower BELL/ Mihir/ Flowtech make to be incorporated	
e)	Modulating thermostat shall be of the make Honeywell/Rapid cool	
f)	Air conditioning of system (Item 36.19): The makes indicated are not understood	Noted, the same is not applicable to the Bidder.
g)	Ventilation system (Item no. 35.01): The makes indicated are not understood.	Noted, the same is not applicable to the Bidder.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,
For and on behalf of BHEL

Sanjeev Kumar
Engineer/BOP