



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-30-Aug-22

CORRIGENDUM- 02

PROJECT	:	2X660 MW THDC KHURJA- CW SYSTEM CIVIL WORKS
PACKAGE	:	SEWAGE TREATMENT PLANT
ENQUIRY NO	:	PE/PG/KHU/E-7049/2022 Date- 11-Aug-22
SUBJECT	:	DUE DATE EXTENSION

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input checked="" type="checkbox"/>

Please note the following:

1. Due date is being extended from **30.08.2022 to 06.09.2022 (11:00 AM)**. Bid opening shall be done at **04:00 PM** on the due date.
2. Amendment to Technical Specification as per attached Annexure

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

**Sumeet
Sahay**

Digitally signed by Sumeet Sahay
DN: cn=Sumeet Sahay, o=Bharat
Heavy Electricals Ltd, ou=PS-PEM,
email=sumeetsahay@bhel.in, c=IN
Date: 2022.08.30 14:45:38 +05'30'

**Sumeet Sahay
Manager/BOP**



**AMENDMENT ON TECHNICAL SPECIFICATION
FOR
SEWAGE TREATMENT PLANT
2X660 MW THDC KHURJA STPP - CW
SYSTEM CIVIL WORKS**

SPECIFICATION NO.: PE-TS-492-673-A001
 AMENDMENT NO # 1
 REV. NO. 00 DATE: 26/08/2022
 Page 1 of 2

The following modifications/ amendment with respect to Technical Specification for BHEL's Technical specification no **PE-TS-492-673-A001** shall apply.

New clauses and scope are added as listed below in **SCHEDULE A** & shall be a part of tender specification and in bidder's scope. Bidder to comply the same.

SCHEDULE-A

NEW CLAUSE/ SCOPE ADDED:

Sl no.	Vol. No.	Section/ Description	Clause no	Page no	Description
1.	IIB	SECTION - IA/ SPECIFIC TECHNICAL REQUIREMENTS FOR MECHANICAL	-	-	The below electrical load list is being followed for the supply of MCC (MCC in BHEL scope). The same ratings to be complied by the bidder. In case some of the drives are not applicable (due to supplier's proprietary system requirement of sewage treatment philosophy), the same MCC module may be kept as spare. In case, any change of rating of drive is necessitated during detail engineering, the modification, if required in MCC shall be part of STP Bidder's scope.
FOR CW SEWAGE TREATMENT PLANT (10KLD)					
		DRIVE			SELECTED MOTOR RATING (KW)
		1.		Sewage transfer pump	2.2
		2.		Sludge recirculation pumps	1.1
		3.		Filter feed pump	1.5
		4.		Treated water disposal pump	1.1
		5.		Air Blowers	1.5



**AMENDMENT ON TECHNICAL SPECIFICATION
 FOR
 SEWAGE TREATMENT PLANT
 2X660 MW THDC KHURJA STPP - CW
 SYSTEM CIVIL WORKS**

SPECIFICATION NO.: PE-TS-492-673-A001
 AMENDMENT NO # 1
 REV. NO. 00
 DATE: 26/08/2022
 Page 2 of 2

6.	Hypo Dosing Pumps	0.75
7.	Electric operated Multi port valve for MGF	0.6
8.	Electric operated Multi port valve for ACF	0.6
FOR RW SEWAGE TREATMENT PLANT (10KLD)		
9.	Sewage transfer pump	2.2
10.	Sludge recirculation pumps	1.1
11.	Filter feed pump	1.5
12.	Treated water disposal pump	1.1
13.	Air Blowers	1.5
14.	Hypo Dosing Pumps	0.75
15.	Electric operated Multi port valve for MGF	0.6
16.	Electric operated Multi port valve for ACF	0.6
