


	BHEL Tenders	Government eProcurement System Published Corrigendum Details	Date : 05-Jun-2025 05:19 PM		
 Print					
Organisation Chain :	Bharat Heavy Electricals Limited PEM - Noida Core Material Management Common BOP				
Tender ID :	2025_BHEL_48689_1				
Tender Ref No :	77/25/6028/AAN				
Tender Title :	Fuel Oil and Tank package for 2x800 MW SINGRAULI STPP STAGE-III				
Corrigendum Type :	Technical Bid				
Corrigendum Document Details					
Corr.No.	Corrigendum Title	Corrigendum Description	Published Date	Document Name	Doc Size(in KB)
1	Corrigendum03	pre bid clarification	05-Jun-2025 05:17 PM	CORRIGENDA03.pdf 	1009.63
2	CORRIGENDUM- 01	Pre-bid clarification	04-Jun-2025 01:55 PM	CORRIGENDA01.pdf 	1016.16



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-5-Jun-25

CORRIGENDUM- 03

PROJECTs	:	2X800 MW NTPC SINGRAULI STPP STAGE III EPC
PACKAGE	:	Fuel Oil and Tank package
ENQUIRY NO	:	77/25/6028/AAN Dated 21.05.2025
SUBJECT	:	Technical Clarification

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input type="checkbox"/>

Please find enclosed pre-bid clarification.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Aanchal Choudhary
Manager/BOP

2x800 MW SINGRAULI STPP STAGE-III-FUEL OIL AND TANK PACKAGE- BHEL REPLY OF PRE-BID QUERY

Sl.No.	Query	BHEL REPLY
1	Please clarify which tanks need to provide Lighting protection System?	Lighting protection not in bidders scope.
2	Please specify the depth of the Water Pit and Sump Pit for the installation of the Dirty Oil Pump and Sump Pump respectively.	The same shall be decided during detailed engineering based on the design calculation furnished by the successful bidder, however minimum 2 meter shall be considered for tender purpose.
3	UT Pumps has been taken over by Ingersoll rand Group under Hydro Prokav Pumps India Pvt Ltd. Please confirm New vendor is approved.	BHEL Noted. Further as mentioned in the technical specification, the sub-vendor list has been included for reference. However, Successful bidder shall submit the proposed sub-vendor list including new-vendors with relevant vendor credentials for acceptance by BHEL/NTPC.
4	The makes for Globe vales are given in the Tender document.	Glove valve sub vendor list is mentioned at page no 361 of 684 of technical specification
5	The Sump Pump specification given in the tender document is Vertical Centrifugal Submersible Pump. However as per the recommendation of the Pump Manufacturer it should be Single screw Pump. Please clarify.	Bidder to follow technical specification
6	The Ball valve approved manufacture list only allows only 2 Manufacturer as attached. Namely Microfinish and G M Engg. The bigger size valves 400, 350, 300 NB vales are not approved with other manufacturer. Please clarify.	Bidder shall follow the technical specifications, Two subvendors are already approved in ntpc list. However, as mentioned in the techncial specification, incase successful bidder wishes to propose new sub-vendors durig detail engineering, the same shall be included in the proposed sub-vendor list along with the relevant credentials and submitted for approval by NTPC.