



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-11-Jun-25

CORRIGENDUM- 04

PROJECTS	:	1 X 800 MW NTPC Sipat STPP Stage-III
PACKAGE	:	WATER TREATMENT PACKAGES
ENQUIRY NO	:	77/25/6032/SAN Dated 23.05.2025
SUBJECT	:	DUE DATE EXTENSION + PRE-BID CLARIFICATIONS

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☒

Bidders are requested to note-

1. Please refer attachment for BHEL replies to Pre- Bid Queries.
2. Due date & time of bid submission has been extended up to 20.06.2025 @ 12.00 PM. Bid opening shall be done at 04:00 PM on the due date.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,
For and on behalf of BHEL

Sanjeev Kumar
Engineer/BOP

BHEL Reply to Pre-Bid Queries

S No	PART / SECTION NO	CLAUSE NO & PAGE NO	DESCRIPTION	BIDDER'S QUERY	BHEL Reply to Pre-Bid Queries
1	Notice Inviting Tender	S no 7. Due Date & Time	For offer submission : 13-June-2025, 12:00 PM	NCC is keen on submitting offer for the subject package. Considering the volume of work involved in various systems of WTP package and time required for preparing techno-commercial offer & price bid, we request for extension of bid submission date by at least 30 days (to 14-07-2025)	Due date has been extended upto 20.06.2025 @12:00 PM. Kindly expedite your offer preparation and submit your offer with in due date & time.
2	(a) Intent of specification, and (b) CWT, Scope of Supply, point no 2	CW Chemical treatment Page 14 of 4283 and Page no 64 of 4283	1) Design, supply, AMS, Erection, Commissioning, O&M, and Handing over on EPC basis. 2) Supply of all CWT specialty chemicals and One (1) year operation after PG test of CW system at full load shall be in bidder's scope of supply.	From these clauses it is considered that O&M of One (1) year is applicable for CWT alone including supply of chemicals. Please confirm our understanding	Bidder's understanding is correct. However, Bidder to refer and comply technical specification requirements.
3	Intent of specification	Page 14 of 4283	Design, Supply, AMS, On EPC Basis	Annual Maintenance Services (AMS) is specified for sub systems covered in SI no 1 to 11, 18,19,21. It is considered that AMS is applicable for the Control & Instrumentation items alone covered Sub Section IC. Please confirm our understanding	As per technical specification section I-C, Bidder to provide Comprehensive Annual Maintenance Services (AMS) for three (03) years after warranty period for all the Analyser instruments and EQMS supplied in this package. Further, as per technical specification requirements, AMC for switchgear/ numerical relay networking is also included in Bidder's scope. Bidder to refer the Technical Amendment - 1 for modified scope of AMC.
4	Annexure XIII	Page no 994 of 4283	Terminal Points	It is considered that within battery limits of Water treatment package and Pipelines lines up to Terminal points will be routed on RCC pedestals or Underground. No pipe racks are envisaged under the scope of WTP package. Please confirm	Pipe supports within the Islands -1, 2, 3 & 4 are to be provided by the bidder meeting technical specification requirements.
5	Condensate Polishing Unit and Plot Plan	Page 45 of 4283 and Page 960 of 4283	CPU Plant	It is considered that Purchaser (BHEL) will provide space in pipe racks for routing of CPU resin transfer lines between CPU located in TG building and Regeneration system located in Island 1. Please confirm.	It is confirmed that outside the Island's boundary, space on pipe racks for routing resin transfer lines between CPU located in TG building and Regeneration system shall be provided by BHEL.