



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-30-Jun-25

CORRIGENDUM- 08

PROJECTS	:	1 X 800 MW NTPC Sipat STPP Stage-III
PACKAGE	:	WATER TREATMENT PACKAGES
ENQUIRY NO	:	77/25/6032/SAN Dated 23.05.2025
SUBJECT	:	PRE-BID CLARIFICATION

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☐

Bidders are requested to note the BHEL replies to Pre- Bid Queries as follows-

SL. NO.	SECTION	CLAUSE NO.	PAGE NO.	SPECIFICATION REQUIREMENT	CLARIFICATION	BHEL REPLIES
1.	Annexure -3	TECHNICAL SPECIFICATION SUMP PUMPS/SUBMERSIBLE PUMPS	431 Of 4283	SUMP PUMPS / SUBMERSIBLE PUMPS Quantity of pumps: - 1. Condenser pit- 1W+01S= 2 no's pump. 2. Transformer yard & Cable tranches- 1W+0S= 4 no's pump. 3. CW & Raw water pump house- 1W+0S= 2 no's pump. 4. Clarified water tank & Service water tank- 1W+0S= 2 no's pump.	Request to you kindly confirm quantity of pumps.	Bidder to follow the technical specification requirements.
2.		Technical specification	1093 Of 4283	2-unit MB mention in data sheet whereas in P&ID 3 unit.	Kindly confirm the configuration.	As per Scope of Supply, Clause No. 12.1/ A) Option - 1 (Ion Exchange Based DM Plant/ h (Page No. 87 of 4283 and Data Sheet - A for DM Plant/ S. No. 12.2 (Page No. 1093 of 4283), Total 2 nos. (2 x 100%) of MB (One no. per DM stream) are to be provided by the bidder.



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,
For and on behalf of BHEL

Sanjeev Kumar
Engineer/BOP

Corrigendum