



**BHARAT HEAVY ELECTRICALS  
LIMITED**  
PROJECT ENGINEERING MANAGEMENT

BHEL PEM,PPEI  
PLOT No.25, SECTOR-16A,  
NOIDA-201301 (U.P.)  
PHONE: 0120-4368761

Ref. No: GEM/2021/B/1750786 Dtd. 10.12.21

Date : 28.12.2021

**CORRIGENDA/ADDENDA-02**

**SUBJECT : 1X660 MW WBPDCS SAGARDIGHI EXTN UNIT V Project**  
**PACKAGE : OXYGEN DOSING SYSTEM**

GeM Bid No. :- GEM/2021/B/1750786 dtd. 10.12.21

DUE DATE
05.01.2022
BY 4:00 PM

GeM Bid No. :- GEM/2021/B/1750786

BHEL Enquiry No. :- E-6831/2021 (For reference at pem.bhel.com & bhel.com.)

**Sub:** Issuance of Corrigendum due to – a) Extension of due date for offer submission, &  
b) Uploading of **pre-Bid queries** for above mentioned project/package/tender at  
“www.pem.bhel.com” & “www.bhel.com”.

- 1) The bid submission date of tender for OXYGEN DOSING SYSTEM invited through GeM vide Bid No. GEM/2021/B/1750786 dtd. 10.12.21 is extended up to 05.01.2022 at 04:00 PM. Bidders are requested to submit their offer on or before due date & time.
- 2) Bidders to refer pre-bid queries for subject project/package/tender are **uploaded** at “www.pem.bhel.com” & “www.bhel.com” for compliance **alongwith this Corrigendum no. 2.**

Thanks And Regards

*Ashutosh Sharma*

Ashutosh Sharma  
Dy. Mgr. /BHEL PEM, Noida  
Mob. No. 9953038740

BHEL/PS-PEM  
POWER PROJECT ENGINEERING INSTITUTE,  
PLOT NO. 25, SECTOR - 16A, NOIDA (UP)

Regd. Office:  
BHEL House  
Siri Fort  
New Delhi-110049

**PRE BID CLARIFICATION**

SL.NO	VOLUME/ SECTION	PAGE NO.	CLAUSE NO.	TECHNICAL SPECIFICATION/TENDER DOCUMENT	COMPLITE DESCRIPTION OF DEVIATION	BHEL Reply
1	doc-set-nit_2021-12-10-11-08-14_ae068be024e5377cc503e2d71cb787b9	<del>85 of 251</del> 73 of 236 of PE-TS-445- 154-A101	11	Local control panel if any required for operation shall be in bidder scope.	Local control panel not required.	As per technical scope defined in the technical specification and P&IDs for Oxygen Dosing System, local control panel is not envisaged. Bidder to follow the technical specification requirements.
2	doc-set-nit_2021-12-10-11-08-14_ae068be024e5377cc503e2d71cb787b9	<del>84 of 251</del> 72 of 236 of PE-TS-445- 154-A101	7	The solenoid valves shall have a limit switch for open close feedback.Solenoid valve shall be rated for 24V DC only.	Solenoid valve will be 24V DC only.(Limit switch not applicable)	For solenoid valves of 1/2 inch size, limit switches are technically not feasible and thus not applicable.
3	doc-set-nit_2021-12-10-11-08-14_ae068be024e5377cc503e2d71cb787b9	<del>107 of 251</del> 93 of 236 of PE-TS-445- 154-A101	-	Electric motor actuators	Electric motor actuators is not applicable	As per technical scope defined in the technical specification and P&IDs for Oxygen Dosing System, electric motor actuators are not applicable.
5	doc-set-nit_2021-12-10-11-08-14_ae068be024e5377cc503e2d71cb787b9	<del>99 of 251</del> 87 of 236 of PE-TS-445- 154-A101	-	Motorised valve Actuator	Motorised valve Actuator is not applicable.	As per technical scope defined in the technical specification and P&IDs for Oxygen Dosing System, motorised valves are not applicable.
6	doc-set-nit_2021-12-10-11-08-14_ae068be024e5377cc503e2d71cb787b9	<del>84 of 251</del> 102 of 236 of PE-TS-445- 154-A101	20 (g)	Hand held configurator kit for calibration of transmitter	Not in V K Pump Scope	This requirement for transmitters stands deteled.
7	doc-set-nit_2021-12-10-11-08-14_ae068be024e5377cc503e2d71cb787b9	<del>138 of 251</del> 126 of 236 of PE-TS-445- 154-A101	<del>9</del> <del>4-9</del>	Control Valves,Actuators & Accessories	Not Applicable	As per technical scope defined in the technical specification and P&IDs for Oxygen Dosing System, Control Valves, Actuators & Accessories are not envisaged. Bidder to follow the technical specification requirements.
8	doc-set-nit_2021-12-10-11-08-14_ae068be024e5377cc503e2d71cb787b9	<del>73 of 251</del> 61 of 236 of PE-TS-445- 154-A101	4	Impulse line root/source valve Impulse line isolation valve Impulse line drain valve Impulse line fitting Impulse pipe	Not Applicable	Bidder to follow the technical specificalton requirements and supply the mandatory spares as applicable for the system.
9	doc-set-nit_2021-12-10-11-08-14_ae068be024e5377cc503e2d71cb787b9	<del>73 of 251</del> 61 of 236 of PE-TS-445- 154-A101	4 h	Fittting for copper / SS tube - Each type / Size 100 mtr.	Reconfirm,100 mtr.or 100 Nos.	Indicated quantity to be read in 'Nos'.