



Ref: E-4938/2015/CORRIGENDUM/01

Date: 10/08/2015

DUE DATE
20/08/2015
11:30AM(IST)

Our Ref:

(i) Enq No.:E-4938/2015 dated 16.07.2015

Subject: Techno-Commercial clarifications for above referred tender of DEBRIS FILTER of 2X660 MW ENNORE SEZ

Bidders to note following Techno commercial clarification:-

- 1) SCC for subject project has been revised and now SCC (Rev 01) instead of SCC (Rev 00) is applicable for subject tender enquiry. SCC Rev 01 has been uploaded on BHEL websites (www.bhel.com & www.bhelpem.com).
- 2) Financial pre-qualification requirement is now uploaded on BHEL websites (www.bhel.com & www.bhelpem.com). Bidders to submit the documents accordingly along with their offer.
- 3) Amendment no. 1 to Technical Specification is being issued along with this corrigendum.

Thanking You

With regards

For & on behalf of BHEL


Akash Verma
Engineer | PG II-2, BHEL PEM | Noida
E-MAIL: akashverma@bhelpem.co.in
Ph. No. +91-120-4368960

(Page 1 of 3)

कृपया प्रेषित करे :	Please reply to :	फ़ोन Phone No:
बीएचईएल, पीएस-पीईएम	BHEL, PS-PEM,	91-120 - 436 8864
पीपीआईआई भवन	PPEI Building,	
प्लॉट नं २५, सेक्टर १६ ए	Plot No.25, Sector 16A,	
नोएडा - २०१ ३०१ उ प्र	Noida-201301 (U.P.)	
भारत	INDIA	

पंजीकृत कार्यालय	Registered Office :
बीएचईएल हाउस	BHEL House,
सीरी फोर्ट	Siri Fort,
नयी दिल्ली - ११० ०४९	New Delhi-110049
भारत	INDIA

TANGEDCO

**2X660 MW ENNORE SEZ STPP
AT ASH DYKE OF NCTPS, CHENNAI**

AMENDMENT NO. 1

**TO TECHNICAL SPECIFICATION
FOR
DEBRIS FILTER (DF)**

**Specification No. : PE-TS-412-165-N001 (REV. 0)
Vol II B**



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
PPEI BUILDING, SECTOR 16 A
NOIDA - 201301**

	TECHNICAL SPECIFICATIONS DEBRIS FILTER	SPECN. NO.:	PE-TS-412-165-N001		
	AMENDMENT NO. 1	REV. NO.	0	DATE:	10.08.15

1.0 With reference to S.No. 5.1(b) of Datasheet A, Section D, Vol IIB of Technical Specification, please consider the Specification amended as below:

Clause as mentioned in Technical Specification	Ammended Clause
MOC of Fastners: A 193 & A 194 (In Bidder's Scope)	MOC of Fastners: SS 316L (In Bidder's Scope)

2.0 MOC of all All bolts & nuts (Not in Contact with Sea Water) shall be SS 316L.

3.0 With reference to Specification of instruments and other related items, mentioned under Section C3 and Datasheet-A of Section D1 of Vol IIB; MOC of impulse pipe, instrumentation tubes, all type of instrumentation erection hardware and the instruments coming in sea water area is amended as "super duplex SS" suitable for sea water.