

Project Engineering
Management

Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)



Ref: E-5528/2016/CORRIGENDUM/01

Date: 27/03/2017

DUE DATE
31/03/2017
14:00 PM(IST)

Our Ref:

(i) Enq No.:- E-5528/2016 dated 20.03.2017

Subject: Technical clarification for above referred tender of HT XLPE POWER CABLE of 2X660 MW ENNORE SEZ

1) Technical Clarification is being issued along with this corrigendum.

Thanking You

With regards

For & on behalf of BHEL

(POOJA BHARDWAJ)
DY. MANAGER/ PGII-2
PEM, BHEL, Noida

कृपया प्रेषित करें : Please reply to : फ़ोन Phone No:
बीएचईएल, पीएस-पीडिएम् BHEL, PS-PEM, 91-120 - 436 8864
पीपीआई भवन PPEI Building, : 8693
प्लॉट नं २५, सेक्टर १६ ए Plot No.25, Sector 16A,

पंजीकृत कार्यालय Registered Office :
बीएचईएल हाउस BHEL House,
सीरी फोर्ट Siri Fort,
नयी दिल्ली - ११० ०४९ New Delhi-110049
भारत INDIA

2X660 MW ENNORE TPS
CORRIGENDA TO TECHNICAL SPECIFICATION FOR HT XLPE POWER CABLES
PE-TS-412-507-E001

Sr. No.	Ref. Section	Clause No.	Specific requirement/ Change
1	data Sheet	10.0 h 1. (i)	Method of application for multi core cable with with Filler & Inner sheath shall be pressure/ vacuum extruded instead of pressure extruded.
2	data Sheet	10.0 h 2	Method of application for Single Core Cable Inner Sheath shall be Extruded instead of Pressure Extruded.

Prepared
27/9/12