

Date: 13/05/2020

PROJECT: 5X800 MW YADADRI TPS
PACKAGE: GENERATOR CIRCUIT BREAKER
REF ENQUIRY NO: PE/PG/YAD/E-6422/2020 dated 12.04.2020
DUE DATE: 19.05.2020 14:00 HRS IST
SUBJECT: TECHNICAL CLARIFICATION TO BIDDER

CORRIGENDUM - 02

Based on Technical clarification raised by Bidder, please find below moment of inertia of generator, exciter and Turbine area: -

1.) Generator area

Generator: 15886 Kg-M²

Exciter: 570 Kg-M²

2.) Turbine area

Rotor	Moment Of Inertia (kgm ²)
HP	1217
IP	5824
LP1	23741
LP2	23741

All bidders are requested to visit the website www.bhel.com (Tender Notifications Section) or www.bhelpem.com.

All future corrigenda/ amendment and due date extension, if any, for this tender shall be hosted only on above websites.

Thanking You,

With Regards,

For & on behalf of BHEL

Amit Meena

Dy. Manager/PG-II

Please reply to:
Amit Meena (DY. MANAGER/PG-II)
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM, Noida-201301 (U.P.)