

TECHNICAL CORRIGENDUM-1

1 x 250 MW Rourkela TPS / CHP

DATE: 27/12/16

Indent Ref: IS-1-16-2003/007 WT, SAC, AFD & DF PACKAGE

1. Clause no c in Proposed PQR, page 1 of 1 has to read as follows:

Existing clause no:	Revised clause no:
PQR Technical : Bidder/or his collaborator should have designed, manufactured/got manufactured, supplied, erected and commissioned at least one (1) no. of Side arm charger for hauling rake of minimum 60 wagons of minimum 110 MT gross weight each, which should have been commissioned during last seven (7) years and is in successful operation for a minimum period of two (2) years, as on 02.04.15 .	PQR Technical : Bidder/or his collaborator should have designed, manufactured/got manufactured, supplied, erected and commissioned at least one (1) no. of Side arm charger for hauling rake of minimum 58 wagons of minimum 110 MT gross weight each, which should have been commissioned during last seven (7) years and is in successful operation for a minimum period of two (2) years, as on date of bid opening .

2. Change in working point of wagon tippler complex

The working point of wagon tippler complex is changed from **(E-2572, S-51.87) TO (E-2592, S-51.87)**

3. Hopper bottom mouth opening to be considered for apron feeder pan width selection

Hopper bottom mouth opening dimension of **1.55m** is to be considered by bidder for selecting the pan width of apron feeder.

COMMERCIAL CORRIGENDUM – 1

1. Additional Commercial Clause

Consequential Damages
“Except in cases of criminal negligence or willful misconduct, the contractor shall not be liable to the Employer, whether in contract, tort, or otherwise, for any indirect or consequential loss or damage, loss of use, loss of production, or loss of profits or interest costs, provided that this exclusion shall not apply to any obligation of the Contractor to pay liquidated damages to the employer”.