



Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)

**Project Engineering
Management**

**OPEN TENDER ENQUIRY OF "OXYGEN DOSING SYSTEM"
FOR 3x800 MW PVUNL PATRATU TPP PHASE I**

Ref No.: PE/PG/PA1/E-6315/2019

Date: 06.11.2019

CORRIGENDUM/ ADDENDUM- 3

Tender Enquiry no.: PE/PG/PA1/E-6315/2019
Date: 18/10/2019,

PRE-BID CLARIFICATION

VOLUME CLAUSE	SECTION	CLAUSE NO.	PAGE NO.	SPECIFICATION REQUIREMENT	CLARIFICATION	REASONS FOR CLARIFICATION	BHEL REPLY
PE-TS-434-154-A101	IB	21	76 OF 171	Local control panel, if any required for operation shall be in bidder scope	Local control panel will not be a bidder scope of supply	Local control panel will not be a bidder scope of supply	As per technical scope for Oxygen Dosing Skids, Junction Box is to be provided.
PE-TS-434-154-A101	IB	22	76 OF 171	The solenoid operated valves/Dampers/Gate shall have a limit switch for open/close feedback. The solenoid valve and mass flow controller with read out	The solenoid operated valves/Dampers/Gate does not comes with limit switch for open/close feedback. The solenoid valve and mass flow controller does not comes with read out	The solenoid operated valves/Dampers/Gate does not comes with limit switch for open/close feedback. The solenoid valve and mass flow controller does not comes with read out	Bidder to comply technical specification requirements.
PE-TS-434-154-A101	IIA	4	81 OF 171	Bidder to provide a flame arrestor in the vent header of each of oxygen dosing skids.	Not in bidder scope of supply	Not in bidder scope of supply	Bidder to comply technical specification requirements.


Pre --bid clarification given above with this corrigendum shall be treated as part of NIT.

All the other terms and conditions of the tender enquiry remain unchanged.

All the bidders are requested to quote accordingly.

Thanking you,

Yours faithfully,
For and on behalf of BHEL


SWETANA SINGH
(Sr. Engineer/ Project Group-3)

Please reply to:
AJAY NATH (Assistant Engineer Gr. I / Project Group-3)
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM, Noida-201301 (U.P.)
Tel No. 0120-4213621/4368838.