

**PLEASE NOTE THAT BHEL IS PLEASE TO ISSUE FOLLWING CORRIGENDUM
AGAINST TENDER ENQUIRY NO. B/4011/2018/6520V1 DATED 27.04.2019 of LP BY PASS
SYSTEM WITH SPARES FOR PATRATU PROJECT:**

Please note the following corrigendum to BHEL drawing 2-12300-31000:

Clause 1.1.3 (B) is now to be read as below:

MATERIAL FOR MAJOR VALVE COMPONENTS VIZ. VALVE STEM, VALVE PLUG,
VALVE SEAT, INLET CAGE/STRAINER SHALL BE ASTM A182Gr.F92/ INCONEL
718 OR EQUIVALENT PROVEN MATERIAL SUITABLE FOR DESIGN PATAMETERS.



Kapil Yadav/DGM (PPX-BOI)