



Ref: PE/PG/NT1/E-5276/2016/CORRIGENDUM/01

Date: 16/07/2016

DUE DATE
23/07/2016
10:00 AM (IST)

Our Ref:

(i) Enq. No:- PE/PG/NT1/E-5276/2016 dated 02.07.2016

Subject: Tender Clarifications


Bidders have to note the following clarifications with reference to subject tender enquiry:-

1. Addendum No. 01 to Technical Specification# PE-TS-400-553-A001 (Rev. 02) is enclosed herewith, for bidders' consideration.
2. NIT clause No. 12 in regard to MSE suppliers is clarified as, in regard to submission of documents establishing MSE status;

'Supplier may submit the requisite documents establishing MSE status of the supplier at the time of offer/ bid opening, and after placement of PO with MSE certificate either issued earlier or after the placement of PO'

Bidders have to submit their offers inline to above clarifications within due date & time.

Thanking You,


For & on behalf of BHEL
Dheeraj Singh

Sr. Engineer | PG II-2, BHEL PEM | Noida

E-MAIL: dheerajsingh@bhelpem.co.in Ph. No. +91-120-4368864

कृपया प्रेषित करें :	Please reply to :	फ़ोन Phone No:
बीएचईएल, पीएस-पीइएम	BHEL, PS-PEM,	91-120 - 436 8864
पीपीइआई भवन	PPEI Building,	
प्लॉट नं २५, सेक्टर १६ ए	Plot No.25, Sector 16A,	
नोएडा - २०१ ३०१ उ प्र	Noida-201301 (U.P.)	
भारत	INDIA	

पंजीकृत कार्यालय	Registered Office :
बीएचईएल हाउस	BHEL House,
सीरी फोर्ट	Siri Fort,
नयी दिल्ली - ११० ०४९	New Delhi-110049
भारत	INDIA



**AIR CONDITIONING SYSTEM
2X500 MW NNTPP
SG PACKAGE**

SPECIFICATION NO. PE-TS-400-553-A001

ADDENDUM No. 1

DATE: 16.07.2016

SHEET 1 OF 2

**2X500 MW NNTPP
SG PACKAGE**

ADDENDUM No. 1

(TECH SPEC No. PE-TS-400-553-A001 R02)

AIR CONDITIONING SYSTEM



**AIR CONDITIONING SYSTEM
2X500 MW NNTTP
SG PACKAGE**

SPECIFICATION NO. PE-TS-400-553-A001

ADDENDUM No. 1

DATE: 16.07.2016

SHEET 2 OF 2

AMENDMENT TO EXISTING CLAUSES OF TECHNICAL SPECIFICATION

Sl. No.	Clause	Existing description	To be read as (Amendment)
1	--	--	Heat dissipation data of equipment/panel/appliances shall be minimum 11 KW for each ESP control room building (Air conditioned area only).
2	7.1.1 of section-C1	The minimum COP and IPLV of Screw/scroll type water chiller shall be 5.40 and 6.17 respectively as per ARI 550.	The minimum COP and IPLV of Screw/scroll type water chiller shall be 4.7 and 5.49 respectively as per ARI 550.