



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT

PROJECT : 2X800MW TANGEDCO UPPUR BTG
PACKAGE : VENTILATION SYSTEM
TENDER ENQUIRY NO.: PE/PG/UPP/E-5919/2018 dtd. 20.04.2018

DATE: - 02.05.2018

Corrigendum-01

1. Reply of Pre-bid queries are enclosed herewith.

All other terms and conditions remain unchanged. You are requested to submit your offer accordingly by due date i.e.14.05.2018 (02:00 PM).

For and on behalf of BHEL

VINIT KUMAR VERMA
(DY.MGR/BOP Ordering/BHEL-PEM)



BHARAT HEAVY ELECTRICALS LIMITED

PROJECT ENGINEERING MANAGEMENT

Sl no	Bidder clarification	BHEL Reply
1	1) In your technical specification no. PE-PS-425-554-A001, Section 1, Sub-Section-C1, Clause No. 5.1(a), you have mentioned the air washers capacity of 2,75,000 CMH, whereas in price schedule Annexure-I same is mentioned as 3,00,000 CMH. Kindly confirm the air flow capacity of air washer unit.	Refer cl. 5.1 a sub section C1 .Please follow price schedule for air washer capacity. Please read second para on page 36 of 657 as 1. 2 nos (all working) Airwashers of 3,00,000 CMH with 90 mmwc shall be provided at BC bay EL. 29.5 M of each unit 2. 2 nos (all working) Airwashers of 3,00,000 CMH with 90 mmwc shall be provided outside A row side of each unit Total 12,00,000 CMH shall be handled by all running Air washers per Unit.
2	2) In your technical specification no. PE-PS-425-554-A001, Section 1, Sub-Section-C1, Clause No. 5.1(b), you have mentioned the UAF unit of double bank spray type, whereas as per Clause No. 3.2 and P&ID same shall be consist of single bank type. Kindly confirm the no. of banks for UAF Unit.	Please follow cl. 5.1 b sub section C1 page 36 of 657 Unitary Air filtration units shall be of double bank type. Please read cl 3.2 on page 25 of 657 as Unitary Air Filtration Unit for ESP Control Buildings For ventilation of this building (except the control room), ambient air will be drawn through unitary air filtration unit of Double bank type comprising fresh air intake louvers, automatically cleanable nylon filters (with water spray) and moisture eliminator and supplied to the space by means of centrifugal fans. The supplied air will be exhausted through wall mounted gravity operated dampers to maintain an overpressure to reduce dust ingress. Please read cl 3.11 on page 32,33 of 657 as Unitary Air Filtration Each unitary air filtration shall be of double bank (cross flow) consist of Casing, Tanks, Fans, Distribution plates, Moisture eliminator and water repellent type nylon filter with frame and support, Header and standpipe with support, Spray and flooding type nozzle. Water shall be sprayed at filter bank. Screen type suction strainer, Pumps, Necessary controls & Instrumentation, and all other required accessories. All equipment, components used in unitary air filtration system shall be in line with the specification requirements stipulated in air washer units above except the fans may be of SISW type.