



**AMENDMENT ON TECHNICAL SPECIFICATION FOR CW TREATMENT PLANT
1X800 MW TSGENCO KOTHAGUDEM TPS, STAGE –VII, PALONCHA.**

SPECIFICATION NO.: PE-TS-410-156-A001

AMENDMENT NO # 1

REV. NO. 00

DATE: 15/05/2015

Page 1 of 1

The following modifications with respect to Technical Specification for **CW TREATMENT PLANT** BHEL's Technical specification no **PE-TS-410-156-A001** shall apply.

Bidder to note that existing clauses/details as appearing in the specification stands deleted and clauses/details as mentioned in "Modified to or Read as" column shall be applicable and complied by the bidder.

MODIFIED CLAUSES/PAGE NUMBERS.

Sl no.	Vol. No.	Section/ Description	Clause no	Page no	Existing clause/details	Modified to or Read as
1.	IIB	SECTION– C1	2.1-iv	18 OF 191	Diaphragm: 10% of total quantity used for each type and size with minimum no. one (1) for each type and size.	Clause deleted.
2.	IIB	SECTION– C1	P&ID	47 OF 191	The sampling line provided for pH transmitter to CW Treatment plant by BHEL.	The sampling line provided for pH transmitter to CW Treatment plant by BHEL shall be returned back to CW Forebay (consider 100 meter 40 NB CS as per IS 1239 Heavy grade Piping) by bidder. Bidder to consider 100 meter piping from CW Treatment plant to CW Forebay.
3.	III	Suggestive Price Schedule	2.5	190 OF 191	Total lump sum price on supply of all water treatment chemicals for CW Treatment Plant as specified in Technical specification No. PE-TS-317-156-A001 . (bidder to give break-ups in separate sheet)	Total lump sum price on supply of all water treatment chemicals for CW Treatment Plant as specified in Technical specification No. PE-TS-410-156-A001 . (bidder to give break-ups in separate sheet)
4.	III	Suggestive Price Schedule	2.6	190 OF 191	Erection and commissioning	Clause deleted.