



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT

PROJECT : 2X800MW TANGEDCO UPPUR BTG
PACKAGE : VENTILATION SYSTEM
TENDER ENQUIRY NO.: PE/PG/UPP/E-5919/2018 dtd. 20.04.2018

DATE: - 11.05.2018

Corrigendum-02

In reference to the above mentioned tender enquiry for **VENTILATION SYSTEM** package please note the following.

Replies of pre-bid queries.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

For and on behalf of BHEL

VINIT KUMAR VERMA
(DY.MGR/BOP Ordering/BHEL-PEM)

SI No.	Document Name	Clause No.	As per Tender	Bidder Query	BHEL reply
1	SPECIFICATION No: PE-TS-425-554-A001 SECTION : I SUB-SECTION : C 2A REV. 00 DATE: 17-04-2018 Page 6 of 17	19.7.4 Specific Requirements	Online non- chemical type scale preventer shall be used to avoid formation of scale in the Airwasher nozzles/ water circuit.	Please note that in the suggested Price Format : Annxe 1 (SI No 17) - it is showing as NON CHEMICAL SCALE INHIBITOR - 10 sets - Kindly let us know which one is correct .	Online non- chemical type scale preventer shall be provided for each Airwasher /UAF total 10 nos . "NON CHEMICAL SCALE INHIBITOR" to be read as " Online non- chemical type scale preventer " in the suggested Price Format : Annxe 1 (SI No 17)