

CORRIGENDUM-1

REF: IS-1-17-2002/DG/CR/01

DATE: 18-09-2019

SN	SHEET AND CLAUSE	ENQUIRY SPEC	CORRECTION
01	ENQUIRY SPECIFICATIONS, SHEET 5 OF 25 , SECTION-II: GENERAL INFORMATION , POWER SUPPLY, POINT NO: 05	EDG Output 1750 KVA , 1500 RPM , 415 V at site conditions	EDG Output 2000 KVA , 1500 RPM , 415 V , 0.8 pf at site conditions

