



**TENDER ENQUIRY FOR LUBE OIL TRANSFER PUMPS
FOR 1 x 660 MW UPRVUNL PANKI TPS.**

Ref No. : PE/PG/PKI/E-6304/2019

Date: 20.09.2019

CORRIGENDUM/ ADDENDUM- 1

Tender Enquiry no.: PE/PG/PKI/E-6304/2019

Date: 10.09.2019,

Extended DUE DATE
30-September- 2019
02:00 PM


1. The Due date for offer submission & Part-I opening for **LUBE OIL TRANSFER PUMPS** for aforesaid project is **30.09.2019, 02:00 P.M.** Techno-commercial offer (Part-I) shall be opened on **30.09.2019 at 03:00 P.M.** Kindly Ensure submission/uploading of offer on or before Extended due date & time i.e. by **30.09.2019, 02:00 P.M** on (<https://bhel.abcpurchase.com>).
2. Along with this Corrigendum no. 01 also find attached reply of pre-bid query – **LUBE OIL TRANSFER PUMPS**.

All other terms & conditions of NIT remains same.

All corrigenda, addenda, amendments, time extensions, clarifications etc. to the tender will be hosted on BHEL websites only (<https://bhel.abcpurchase.com>) under subject tender reference. Bidders are requested to visit our website from time to time to keep themselves updated.

Thanking you,

Yours faithfully,
For and on behalf of BHEL



20/09/19

SHRI PRAKASH
(DY. MANAGER /Project Group-3)

Please reply to:

SHRI PRAKASH –DY. MANAGER /PG-3

Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM, Noida-201301 (U.P.)
Tel No. 0120-4213621/4368838.

1 x 660 MW UPRVUNL PANKI TPP - LUBE OIL TRANSFER PUMPS
PRE-BID CLARIFICATION SCHEDULE
ENQUIRY NO.PE/PG/PKI/E-6304/2019 Dt- 09-09-2019

S.No.	Section/Clause/ Page No.	Statement of the referred clause	Clarification required	BHEL REPLY
1	Data sheet A for LOTP pump, page 107 of 125.	Material of construction Rotor/Gear - EN8 /9	MOC of rotor/Gear - EN 353	Bidder to follow technical specification.
2	Electrical portion specification: Clause 1.19.04, page 85 of 125. AND Motor datasheet C, S.No C (8), Page 102 of 125	Motor located in hazardous area shall have flameproof enclosure conforming to IS: 2148 /Equiv. as detailed below: a) Fuel Oil area : Group IIB b) Hydrogen generation plant area : Group IIC (or Group-I, Div-II as per NEC or Class-1, Gr-B, Div-II as per NEMA/IEC60034).	We come to understand from specification clause No. 1.19.04 and motor datasheet C that motor required is non flame proof for Lube oil package. Kindly confirm.	Motor is non flame proof for Lube oil transfer pumps.