

**Corrigendum 4 Dated 21-11-2024**  
**CPC Tender No. BHEL/CPC/SGL/ BOP-CVL/25/041**

**Name of Work:** Civil and Architectural works in foundations & Civil Superstructure for BOP Buildings of Unit-1 & Unit-2 at 2x800MW Singrauli STPP Stage-III, District Sonebhadra, U.P.

**Some of the Bidders sought clarifications in regard to the published tender specification. The clarifications issued by BHEL are as below:**

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification
1	BOQ ST no. A 601	Supplying & installation of engineering grade polystyrene foam backer rod (circular cross section) at 12 mm depth with minimum density of 22 kg/cum and compressive strength of 0.40 kg/sqm having dia. 25% more than the expansion joint width as joint filler at joints in concrete including nailing, coating of both faces with coal tar pitch/bitumen etc. all complete.	A 601 (Supplying & installation of engineering grade polystyrene foam backer rod (circular cross section) at 12 mm depth with minimum density of 22 kg/cum and compressive strength of 0.40 kg/sqm having dia. 25% more than the expansion joint width as joint filler at joints in concrete including nailing, coating of both faces with coal tar pitch/bitumen etc. all complete.) - Required Unit Should be in RM instead of SqM.	Tedner specifications shall prevail.
2	BOQ ST no. 610 b	Providing and fixing PVC water stops in joints conforming to IS 12200 & IS 15058 all complete for the following: (Bulb or Kicker type) - <b>230 mm wide and 8 mm thick</b>	610 b - Higher Thickness has less weightage	Tedner specifications shall prevail.
3	BOQ ST no. 704 c	Supplying, fabricating, erecting and installing following items in concrete/brickwall for all kind of works, including setting material in concrete, layout, scaffolding, cutting, forming, grinding, drilling, bolting, welding, jointing, testing etc. all complete. - <b>UPVC pipes / conduits of all diameters</b>	A 704 c - UPVC Pipers unit is in Kgs	Tedner specifications shall prevail.
4	BOQ ST no. 915 Ae	Providing, fixing and fitting of glazing of first grade class in steel/aluminium/wooden frames, where ever required, cleaning after fixing including hardware, gaskets, clips, beadings etc. all complete. - <b>3mm thick Polycarbonate sheet with profile matching with metal sheeting shall be provided. The Polycarbonate sheets shall be fire and u/v resistant, and suitable for continuous use up to a temperature of 1000C. Suitable aluminium beading shall be used. The open ends of the sheet shall be sealed as per manufacturer's recommendations .</b>	915 Ae - Temp limit Should be 100C instead of 1000C	Typo error. May please read 100 <sup>0</sup> C instead of 1000C.

Note:

- 1) All other terms and conditions against this NIT shall remain unchanged.
- 2) This corrigendum is to be submitted duly signed and stamped along with the Techno-commercial bid (Part- I).

**for BHARAT HEAVY ELECTRICALS LTD**  
**Deputy Manager/ SCT- CPC**