

BHARAT HEAVY ELECTRICALS LIMITED ,
Heavy Electrical Equipment Plant
Ranipur, Haridwar – 249 403 (UA), India



Tender Enquiry No. B/4011/2020/1374/V1 for the requirement of LP BYPASS STSEM WITH SPARES

Corrigendum -01

With reference to above tender enquiry of LPBP System of 2x660MW Khurja project, the following changes are applicable as per details given below:-

Drg No.21230050503			
Reference Clause	Description	As it Exist	To be read as
Input Data for Valve & Actuator	WIV Design Pressure/Temperature	43.2 bar (a)/100 deg. C	47 bar (a)/100 deg. C
	Water Pressure at Valve Inlet	18.04 bar (a)	17.72 bar (a)
Drg No.31230050510			
Reference Clause No.	Description	As it Exist	To be read as
Table- 1, Sl. No.- 18	Solenoid Valves for LPBP Valve & Water Injection Valve for LPBP System	1 No. each type	10% or 1 No. each type whichever is more. % should be taken based on total installed quantity applicable for 2 units (i.e. 04 Nos. LPBP Stop & Control Valves & 04 Nos. Water Injection Valves). Fraction will be rounded off to next whole number.

All other terms & conditions of the tender will remain unchanged.

SWATI JAIN (Dy.Manager/PPX-BOI)
Email: swati88@bhel.in
Ph. 01334-281690

Ashish Gupta (SDGM/ PPX-BOI)
Email: gupta.a@bhel.in
Ph. 01334- 285834