

CORRIGENDUM - 2

ITEM : RING GRANULATOR FOR CHP MECHANICAL PACKAGE - 3 X 500 MW NTPC VALLUR TPS

ENQUIRY NOS. : 77/09/6296/AK dt. 18.02.10

Changes/ deletions w.r.t. BHEL's enquiry specs. regarding the scope of supply & services :

- Sheet 3 : Transportation to site clause is taken care of in our commercial terms & conditions, the same must be adhered to as mentioned in our commercial terms & conditions.
- Sheet 3 : Control Panels & limit switches which are required for hydraulic door opening & crusher door positions only.
- Sheet 3 : Calculations (in the last sentence of this sheet) for selection of components need not be submitted by you.
- Sheet 4 : Point 1.e : Design calculations need not be submitted.
- Sheet 4 : Point 1.g : Review and vetting of fabrication drgs. of chutes and other structures need not be done by you.
- Sheet 4 : Point 4 : Since hydraulic door opening system has also been included in your scope, the last sentence of Sheet 4 in this regard may be deleted.
- Sheet 5 : Point 6 : Consumables need not be supplied by you.
- Sheet 5 : Point 9 : Vetting of foundation drgs. need not be done by you.
- Sheet 5 : Point 11 : Vetting of complete Crusher House and chute work drgs. need not be undertaken by you, however General arrangement of crushers in the crusher house GA drg. in the crusher floor w.r.t maintenance activities shall be vetted by the bidder.
- Sheet 5 : Point 12 : System integration requirements w.r.t. other systems/equipments in crusher house like dust suppression / dust extraction system & over all CHP need not be given by you. However, control requirements and control philosophy of crusher shall be in bidder's scope only.
- Sheet 5 : Point 15 : Vetting of vibration isolation system need not be done by you.
- Hydraulic door opening mechanism for crusher which was mentioned earlier as optional shall be the part of basic crusher offer.
The same has been already indicated accordingly in the price format furnished to you.

ALL ABOVE POINTS SHALL BE CONFIRMED WITHOUT ANY DEVIATIONS BY 16-04-2010.

Bidder shall furnish the revised price offer by considering all above changes / deletions w.r.t scope of supply & services in the format which shall be furnished by our commercial group.