

**LSTK-2: SYNGAS PURIFICATION UNIT**  
**(NIT NO.: PNMM/PC288/E/001)**  
**Pre Bid Clarification : Set-1, Part 1 of 4 (Technical)**

S. No.	Reference of Bidding Document				Bidder's Query	Owner's / PDIL's Reply_dtd 26.07.2024
	Section	Page No.	Clause No.	Subject		
-1	PC0288/E/001/ P-II/ SEC-3.0	Sheet 9 OF 71	5.1.(i)	Ammonia Synthesis Unit	Bidder understand that the subject tender is for syn gas purification package and not Ammonia Synthesis Unit. BCGCL/PDIL is requested to kindly issue the suitable amendment.	Subject tender is for syn gas purification package only. suitable amendment shall be followed.
0	PC0288/E/001/ P-II/ SEC-1.0	Sheet 5 OF 6	2.3.6	Proper instrument air storage and Plant air & Instrument air distribution network shall be envisaged for the Purification Plant to be taken care by the LSTK Contractor	Bidder request BCGCL/PDIL to clarify the requirement of storage & provide the Storage duration required for the plant.	Noted, Bidder to note instrument air and plant air shall only be supplied by owner at B.L. However, Bidder to consider and inform instrument air storage for adequate buffering and safe shut down requirement.
1	PC0288/E/001/ P-II/ SEC-2.0	Sheet 5 OF 10	2.6	Storage Capacity (Storage Tank Under LSTK Contractor's Scope)	Bidder request BCGCL/PDIL to clarify the requirement of storage & provide the Storage duration required for the plant.	Refer Sl. No. 0 reply above.
2	PC0288/E/001/ P-II/ SEC-2.0	Sheet 9 OF 10	3.1	Typical Analysis of Ammonia Synthesis Gas : Pressure @ B.L of Purification Plant, kg/cm 2 a (Min) 18 (hold)	Bidder request BCGCL/PDIL to provide the Ammonia syngas pressure at the B/L.	Typical Analysis of Ammonia Synthesis Gas : Pressure @ B.L of Purification Plant, kg/cm 2 a (Min) 15.5
3	PC0288/E/001/ P-II/ SEC-2.0	Sheet 9 OF 10	3.1	Typical Analysis of Ammonia Synthesis Gas : Temperature Pressure @ B.L of Purification Plant, 30 (hold)	Bidder request BCGCL/PDIL to provide the Ammonia syngas Temperature at the B/L.	Typical Analysis of Ammonia Synthesis Gas : Temperature @ B.L of Purification Plant, 20
4	PC0288/E/001/ P-II/ SEC-3.0	Sheet 3 OF 71	1.2 (h)	Chemical laboratory instruments & laboratory chemicals	Bidder request BCGCL/PDIL to provide the list of chemical laboratory instrument & Chemicals required for plant.	This shall be decided and procured by the contractor based on what analysis will be needed as per requirement. List to be provided along with the bid. Same shall be <del>subject to owner approval</del>
5	PC0288/E/001/ P-II/ SEC-3.0	Sheet 10 OF 71	6.0	The Engineering Design Specifications shall comprise of technical data and information required for the Detailed Design and Engineering, Procurement/supply of Equipment and Material, Construction, Pre-Commissioning, Start-up and Operation of the Ammonia Synthesis, Ammonia storage & associated Utilities	Bidder understand that Ammonia synthesis, Ammonia Storage & associated utilities are not associated to this package. BCGCL/PDIL is requested to kindly issue the suitable amendment.	Noted for deletion .suitable amendment shall be followed.
6	PC0288/E/001/ P-II/ SEC-3.0	Sheet 31 OF 71	6.22	Hot Flare System	Bidder understand that Hot Flare System is not applicable for this package. BCGCL/PDIL to confirm.	Bidder understanding is correct.Refer technical section 4 clause 3.5.
7	PC0288/E/001/ P-II/ SEC-3.0	Sheet 31 OF 71	6.23	HAZOP Study Report a) Basic Design and Detailed Engineering. b) Construction, Erection and Mechanical Completion. c) Plant Start-up and Commissioning.	HAZOP Study are generally conducted at detailed engineering stage of Contract during execution stage. HAZOP is not conducted for Construction, Erection and Mechanical Completion and Plant Start-up and Commissioning.  BCGCL/PDIL is requested to issue suitable amendment.	Noted HAZOP Study shall be conducted during detailed engineering stage. Suitable amendment shall be followed.

**LSTK-2: SYNGAS PURIFICATION UNIT**  
**(NIT NO.: PNMM/PC288/E/001)**  
**Pre Bid Clarification : Set-1, Part 1 of 4 (Technical)**

S. No.	Reference of Bidding Document				Bidder's Query	Owner's / PDIL's Reply_dtd 26.07.2024
	Section	Page No.	Clause No.	Subject		
8	PC009/E/001P-II/ SEC-8.0	Sheet 5 OF 14	1.1.3 SI No 11	Guaranteed Total Works Cost "A"/Day = $\sum(Q \times R)$ {SI.No.1-9}	Bidder understand that SI No 1 to 10 will be considered instead of SI no 1 to 9. BCGCL/PDIL to kindly confirm.	Bidder understanding is correct.suitable amendment shall be followed.
9	PC009/E/001P-II/ SEC-8.0	Sheet 7 OF 14	1.7.1	Product Ammonia Syn. Gas Quality Pressure Kg/Cm2abs 18 (Min.)(hold)	Bidder request BCGCL/PDIL to furnish the firm value of pressure for Guarantee case operation.	Typical Analysis of Ammonia Synthesis Gas : Pressure @ B.L of Purification Plant, kg/cm 2 a (Min) 15.5
10	PC009/E/001P-II/ SEC-8.0	Sheet 7 OF 14	1.7.2	Product Ammonia Syn. Gas Quality Tempeature 30 (Max.)(hold)	Bidder request BCGCL/PDIL to furnish the firm value of temperature for Guarantee case operation.	Typical Analysis of Ammonia Synthesis Gas : Temperature @ B.L of Purification Plant, 20
11	PC009/E/001P-II/ SEC-8.0	Sheet 8 OF 14	1.7.6	Effluent from Purification Plant:  Plant should be designed for zero liquid discharge (ZLD).	Bidder understand the process condensate collected within the plant shall be terminated at the plant battery limit as per Clause 1.8.  ZLD is not applicable for this package.  BCGCL/PDIL to kindly confirm	Bidder understanding is correct.Effluent specification to be complied by the bidder.
12	PC0288/E/001/P-II/ SEC-3.0	36/71	7.2.3	Site grading and contour drawing	Bidder requests BCGCL/PDIL to furnish the contour drawing and topo survey of the site for estimation of earth work for grading.	Topographical survey is under progress & final report (tentative) shall be shared upon completion. Final report is expected in mid August.
13	PC0288/E/001/P-II/ SEC-3.0	36/71	7.2.3	Foundations, Concrete Structures and Paving	BCGCL/PDIL is requested to provided geotechnical report applicable for the subject tender along with the Foundation and Pile recommendations. The same is required by bidder better understanding of the soil profile and most competitive price	Soil investigation survey is under progress & final report (tentative) shall be shared upon completion. Final report is expected in mid September.
14	PC0288/E/001/P-II/ SEC-4.0	13/14	7.7	Plant Elevation	BCGCL/PDIL to furnish the site NGL , FGL , FPL .	Site Levels like NGL will be available in topographical survey report. Topographical survey is under progress & final report shall be shared on CPP portal upon completion. Tentatively, final report of topographical survey is expected in mid August. FGL shall be established upon receipt of final survey report & details shall be shared on CPP portal. For other plant levels like FPL, etc refer NIT clause 1.2.1 - Site conditions of DESIGN PHILOSOPHY - CIVIL & STRUCTURAL WORKS
15				GROUND TOPOGRAPHY	Filling and Grading in the proposed areas shall be carried out using locally available soil. BCGCL/PDIL to confirm.	NIT condition shall prevail, refer <b>clause 1.3 - Grading</b> of DESIGN PHILOSOPHY - CIVIL & STRUCTURAL WORKS

**LSTK-2: SYNGAS PURIFICATION UNIT**  
**(NIT NO.: PNMM/PC288/E/001)**  
**Pre Bid Clarification : Set-1, Part 1 of 4 (Technical)**

S. No.	Reference of Bidding Document				Bidder's Query	Owner's / PDIL's Reply_dtd 26.07.2024
	Section	Page No.	Clause No.	Subject		
16				Minor Structures Not Sensitive to Settlement	Ground Improvement: It is understood that filling of ground with locally available earth to FGL in in layers not exceeding 200mm thickness to 90% Standard Proctor Density is ground improvement. BCGCL/PDIL to confirm .	NIT conditions shall prevail. Refer clause 3.2 : <b>Filling</b> in Annexure-V of DESIGN PHILOSOPHY – CIVIL & STRUCTURAL WORKS
17				Site grading	Site is assumed to be levelled and no grading is required. Micro grading of $\pm 300$ mm is only in bidder's scope. BCGCL/PDIL to Confirm	Bidder understanding is correct
18				Standard drawings	BCGCL/PDIL to furnish the standard drawings applicable for the subject tender.	Query is not clear.
19	DESIGN PHILOSOPHY – ELECTRICAL	34 of 77	9.4.1.3	11 kV & 3.3 kV Switchboard shall conforms to IS/IEC 62271-200, IAC-A FLR-50KA/40KA 1 Sec, PM, LSC 2B ....	Internal Arc fault rating of 50kA seems to be on much higher side.  For an 11kV system, Bidder request BCGCL/PDIL to accept an IAC rating equal to the short-time rating, which is 40kA for 1 second, in line with prevailing industrial practices.  BCGCL/PDIL to confirm.	as per NIT cl. No.9.4.2.3 - A study shall be conducted by LSTK Contractor to determine the rated short circuit capacity for the selection of equipment. However, Rated short circuit breaking capacity shall be as determined by the study or 40 KA for 3 sec, whichever is higher. HV Switchboard shall be suitable for Internal Arc (AFLR) withstand current of "rated short circuit current" for 1 sec.
20	TECHNICAL SPECIFICATION - HIGH VOLTAGE SWITCHBOARDS	14 of 24	-	System details : 11kV - Short time current - 40kA;		
21	DESIGN PHILOSOPHY – ELECTRICAL	34 of 77	9.4.1.6	Suitable factory fitted arc duct arrangement shall be provided for vending out the arc out of the switchgear room.	The switchgear offered will have plenum assy. above panels for exhausting the hot gases after expansion through flap in the room itself. Hence, No separate duct is required in our type tested design.  BCGCL/PDIL to confirm	Noted. Amendment shall be issued.
22	DESIGN PHILOSOPHY – ELECTRICAL	35 of 77	9.4.1.8	The switchgear shall have integral making type earth switch with proper Mechanical & Electrical interlock.	Instead of Integral Earth Switch, bidder propose for separate Earthing Breaker Trolleys for Bus & Feeder earthing  BCGCL/PDIL to kindly confirm.	Noted, Bidder to provide saperate one no.earthing trunk each with breaker for bus and feeder earthing for one no. Complete switch gear.Amendment shall be issued.
23	MASTER VENDORS LIST FOR PROJECTS ELECTRICAL ITEMS [04-00MM-0011]	EL- 23 & 24	-	810310 : HV POTENTIAL TRANSFORMER & 810309 : HV CURRENT TRANSFORMERS	As per directives issued by GoI regarding mandatory procurement through GeM (Government e- Marketplace) for the goods and services available on GeM. Hence, procuring items only through approved vendor list is not feasible. Items will be procured from GeM/bidder approved sources.  Required credentials of finalised sub vendor will be furnished for BCGCL/PDIL reference.	All electrical Items shall be procured from approved vendor list attached with NIT only. In case any vendor from NIT vendor list is not providing any item/vendor is not mentioned for any item , then , approval of vendor for that item shall be taken from client based on credentials.

**LSTK-2: SYNGAS PURIFICATION UNIT**  
**(NIT NO.: PNMM/PC288/E/001)**  
**Pre Bid Clarification : Set-1, Part 1 of 4 (Technical)**

S. No.	Reference of Bidding Document				Bidder's Query	Owner's / PDIL's Reply_dtd 26.07.2024
	Section	Page No.	Clause No.	Subject		
24	Annexure 1 to Letter Inviting Bid	Page 7 of 8	Clause 2.4.1	Technical Criteria of PQC: All documents in support of Technical PQC furnished by the BIDDERS shall be verified and certified by any one of the following independent third party inspection agency:..... .....TPIA will provide in addition a certificate towards verification and certification of documents pertaining to Technical PQC as per proforma attached as Annexure-1.15.	BCGCL/PDIL is requested to kindly allow certification of the documents submitted for the Technical Criteria of PQC by Independent Statutory Auditor of their Company.  Suitable amendment may kindly be issued in this regard as below:  "Bidders shall submit all the documents, in support of Technical Qualification Requirements (such as copy of Purchase Orders/ Work Orders/ Contract Agreements/ Client Certificates etc.), duly certified and verified for authenticity from Independent Statutory Auditor of their Company or specified Third-Party Inspection Agency (TPIA)."	Shall be replied later
25	Annexure 1 to Letter Inviting Bid	Page 7/8 of 8	Clause 2.4.2	FINANCIAL CRITERIA OF PQC: Bidder shall submit "Details of financial capability of Bidder" in prescribed format in prescribed format (Annexure-1.18) of tender document, duly signed and stamped by a Chartered Accountant / Certified Public Accountant (CPA). Further: (a) For Indian Bidders, copy of audited annual financial statements submitted in bid shall be duly certified / attested by Notary Public with legible stamp.	Bidder requests for deletion of the requirement signing of Annexure 1.18 by Chartered Accountant / Certified Public Accountant (CPA) as the Annexure 1.18 will be enclosed with extract of Annual audited statements, duly signed and stamped by a Chartered Accountant / Certified Public Accountant (CPA).	Shall be replied later
26	ITB	Page 8/9 of 37	Clause 10.0	EARNEST MONEY DEPOSIT (EMD)	As per Letter inviting Bids, Original documents are to be submitted at BCGCL/PDIL Office at Noida and beneficiary account details are provided for CIL Kolkata.  BCGCL/PDIL to kindly share the beneficiary address, in the name EMD BG is to be issued and accordingly confirm the state (WB/UP) of which stamp act is to be followed.	Shall be replied later
27	ITB	Page 12 of 37	Clause 15.3 (e)	Supply of Spares & Consumables.....	Bidder understands that these spares are only commissioning spares.	Shall be replied later
28	ITB	Page 34 of 37	Clause 29.0	Price Variation	Bidder request BCGCL/PDIL to indicate the list of price components which are due for price variation	Shall be replied later
29	ITB	Page 37 of 37	Clause 37.0	Integrity Pact	Bidder to submit the Integrity Pact along wit Bid proposal.  BCGCL/PDIL is requested to either share the pre-signed Integrity Pact to be submitted in original, along with Bid or confirm whether the signed Integrity Pact furnished with bid proposal will be signed by Owner at the time of Bid opening.	Shall be replied later

**LSTK-2: SYNGAS PURIFICATION UNIT**  
**(NIT NO.: PNMM/PC288/E/001)**  
**Pre Bid Clarification : Set-1, Part 1 of 4 (Technical)**

S. No.	Reference of Bidding Document				Bidder's Query	Owner's / PDIL's Reply_dtd 26.07.2024
	Section	Page No.	Clause No.	Subject		
30	GCC	Page 4 of 96	Clause 1.1	The Grant of Licence, .....Supply of PLANTS and Associated Cooling Towers, .....	Bidder understands that Cooling water will be provided by the owner and cooling tower is no in the scope of LSTK 2 Island Package.  Suitable amendment in this regard may kindly be issued.	Shall be replied later
31	GCC	Page 5 of 96	Clause 1.10	The CONTRACTOR shall furnish .....SOFTWARES .....	Software contains information that is proprietary in nature. Therefore, bidder requests BCGCL/PDIL to delete this <u>requirement from the scope of bidder.</u>	Shall be replied later
32	GCC	Page 5 of 96	Clause 1.14	The CONTRACTOR shall provide cross-sectional drawings wherever applicable to identify the spare part numbers and their location. The sizes of bearings, their make & number shall also be furnished.	Cross-sectional drawing may contain proprietary information. Bidder request BCGCL/PDIL to delete this requirement.	Shall be replied later
33	GCC	Page 12 of 96	Clause 3 (42)	Definition of Mechanical Completion	Raw material and utilities shall be provided by the onwer for pre-commissioning activities.	Shall be replied later
	SCC	Page 26 of 52	Clause 2.8 (g)	Raw Material and utilities as defined in Section 2.0 of Technical part of NIT shall be made available to the CONTRACTOR at one point of Syngas Purification Unit battery limit 3 months prior to the end of Mechanical Completion period for Pre-commissioning by OWNER at Syngas Purification Unit battery limit.	In case, availability of the inputs are delayed for reasons not attributable to bidder, Bidder understands that Mechanical Completion shall be deemed accepted.  BCGCL/PDIL to confirm.	Shall be replied later
34	GCC	Page 12 of 96	Clause 3 (42 - C & D)	Definition of Mechanical Completion	In case Mechanical Completion has been delayed, for the reasons not attributable to bidder, care or custody of installed catalyst/adsorbent/tower packing / internals, etc. shall be responsibility of the owner and new replacement due to delayed commissioning shall be payable to the bidder as per actuals plus applicable overheads.  BCGCL/PDIL to confirm.	Shall be replied later
35	GCC	Page 19 of 96	Clause 7.2.1	To the fullest extent permitted by Law, CONTRACTOR assumes liability for, and agrees to indemnify, protect, save and hold harmless OWNER from and against any and all Liabilities.....	Bidder understands that liability shall be limited to LSTK 2 Contract only.  BCGCL/PDIL to confirm.	Shall be replied later

**LSTK-2: SYNGAS PURIFICATION UNIT**  
**(NIT NO.: PNMM/PC288/E/001)**  
**Pre Bid Clarification : Set-1, Part 1 of 4 (Technical)**

S. No.	Reference of Bidding Document				Bidder's Query	Owner's / PDIL's Reply_dtd 26.07.2024
	Section	Page No.	Clause No.	Subject		
36	GCC	Page 27 of 96	Clause 12.3.3.5	<b>Contractor's responsibility for approved sub-contractor:</b> Include a price list (which shall be binding to the extent reasonably feasible for a period of (6) six months from the date of such PURCHASE ORDER or SUB-CONTRACT) covering all commissioning and two years spare and replacement parts relating to the subject matter of such PURCHASE ORDER or SUB-CONTRACT.	A suggestive list of spares would be included and shall be have a validity as per the bid specifications. Further, the owner may vary the quantity of spares, however, variation in quantities will not be accepted. However, complete deletion of any item shall be acceptable.  BCGCL/PDIL to confirm.	Shall be replied later
37	GCC	Page 40 of 96	Clause 29.2	The CONTRACTOR shall guarantee that the Plants, Equipment and machineries will be new and in accordance with the CONTRACT documents and free from defects in design, material and workmanship and shall give mechanical warranty for a period of Twelve (12) calendar months commencing immediately upon PRELIMINARY ACCEPTANCE as per Clause 17 SCC.....	Bidder understands that in case preliminary acceptance is delayed for the reasons not attributable to bidder, warranty will start from the date of deemed acceptance.  BCGCL/PDIL to confirm.	Shall be replied later
38	GCC	Page 53 of 96	Clause 40.3	FOR THE SETTLEMENT OF DISPUTES BETWEEN GOVERNMENT DEPARTMENT AND ANOTHER AND ONE GOVERNMENT DEPARTMENT AND PUBLIC ENTERPRISE AND ONE PUBLIC ENTERPRISE AND ANOTHER THE ARBITRATION SHALL BE AS FOLLOWS	Bidder request BCGCL/PDIL to suitably incorporate the provisions of AMRCD.	Shall be replied later
39	GCC	Page 56 of 96	Clause 49	49.0 DEFENCE OF SUITS 49.1 If any action in Court is brought against the OWNER or an officer or agent of the OWNER for the failure omission or neglect on the part of the CONTRACTOR to perform any acts, matters, covenants or things under the CONTRACT, or for damage or injury caused by the alleged omission or negligence on the part of the CONTRACTOR, his agents representatives or his SUB-CONTRACTORS or in connection with any claim based on lawful demands of SUB-CONTRACTORS, workmen, suppliers or employees, the CONTRACTOR shall in all such cases indemnify and keep the owner and/ or his representative harmless from all losses damages, expenses or decrees arising out of such action.	BCGCL/PDIL being a project owner shall indemnify the bidder to hold harmless against this provisions and request for deletion of the provisions from the bidding document.	Shall be replied later

**LSTK-2: SYNGAS PURIFICATION UNIT**  
**(NIT NO.: PNMM/PC288/E/001)**  
**Pre Bid Clarification : Set-1, Part 1 of 4 (Technical)**

S. No.	Reference of Bidding Document				Bidder's Query	Owner's / PDIL's Reply_dtd 26.07.2024
	Section	Page No.	Clause No.	Subject		
40	GCC	Page 61 of 96	Clause 55.1.5 (ii)	.....CONTRACTOR further confirms that it has included all cost of repairs of road, civil works, strengthening of bridges, culverts, widening of roads, etc. as required for transportation of ODC items of EQUIPMENT in its CONTRACT PRICE.....	In case of there is any requirement of repairs of road, civil works, strengthening of bridges, culverts, widening of roads, etc. for transportation of HLC or ODC, bidder will inform the owner to take with competent authority.  BCGCL/PDIL to confirm.	Shall be replied later
41	GCC	Page 68 of 96	Clause 55.7.5	In addition, within 14 (fourteen) working days of the date of shipment, the CONTRACTOR shall dispatch, by Air Courier, according to the instructions of the PROJECT MANAGER in this behalf, 10 (Ten) sets/copies of the said documents.	The documents required to be submitted shall be submitted to the owner by hand/courier, within the schedule as per the provisions of the bidding document.  However, requirement air courier is requested to be kindly deleted.	Shall be replied later
42	GCC	Page 75 of 96	Clause 56.4.5	Payments of the amount(s) due on the Final Bill to the extent certified by the PROJECT MANAGER, shall be made within 84 (Eighty Four) days from the due date .....	Bidder understands that Final payment will be issued after issuance of Final Acceptance Certificate. Bidder requests BCGCL/PDIL to review the requirement for release of final payment within 84 days and reduce it to 30 days in line with provisions of the terms of payment.	Shall be replied later
43	GCC	Page 83 of 96	Clause 59.1	Unless otherwise specified in Bidding Documents, it shall be the CONTRACTOR's sole responsibility to obtain all approvals from any authority (except for environment clearance and Consent to Establish/Operate.....	Usually, statutory approvals for the project are issued in the name of the owner of the project.  Thereby, compliance for obtaining statutory approval may kindly be deleted from the scope of bidder. However, data/information required for the same would be provided by the bidder, limited to the scope of LSTK 2 Island package only.	Shall be replied later
44	SCC	Page 26 of 52	Clause 2.8 (g)	.....In case of any escalation by statutory authorities in the unit rates during execution of Contract, the same shall be borne by Contractor).....	Bidder request BCGCL/PDIL to kindly delete this requirement as it is difficult to envisage the change in the unit rates for construction water and power.	Shall be replied later

**LSTK-2: SYNGAS PURIFICATION UNIT**  
**(NIT NO.: PNMM/PC288/E/001)**  
**Pre Bid Clarification : Set-1, Part 1 of 4 (Technical)**

S. No.	Reference of Bidding Document				Bidder's Query	Owner's / PDIL's Reply_dtd 26.07.2024
	Section	Page No.	Clause No.	Subject		
45	SCC	Page 26 of 52	Clause 3.2	In the event that CONTRACTOR is instructed by OWNER to perform any change order, whether it be additional work or a reduction in the scope of work, a 10% markup shall be allowed to cover the cost of overheads and profits of the CONTRACTOR on the total lump-sum cost of the CHANGE ORDER for procurement of equipment, services including third party, including all taxes, duties and all other related costs.	LSTK 2 Island package will be awarded to bidder on lumpsum basis and bidder would engage the sub-agencies for carrying out its obligations.  Therefore, bidder may have additional liability towards reduction in scope of work.  Therefore, bidder understands the 10% mark-up will be available to bidder on the additional liability that may come after reduction in the scope of work.	Shall be replied later
46	ITB	Page 15 of 37	Clause 19.5 (v)	BOCW Cess	BCGCL/PDIL to confirm the applicability of BOCW on supply and services.	Shall be replied later
47	ITB	Page 15 of 37	Clause 19.5 (v)	BOCW Cess	For carrying out site activities, bidder do not engage the labour directly and site activities are carried out through sub-agencies.  Bidder will ensure implemtnation of Provisions of BoCW through its sub-agencies and challan will be submitted to the owner. In case, bidder is not able to submit the challan, bidder will recover the applicable amount from its sub-agencies and submit the challan to owner.  <del>BCGCL/PDIL to confirm</del>	Shall be replied later
48	SCC	Page 28 of 52	Clause 7.0	Labour & Staff	Bidder has a past experience of managing the large project involving the site management either through self or through engaging sub-agencies.  Therefore, the arranement for labour & staff will be as per the bidder's procurement policy.  <del>BCGCL/PDIL to confirm</del>	Shall be replied later



**LSTK-2: SYNGAS PURIFICATION UNIT**  
**(NIT NO.: PNMM/PC288/E/001)**  
**Pre Bid Clarification : Set-1, Part 1 of 4 (Technical)**

S. No.	Reference of Bidding Document				Bidder's Query	Owner's / PDIL's Reply_dtd 26.07.2024
	Section	Page No.	Clause No.	Subject		
49	ITB	Page 12 of 37	Clause 15.3 (c)	The firm CONTRACT PRICE quoted by the Bidder shall be inclusive but not be limited to the following:.....	Bidder understand the price variation is available for supply, erection, civil & structural works, etc. of structural steel and stainless steel.	Shall be replied later
	SCC	Page 31 of 52	Clause 12.0	Price Variation Clause	However, as per ITB, price variation is not available to the bidders.	Shall be replied later
50	SCC	Page 31 of 52	Clause 12.0	Price Variation Clause	Bidder understand that price variation is available only on structural steel and stainless steel.  BCGCL/PDIL is requested to allow price variation other materials envisaged to be utilised for completion of the <del>scope of work under LSTK 2 island package</del>	Shall be replied later
51	SCC	Page 32 of 52	Clause 12.2	.....Accordingly, in case of delay by the contractor beyond contractual delivery date for reasons attributable to contractor, no upward price variation shall be payable. However, downward/ negative price variation shall be applicable for the actual completion period.	Bidder understand the price variation is payable upto approved extended completion date. BCGCL/PDIL to confirm.	Shall be replied later
52	SCC	Page 32 of 52	Clause 12.2	.....Accordingly, in case of delay by the contractor beyond contractual delivery date for reasons attributable to contractor, no upward price variation shall be payable. However, downward/ negative price variation shall be applicable for the actual completion period.	Bidder request BCGCL/PDIL to consider payment of any upward or downward variation upto approved extended completion date.	Shall be replied later
53	SCC	Page 33 of 52	Clause 12.7	Escalation formula shall be implemented only when price increase due to variation is more than +5%. However for any decrease, formula will be applicable.	Bidder request deletion of 5% limit for implementing upward price variation formula.	Shall be replied later

**LSTK-2: SYNGAS PURIFICATION UNIT**  
**(NIT NO.: PNMM/PC288/E/001)**  
**Pre Bid Clarification : Set-1, Part 1 of 4 (Technical)**

S. No.	Reference of Bidding Document				Bidder's Query	Owner's / PDIL's Reply_dtd 26.07.2024
	Section	Page No.	Clause No.	Subject		
54	SCC	Page 29/30 of 52	Clause 11.2	Indian bidders ..... and who have indicated the Foreign Currency price for such materials and/or services in their bids ..... , there shall remain any unutilized foreign currency indicated in the priced bid relevant to the formation of the CONTRACT in relation to such supplies or services, these shall be considered to be the CONTRACTOR's fee for the relative procurement or services, as the case may be, and shall be added to and paid for separately, in the Final Bill, in addition to the price of services, in Indian Rupees equivalent of such unutilised foreign currency balance(s) converted at the currency exchange rate, available at RBI'S WEBSITE, prevailing on the date of MECHANICAL COMPLETION.	Bidder request BCGCL/PDIL to consider payment of any unutilised foreign currency amount, as quoted along with bid, at the time of mechanical completion.  Further, BCGCL/PDIL is requested to pay the foreign currency in originally quoted currency only.	Shall be replied later
55	SCC	Page 30 of 52	Clause 11.3	If in the performance of the CONTRACT, the CONTRACTOR obtains or procures within India any materials or services which at the time of the bid were indicated to be procured or provided from outside India, the CONTRACTOR shall be paid only the Indian Rupee equivalent of the foreign currency cost of such materials or services as indicated in the last priced bid relevant to the formation of the CONTRACT, converted at the currency exchange rate, available at RBI'S WEBSITE prevailing on the date of payment by the CONTRACTOR for such supplies or services.	BCGCL/PDIL is requested to pay the foreign currency in originally quoted currency form only.	Shall be replied later
56	SCC	Page 30 of 52	Clause 11.3	In case of change of source of supply from Indian to foreign or vice versa net evaluated cost would be carried forward, both in respect of CIF as well as INR price and taxes and duties thereon.	Bidder request the any additional implication due to change in source of supply will be reimbursed to the bidder.	Shall be replied later
	SCC	Page 30 of 52	Clause 11.4	In case of change of source of supply from Indian to foreign or vice versa net evaluated cost would be carried forward, both in respect of CIF as well as INR price and taxes and duties thereon		Shall be replied later

**LSTK-2: SYNGAS PURIFICATION UNIT**  
**(NIT NO.: PNMM/PC288/E/001)**  
**Pre Bid Clarification : Set-1, Part 1 of 4 (Technical)**

S. No.	Reference of Bidding Document				Bidder's Query	Owner's / PDIL's Reply_dtd 26.07.2024
	Section	Page No.	Clause No.	Subject		
57	SCC	Page 30 of 52	Clause 11.7	The CONTRACTOR shall submit billing schedule which is to be approved by the OWNER. The CONTRACTOR shall submit all invoices for a particular month under a single covering letter (once in a month) based on the billing schedule duly certified by OWNER with related documents.	Bidder has envisaged supplies from various works including from sub-vendors. The billing for supply of goods including its associated services and price variation will be billed as per the supply of goods from each works.  However, Billing for the site execution works will be on monthly basis for respective price component.  BCGCL/PDIL to confirm.	Shall be replied later
58	SCC	Page 33 of 52	Clause 13	STATUTORY VARIATION IN TAXES AND DUTIES	T&D are payment to Govt. exchequer and will be billed to owner as per statutory regulation, as on date of billing.  Therefore, bidder request BCGCL/PDIL to reimburse the variation in T&D, as per actuals.  BCGCL/PDIL is requested to issue suitable amendment in this regard.	Shall be replied later
59	SCC	Page 34 of 52	Clause 14	Terms of Payment	Bidder request BCGCL/PDIL to provide the atleast 10% interest free advance on Contract price, required to carry out <u>engineering and procurement activities</u> .	Shall be replied later
60	SCC	Page 51 of 52	Clause 22.1	MAD Clause for non-availability of Syngas Purification Plant (for less than 10 days per month)	Bidder understands that Clause 22.1 is not applicable for time when the plant is not available for 10 days on continuous basis.  BCGCL/PDIL to confirm.	Shall be replied later
	SCC	Page 52 of 52	Clause 22.3	MAD charges for non- availability of Syngas Purification Plant on continuous basis (at least 10 days) during O&M Service period.		Shall be replied later
61	SCC	Page 51 of 52	Clause 22.1	MAD Clause for non-availability of Syngas Purification Plant (for less than 10 days per month)	Bidder understands that operational availability will be calculated without considering the period where Clause 22.3 is applicable.  BCGCL/PDIL to confirm.	Shall be replied later
62	Section 10.0 of Part II Technical			Spares Parts	Bidder understands that the O&M spares will be supplied by the bidder, as per the requirement during the O&M.  The list enclosed in the bidding document at Section 10.0 of Part II Technical is indicative in nature.  BCGCL/PDIL to confirm.	Shall be replied later
63	SCC			Payment Terms for O&M	Bidder request BCGCL/PDIL to provide suitable yearly escalation on the O&M price.	Shall be replied later