

**Clarification No. 04 to Technical Specification (Section-VI) of Coal Handling Plant Package of
Nabinagar STPP (3x660MW)**

ANNEXURE-II

Sl. No.	Section-Part / Sub-Section / Page / Clause	Bidder's Query		Employer's Clarification
1	Section-VI/Part-A, clause no., 2.01.02 Sub-section-II/A-1/Intent of Specification, Page 7 of 29	Coal received from BOBR wagons shall be unloaded in under ground R.C.C. Track hopper of 6000MT capacity	Customer is requested to clarify if the scope of the bidder includes the supply of compressor for wagon opening or the same will be provided by NTPC.	Bidder to note that the compressor for unloading coal from railway wagons is not included in the scope of bidder.
2	Section-VI/ Part-B, Sub-section-clause no. 4.07.02, IIIA-01Chp, Page 16 of 28	Following.....indications shall be provided in LVS... m) Bunker level.	Customer is requested to confirm if supply of Bunker level sensors/ panels/ indicators are in bidder's scope or will be in NTPC's scope.	The bunker level sensors/panels are in NTPC scope of work
3	---	---	Please provide the detail specification of VVVF Drives to be used for Vibrating feeder, Apron feeder etc. However, brief description of VVVF drive for Stacker /Reclaimer is available in NIT vide cl. no. 3.22.00 / Part-B/Sub-Sec-III/A page 4 of 10.	Bidder to refer cl 3.22.00 Part B Sub sec III A-19 for specification for other VVVF drives also

[Signature]

Sep

PACKAGE : Coal Handling Plant Package PROJECT : Nabinagar STPP (3x 660MW)	CLARIFICATION NO.04 TO BIDDING DOCUMENTS (TECHNICAL SPECIFICATIONS) DOC. NO.:CS-0370-155-2-CLRF-04	Page 1 of 2
--	--	-------------

**Clarification No. 04 to Technical Specification (Section-VI) of Coal Handling Plant Package of
Nabinagar STPP (3x660MW)**

4	---	---	CI No. 2.02.51.00 Electrical Buildings- In MCC-IC & ID room, cable trench will be consider inside the MCC room. Please confirm whether MCC-IC & ID room shall be considered single storied building.	MCC 1C building shall be single storied. MCC 1D shall be located in TP-5 in line with cl 2.02.51.00 (iv) Part A Sub Sec II A 01 of Tech specification & tender drawing no. 0370-155-POM-A-10 Rev A.
5	Technical specification, section VI, Part-B, Sub-section IIIA-01 CHP, Page 24 of 28	---	Ref. cl. No. 4.14.00(g) vide Part-B/Sub-Sec-IIIA Page 24 of 28, The specification for Position monitoring system of Travelling Tripper has not furnished in NIT. Please confirm the technical specification of the same.	The specification for positioning monitoring system shall be as per manufacturer's standard design.

Sep

PACKAGE : Coal Handling Plant Package PROJECT : Nabinagar STPP (3x 660MW)	CLARIFICATION NO.04 TO BIDDING DOCUMENTS (TECHNICAL SPECIFICATIONS) DOC. NO.:CS-0370-155-2-CLRF-04	Page 2 of 2
--	---	---------------------------