

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
पावर सेक्टर- पश्चिमी क्षेत्र
श्रीमोहिनी काम्प्लेक्स, 345 - किंग्सवे
नागपुर- 440 001



Bharat Heavy Electricals Limited
Power Sector-Western Region
Shreemohini complex, 345 - Kingsway
Nagpur -440 001

फोन / Phone 0712- 3048600 TO 604 फैक्स FAX: 0712- 3048698- 699/ 3048605 www.bhel.com

Ref: BHE/PW/PUR/RGIT-CRH/OJ-138/Clarification- 01

Date 05/12/2009

-----Page 1 of 1-----

To

ALL BIDDERS

Sub: Clarification-01: for Special Condition of Tender Specification

JOB: Providing services of HLHR crane at 4X600MW JPL-Raigarh site

TS No. BHE/PW/PUR/RGIT-CRH/OJ-138

Bidders to kindly take note of the following:

=====

Queries-01

Special Conditions of Contract (Section A): 1.1.1 Technical Requirement
(Page 16 of 77)

Sr. 05 For Boom & Jib Lengths.

As per Tender Specification Jib length to be as per Crane manufacturer's standard setup. As you are aware that Heavy Lift Cranes with 600 MT & above Capacity comes with Fixed Jib & Luffing Jib Configuration. Please inform exact Jib Type required & minimum Jib length required. Further we will provide Total Main Boom Length only which will suit your Ceiling Girder Erection. We request you to confirm the same.

Ans: Details of ceiling girder are enclosed in tender specification. We are attaching key plan drawing for further clarity. Ceiling Girder can be lifted with fixed jib and luffing jib both, you have to plan accordingly as per reference drawing .Please note that welded beam and rolled beam has also to be lifted by same crane in between the girder.

Queries: No- 2

The heaviest ceiling girder to be lifted is 167MT; top of Ceiling Girder is 95.68m. Considering the above parameters the normal crane that can do the lift is 800-1250MT whose crawler to crawler outer dimension is approx 12m whereas the crawler to crawler outer dimension specified in the tender is maximum 10.5m. We request you to please revise the crawler to crawler outer dimension to at least 12m so that suitable crane/s can be offered.

Ans:

Crawler to Crawler distance of 10.5 Meter mentioned in the tender document is indicative. Crawler to crawler outer dimension may vary from crane to crane. However, we attach key plan drawing here for further clarification w.r.t. distance between Boiler & ESP Area and distance between Boiler columns.

Contractor has to go for detailed study of attached drawings and evaluate whether the crane can march in & out and perform the lifting operation in boiler structure with offered crawler to crawler distance.

Key Plan Drawing attached.

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Clarification-01 (Clarification-OJ-138)" against NIT-7533 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

Sr DGM (Purchase)